

Balancing and Settlement Code

CVA Data Catalogue

Version 19.0

Date: 5 November 2009

CVA DATA CATALOGUE

1. Reference is made to the Balancing and Settlement Code and, in particular, to the definition of “Data Catalogue” in Section X, Annex X-1 thereof.
2. This CVA Data Catalogue is Version 19.0.
3. This CVA Data Catalogue is effective from 5 November 2009.
4. This CVA Data Catalogue has been approved by the Panel.

Intellectual Property Rights, Copyright and Disclaimer

The copyright and other intellectual property rights in this document are vested in ELEXON or appear with the consent of the copyright owner. These materials are made available for you for the purposes of your participation in the electricity industry. If you have an interest in the electricity industry, you may view, download, copy, distribute, modify, transmit, publish, sell or create derivative works (in whatever format) from this document or in other cases use for personal academic or other non-commercial purposes. All copyright and other proprietary notices contained in the document must be retained on any copy you make.

All other rights of the copyright owner not expressly dealt with above are reserved.

No representation, warranty or guarantee is made that the information in this document is accurate or complete. While care is taken in the collection and provision of this information, ELEXON Limited shall not be liable for any errors, omissions, misstatements or mistakes in any information or damages resulting from the use of this information or action taken in reliance on it.

AMENDMENT RECORD

Version	Effective Date	Description of Change	Changes Included	Mods/Panel/ Committee Refs
1.0	April 2000	Draft For Review		
1.0	May 2000	Post Internal Review		
1.1	June 2000	Inclusion of BMRA interfaces		
2.0	August 2000	NETA Baseline v1.3		
3.0	March 2001	NETA Baseline V3.2		
4.0	August 2001	Authorised, Modification P10, Change Proposal 519 and additions for consistency with Logica IDD 3.6 and EPFAL manual flows		
5.0	August 2002	Release 2 Final	P8, P18a, P33, CP508, CP527, CP547, CP555, CP560, CP569, CP593, CP595, CP597, CP615, CP619, CP755	
6.0	December 2002	December Release Final	CP511, CP532, CP559, CP566, CP632, CP751	
7.0	March 2003	February 2003 Release	P55, P71, P78, CP753, CP754, CP797	
8.0	June 2003	June Release Final	CP553, CP571, CP577, CP703, CP743, CP750, CP756, CP777, CP832, CP841, CP858, CP869, CP877 (P4 and P78 Previous Releases) and CP708	
9.0	November 2003	November 2003 Release Final		
10.0	June 2004	CVA June 2004 Release (Final)	P98, CP915, CP998. Further P98 review comments applied. P82 Removal	ISG/40/003
11.0	November 2004	CVA November 2004 Release	P98 Phase 2	
12.0	February 2005	CVA February 2005 Release	CP1078, P140	
13.0	November 2005	CVA Programme November 2005 Release	CP1061 P192	ISG/48/002
14.0	November 2006	BSC Systems November 2006 Release P194	P194	
15.0	23 August 2007	P197 Release	P197	P/115/04

Version	Effective Date	Description of Change	Changes Included	Mods/Panel/ Committee Refs
16.0	26 June 2008	June 08 Release	CP1223	ISG84/01
17.0	6 November 2008	November 08 Release	P214	ISG90/04
18.0	25 June 2009	June 09 Release	CP1265	ISG97/01 SVG97/01
19.0	5 November 2009	November 09 Release	P217	Panel 142/06

DOCUMENT APPROVAL

VERSION	DATE	REVIEWER	RESPONSIBILITY	SIGNATURE
1.0	9/5/2000	Brian Saunders	NETA Programme Director: Approval for Release.	
2.0	23/8/2000	Peter Menczer	Approval for Release	
3.0	22/03/01	Rob Muchmore	NETA CDA	22/03/01
4.0	21/08/01	Nigel Gibbs	ELEXON	
5.0	07/08/02	ISG		
V6.0	26/11/02	ISG		
V7.0	28/01/03	ISG		
V8.0	27/05/03	ISG		
V9.0	23/09/03	ISG		
V10.0	23/09/03	ISG (ISG/40/003)		25/05/2004
V11.0	23/09/03	ISG (ISG/44/004)		28/09/2004
V12.0	23/09/03	ISG (ISG/48/004)		25/01/2005
V13.0	27/09/05	ISG (ISG/56/004)		02/11/2005
V14.0	29/08/06	ISG (ISG/67/004)		02/11/2006
V15.0	23/08/2007	P/115/04	P197 Release	23/08/2007
V16.0	26/06/08	ISG84/01	CP1223	26/06/2008
V17.0	06/11/08	ISG90/04	P214	06/11/08
V18.0	25/06/09	ISG97/01 SVG97/01	CP1265	25/06/09
V19.0	05/11/09	Panel 142/06	P217	05/11/09

CONTENTS

- 1.1 Purpose of this document 7
- 1.2 Scope of the CVA Data Catalogue..... 7
- 2.1 SAA, CRA, BMRA, ECVAA and CDCA Interfaces..... 7
- 2.2 Transmission Company Interfaces..... 7
- 2.3 FAA Interfaces 7
- 3.1 Transmission Company EDT Interface Specifications..... 8
 - 3.1.1 Data File Format 8
 - 3.1.2 File Header 8
 - 3.1.3 File Footer..... 9
 - 3.1.4 Record Formats..... 9
 - 3.1.5 Repeating Structure..... 10
 - 3.1.6 File naming 12
 - 3.1.7 Use of Sequence Numbers 12
 - 3.1.8 Time..... 13
- 3.2 Transmission Company EDL Interface Specifications..... 13
 - 3.2.1 Principle 13

- Annex A **Data File Specification.**
- Annex B **Data Dictionary.**
- Annex C **Transmission Company EDL Interface.**

1 Purpose and Scope

1.1 Purpose of this document

This document, the CVA Data Catalogue contains information relating to all the communication interfaces between CVA BSC Agents or the Transmission Company and BSC Parties and Party Agents.

This document specifies, where appropriate, references to relevant sections of the Logica and EPFAL IDD Part 1 documents. The Logica and EPFAL IDD Part 1 documents contain information on data items and file formats, the participants involved in exchange of each file, and references to the owner of each file and its associated network (where this detailed information is not available in the Logica and EPFAL IDD Part 1 documents, it will be included in this document). It provides a consolidated repository of NGC EDT/EDL specs.

This document is a Code Subsidiary Document and its purpose is to form the Data File Catalogue for all CVA communications, as set out in the BSC Section O.

1.2 Scope of the CVA Data Catalogue

The CVA Data Catalogue includes all data interfaces between CVA BSC Agents (SAA, CRA, BMRA, ECVAA, CDCA, FAA) or the Transmission Company and Parties or Party Agents. It does not include SVAA interfaces, which are specified in the SVA Data Catalogue, and it does not include communications between central service providers.

Because of the different nature of the Transmission Company's EDL interface this has been excluded from the Data Dictionary and included as a separate Annex C.

2 Reference Documents

The following documents are referenced by the CVA Data Catalogue.

2.1 SAA, CRA, BMRA, ECVAA and CDCA Interfaces

Logica Interface Definition and Design Document (Part 1).

Logica Interface Definition and Design Spreadsheet (Part 1).

2.2 Transmission Company Interfaces

EDT Interface Specification

EDL Interface Specification

2.3 FAA Interfaces

EPFAL Interface Definition and Design (Part 1).

3 Interface Specifications

This section specifies the general principles that apply to all data files in the electronic data file transfer interfaces between Parties (or their agents) and the Transmission Company's Electronic Data Transfer (EDT) Interface.

Full details of the Transmission Company's Electronic Dispatch Logging (EDL) are given in Annex [C] of this document.

For information on CVA BSC Systems Interface Specifications, please refer to the Logica IDD Part 1 document and spreadsheet.

For information on FAA Interface Specifications, please refer to the EPFAL IDD Part 1 document.

3.1 Transmission Company EDT Interface Specifications

3.1.1 Data File Format

All data will be submitted using the single file format specified below. All data types for Balancing Mechanism Units (BMUs) assigned to the BSC Parties and their Agents may be included within the file.

Data within the file will be validated on a record by record basis.¹

Submissions for each BSC Party or Agent² will be made in Comma Separated Value (CSV) text formatted files. Each submission file will consist of one or more records, with each record being a single line of text.

3.1.2 File Header

The File header format is as follows.

Field	Format	Comments
Data Record Type	Alphanumeric	Up to 4 Characters. One of:
		PN Physical Notification
		QPN Quiescent Physical Notification
		BOD Bid-Offer Data
		MEL Maximum Export Limit
		MIL Maximum Import Limit
		RURE Run Up Rates Export
		RURI Run Up Rates Import
		RDRE Run Down Rates Export
		RDRI Run Down Rates Import
		NDZ Notice to Deviate from Zero
		NTO Notice to Deliver Offers

¹ Although, hypothetically, there is no upper limit to the frequency with which data may be submitted or to the size of data files, it is possible that an error on a Client system might jeopardise the stability of the entire EDT submission system by resubmitting a large file at frequent intervals. For this reason, if BSC Party's frequency of submissions exceeds a defined normal rate for a sustained period, then that Party's, or their Agent's, account shall be locked until they contact NGC to resume normal service.

² All nomenclature of Agents and their respective BMUs, including the 9-character field above, will be agreed between NGC and the relevant Agent or their representative as part of the Agent/BMU registration process.

Field	Format	Comments	
		NTB	Notice to Deliver Bids
		MZT	Minimum Zero Time
		MNZT	Minimum Non-Zero Time
		SEL	Stable Export Limit
		SIL	Stable Import Limit
		MDV	Maximum Delivery Volume
		MDP	Maximum Delivery Period
BSC Party or Agent Name	Alphanumeric	Up to 9 Characters	
BM Unit Name	Alphanumeric	Up to 9 Characters	

3.1.3 File Footer

The text string '<EOF>' indicates the end of the file.

3.1.4 Record Formats

Each record will consist of a number of fields, each separated by a comma. Each record will include a record header consisting of the same initial fields, as shown in section 3.1.2 above. The remainder of each record will contain data according to the data record type included in the record header, as defined in the main body of the CVA Data Catalogue below.

Any records that start with an asterisk (***) will be ignored, thereby allowing comments to be included in submission files.

3.1.5 Repeating Structure

The repeating structure is as defined as follows.

Id	Row Type	range	L 1	L2	L3	L4	data type	valid set	item name/group description (comments)
EDT01	F (File Type)								<u>Title of Flow (plus sub-flow number where appropriate)</u>
ABCD	R (Record Type)								record type appears as the first field in an electronic file. Record types are unique within a file type but not across all file types. The same file type may be reused in a different flow with a different structure.
Tnnnn	D (Data Item)								Each data item is assigned a Data Item Id. The Data Item Id is used for all occurrences of the same Data Item.
		1-*							range indicates how many occurrences of this record type may appear at the current level. (comment may further refine the repeating rules) 0-* indicates unlimited repeat (optional record type) 1-* indicates unlimited repeat with at least one instance of the record type 1 indicates the record type appears exactly once 2 indicates the record type appears exactly twice 48 indicates that this record type is repeated 48 times 46-50 is used where a record type is repeated 46, 48 or 50 times to contain settlement data.
			G						G indicates that this is a repeating group i.e. a record type
				1					1 indicates that this is a data item within a record type
				O					O indicates that this is an optional data item within the record type (in electronic files, this means that the field may be empty)
									Data items and nested record types must appear in the order stated.
									L1, L2... define the nesting structure.
							text(9)		this field will contain a text string with up to 9 characters
							integer(n)		this field will contain an integer with an optional leading “-“ followed by up to n digits

Id	Row Type	range	L 1	L2	L3	L4	data type	valid set	item name/group description (comments)
							decimal		this field will contain a real number
							decimal (n,d)		this field will contain a real number. There will be an optional leading “-“ followed by up to d digits after the decimal point and up to (n-d) before the decimal point
							char		this field will contain a single character
							boolean		this field will contain a single character T or F
							date		this field will contain a date YYYYMMDD
							datetime		this field will contain a date and time YYYYMMDDHHMMSS
								valid set id	the field’s values are constrained to be within the definition of the identified valid set - see section 2.2.11

3.1.6 File naming

Each submission file will have a file name consisting of two parts and a file extension. The file extension will be '.SBM' to indicate that the file contains submission data defined to be as follows:

Title	Meaning	Field Size	Field Format	Comments
TANAME	BSC Party or Agent Name	9	XXXXXXXXX	name should be padded with '_' to the full field width
SEQNO	Sequence number	4	9999	the submission sequence number

Thus, the filename will be of the form

XXXXXXXXXX9999.SBM

For example, for a BSC Party or their Agent the name 'TR_AGT', for which the previously submitted file sequence number was 20, the file name would be:

TR_AGT__0021.SBM

The BSC Party or their Agent portion of the name must correspond with the agreed name of the submitting agent. All submission files must have a 'SBM' file type marker. If these conditions are not met, the submitted file will be rejected in its entirety.

3.1.7 Use of Sequence Numbers

The submission sequence number contained within the file name must be submitted successively. Each time a file is submitted the sequence number should be incremented by one. Should a file be submitted out of sequence it will be rejected in its entirety. All subsequent out of sequence files will be rejected until a file with sequence number corresponding to the last successful submission sequence incremented by one is submitted.

The first submission made via EDT to the Transmission Company by a BSC Parties or their Agents should have a submission sequence number of 0001. Leading zeroes should be included to the full field width. After submission 9999 the next submission number should roll over to 0001.

3.1.8 Time

All times are GMT and must be a whole number of minutes. In the table definitions, the following field format conventions are used:

Time format: [CCYY-MM-DD hh:mm] where the following definitions apply:

CCYY	year	(numeric)
MM	month	(numeric)
DD	day	(numeric)
	a single space separator between date and time:3	
hh	hours	
mm	minutes	

3.2 Transmission Company EDL Interface Specifications

3.2.1 Principle

The EDL Interface is a message based rather than file based system, and as such is not part of this document. For completeness, however, an overview has been included in Annex C. The interface between the Transmission Company and Participants will in general be implemented by one of the suppliers providing this service. The necessary information for producing such an interface is available directly from the Transmission Company.

4 Data File Description Standards

All standards relating to electronic CVA BSC Agent interfaces and the data items contained therein are specified in the Logica IDD Part 1 document.

³ Whilst all data handling is automatic, the NGC format is intended to be as legible as possible. Generally additional spaces are allowed either side of fields. The only restriction on additional spaces is in the date/time field separating the date and time portions, where only a single space character must be present.