



## Test Report

**Report No** : MI596  
LTSS Limited  
**Client:** : Charwell House  
Wilsom Road  
Alton, Hampshire, GU34 5BD  
**Description** : Road/street luminaire  
**Manufacturer** : Not disclosed  
**Classification** : Class I  
**Type/Model** : LX DPR710E43DSV  
**Lamp Type** : LED  
**Condition on Receipt** : Good  
**Test Specification** : Measurement of power consumption in accordance with the  
"Unmetered Supplies Operational Information" document –  
Version 12.0 (29/11/12)  
**Date Tested** : 21/10/13  
**Conclusion** : Refer to body of Report  
**Date Issued** : 24/10/13  
**Tested by:** Z.LEES  
**Position:** Senior Laboratory Engineer  
**Approved:** K.GOVINDEN  
**Position:** Technical Manager

  


1286

These Test Results relate only to the unit tested. This Report and following report may not be reproduced except in full without the written approval of the Testing Laboratory.

Registered Office: Stafford Park 7 Telford Shropshire TF3 3BQ England  
Tel: +44 (0) 1952 290907 Fax: +44 (0) 1952 290908 Email: [lab@thelia.org.uk](mailto:lab@thelia.org.uk)  
Web: [www.thelia.org.uk](http://www.thelia.org.uk)  
Web: [www.lalab.co.uk](http://www.lalab.co.uk)

Registered in England No: 07850441 VAT Reg No GB 125 0517 50 The Lighting Industry Association Laboratories is a Trading Division of the Lighting Industry Association



## REPORT MI596

Test condition 1. 350 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	113.06	113.77	114.37	114.12	114.84
220	112.85	113.80	114.41	114.20	114.87
230	112.87	113.88	114.38	114.22	114.96
240	112.90	113.90	114.45	114.34	114.75
250	112.96	114.06	114.44	114.41	114.80

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	117.29	119.05	119.47	119.54	119.91
220	117.82	119.92	120.44	120.38	120.86
230	118.86	120.82	121.37	121.28	121.78
240	119.91	121.87	122.43	122.47	122.78
250	120.99	123.29	123.59	123.75	123.94

---

Continued on following page



## REPORT MI596

Test condition 2. 450 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	143.72	145.25	145.12	144.34	145.20
220	143.37	145.30	145.59	144.45	145.36
230	143.41	145.43	145.42	144.61	145.57
240	143.45	145.62	145.64	144.79	145.89
250	143.49	145.81	146.05	144.95	146.06

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	148.17	149.83	149.99	149.24	149.78
220	148.93	150.78	150.72	150.02	150.80
230	149.63	151.63	151.60	151.02	151.89
240	150.48	152.63	152.69	151.94	152.82
250	151.52	153.82	153.99	153.03	153.10

---

Continued on following page



## REPORT MI596

Test condition 3. 525 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	167.38	168.04	168.67	167.78	168.35
220	167.33	168.00	168.54	167.60	168.31
230	167.36	168.00	168.36	167.51	168.21
240	167.48	167.98	168.27	167.33	168.13
250	167.52	167.89	168.23	167.26	168.10

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	172.05	172.27	173.12	172.03	172.81
220	172.56	173.00	173.44	172.65	173.25
230	173.20	173.58	174.11	173.11	173.98
240	174.15	174.38	174.67	173.86	174.61
250	174.96	175.24	175.67	174.73	175.55

---

Continued on following page



## REPORT MI596

Test condition 4. 575 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	184.21	183.96	183.61	184.17	183.94
220	184.03	184.00	183.62	184.25	183.98
230	184.05	184.18	183.77	184.35	184.01
240	184.00	184.22	183.88	184.46	184.08
250	183.99	184.41	184.04	184.57	184.22

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	188.29	188.25	187.99	188.53	188.42
220	188.72	188.90	188.92	189.14	188.99
230	189.29	189.90	189.42	189.90	189.57
240	190.05	190.50	190.24	190.78	190.36
250	190.83	191.53	191.30	191.75	191.39

---

Continued on following page



## REPORT MI596

Test condition 5. 700 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	222.91	223.04	222.62	223.88	223.01
220	222.67	223.18	222.43	223.83	222.94
230	222.73	223.04	222.23	223.59	222.96
240	222.44	222.99	222.04	223.42	222.95
250	222.40	222.98	221.85	223.24	223.01

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	226.79	227.47	226.61	227.74	226.85
220	227.28	227.75	226.94	228.06	227.35
230	227.47	228.35	227.23	228.59	228.05
240	228.21	228.77	227.68	229.13	228.65
250	228.82	229.37	228.51	229.76	229.52

Continued on following page



## REPORT MI596

### ILLUSTRATION



End