



## Test Report

**Report No** : MI599  
LTSS Limited  
**Client:** : Charwell House  
Wilsom Road  
Alton, Hampshire, GU34 5BD  
**Description** : Road/street luminaire  
**Manufacturer** : Not disclosed  
**Classification** : Class I  
**Type/Model** : LX DPR704E43DSV  
**Lamp Type** : LED  
**Condition on Receipt** : Good  
**Test Specification** : Measurement of power consumption in accordance with the  
"Unmetered Supplies Operational Information" document –  
Version 12.0 (29/11/12)  
**Date Tested** : 22/10/13  
**Conclusion** : Refer to body of Report  
**Date Issued** : 28/10/13  
**Tested by:** Z.LEES  
**Position:** Senior Laboratory Engineer  
**Approved:** K.GOVINDEN  
**Position:** Technical Manager


1286

These Test Results relate only to the unit tested. This Report and following report may not be reproduced except in full without the written approval of the Testing Laboratory.

Registered Office: Stafford Park 7 Telford Shropshire TF3 3BQ England  
Tel: +44 (0) 1952 290907 Fax: +44 (0) 1952 290908 Email: [lab@thelia.org.uk](mailto:lab@thelia.org.uk)  
Web: [www.thelia.org.uk](http://www.thelia.org.uk)  
Web: [www.lalab.co.uk](http://www.lalab.co.uk)

Registered in England No: 07850441 VAT Reg No GB 125 0517 50 The Lighting Industry Association Laboratories is a Trading Division of the Lighting Industry Association



## REPORT MI599

Test condition 1. 350 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	46.02	46.32	46.47	46.22	46.78
220	46.04	46.36	46.54	46.20	46.82
230	46.11	46.39	46.57	46.22	46.86
240	46.18	46.46	46.64	46.31	46.92
250	46.25	46.54	46.72	46.38	47.04

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	48.95	49.26	49.63	49.27	49.88
220	49.52	49.66	49.99	49.70	50.23
230	50.04	50.27	50.45	50.24	50.74
240	50.76	50.95	51.12	50.89	51.42
250	51.40	51.63	51.82	51.66	52.28

Continued on following page



## REPORT MI599

Test condition 2. 450 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	58.86	59.35	58.89	59.00	58.99
220	58.94	59.46	58.99	59.08	59.05
230	59.02	59.55	59.04	59.15	58.88
240	59.12	59.62	59.11	59.24	58.95
250	59.27	59.78	59.28	59.37	59.03

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	61.46	61.99	61.57	61.82	61.96
220	61.97	62.45	62.01	62.15	62.22
230	62.40	62.93	62.45	62.52	62.42
240	63.12	63.59	63.09	63.20	63.04
250	63.72	64.18	63.65	63.75	63.75

---

Continued on following page



## REPORT MI599

Test condition 3. 525 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	68.12	68.89	69.01	68.74	68.13
220	68.13	68.90	69.03	68.71	68.12
230	68.12	68.88	69.06	68.72	68.13
240	68.14	68.88	69.08	68.74	68.21
250	68.19	68.92	69.09	68.74	68.14

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	70.79	71.38	71.51	71.19	70.70
220	70.87	71.60	71.69	71.47	70.84
230	71.37	72.00	72.22	71.82	71.24
240	71.84	72.46	72.68	72.41	71.74
250	72.32	73.01	73.14	72.93	72.21

---

Continued on following page



## REPORT MI599

Test condition 4. 575 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	74.56	75.10	74.66	75.40	75.38
220	74.62	75.19	74.74	75.50	75.41
230	74.65	75.26	74.80	75.57	75.48
240	74.76	75.28	74.83	75.68	75.54
250	74.91	75.42	75.21	75.75	75.75

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	76.78	77.37	77.10	77.89	77.63
220	77.23	77.82	77.31	78.11	78.04
230	77.77	78.25	77.78	78.56	78.45
240	78.21	78.67	78.25	79.12	78.96
250	78.82	79.25	78.95	79.62	79.63

---

Continued on following page



## REPORT MI599

Test condition 5. 700 mA Operation.

### Watts

Voltage	Sample Number				
	1	2	3	4	5
210	91.83	91.55	91.05	91.29	91.09
220	91.73	91.50	90.97	91.28	91.07
230	91.67	91.45	90.95	91.25	91.03
240	91.52	91.42	90.90	91.24	91.02
250	91.53	91.39	90.90	91.22	91.00

### VA

Voltage	Sample Number				
	1	2	3	4	5
210	94.00	93.68	93.29	93.52	93.22
220	94.11	93.82	93.40	93.62	93.39
230	94.33	94.05	93.61	93.90	93.71
240	94.64	94.43	93.98	94.38	94.10
250	95.17	94.82	94.42	94.75	94.40


---

Continued on following page



## REPORT MI599

### ILLUSTRATION



---

End