



Test Report

Report No : L14529
Client: : LPA Excil Electronics
Ripley Drive
Normanton
West Yorkshire, WF6 1QT
Description : Lumitray Stan Nat
Manufacturer : Not Disclosed
Type/Model : LTY993S18ND
Test Specification : Measurement of power consumption in accordance with the
“Unmetered Supplies Operational Information” document –
Version 13.0 (7/11/13)
Date Tested : 11/09/14
Conclusion : Refer to body of Report
Date of Issue : 15/09/14
Date of Expiry : 14/09/19

Tested by: C.LOVEITT
Position: Laboratory Technician

Approved by: J.ADAMS
Position: Laboratory Supervisor



These test results relate only to the unit(s) tested. This Report and any subsequent report(s) may not be reproduced except in full without the written approval of the Testing Laboratory.



INTRODUCTION

LPA Excil Electronics has supplied the product identified in table 1 for measurement of power consumption in accordance with the “Unmetered Supplies Operational Information” document – Version 13.0 (7/11/13).

PRODUCT DETAILS

Table 1. Test Sample Details

Product Description	Lumitray Stan Nat
Model No.	LTY993S18ND
Number of Samples	Five
Condition on Receipt	Good
Nominal Dimensions	Not Applicable
Product Supply Requirement	240V 50Hz
Lamp Type and Power	LED
Sampling Method: Test samples selected and supplied by client, no sampling method specified by client.	

RESULTS

Table 2. Wattage and VA results for Lumitray Stan Nat

Operating Mode	100%				
Watts					
Voltage	Sample Number				
	1	2	3	4	5
210	35.36	35.46	35.25	35.11	35.22
220	35.37	35.46	35.26	35.12	35.23
230	35.38	35.47	35.26	35.13	35.23
240	35.39	35.48	35.28	35.14	35.24
250	35.41	35.49	35.29	35.15	35.25
VA					
Voltage	Sample Number				
	1	2	3	4	5
210	37.39	37.47	37.29	37.12	37.19
220	37.71	37.79	37.60	37.45	37.51
230	38.09	38.17	37.99	37.81	37.86
240	38.47	38.54	38.37	38.24	38.28
250	38.93	39.00	38.83	38.70	38.74

Continued on following page

This page is to be read in conjunction with the first page of this report

DEVIATION(S) FROM TEST STANDARD

No reported deviations from test standard.

MEASUREMENT UNCERTAINTY

The following expanded uncertainties apply to the measurements shown in the results;

Apparent Power (W): $\pm 0.69\%$, True Power (VA): $\pm 0.61\%$

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a coverage probability of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

Continued on following page

ILLUSTRATION



Figure 1. *Image of tested samples*

End