

No	Manufacturer	Model	Meter Type	(See Note 7) Outstations with a fixed Pulse Multiplier of 1	(See Note 6) Data Transfer Network Data Item J0471 'Outstation Type'	Compliance							Protocol											
						CoP1	CoP2	CoP3	CoP5	CoP6	CoP7	CoP10	IMServ Europe Ltd	Metering Services Ltd	Npower Northern Ltd	Scottish & Southern Energy Plc	Siemens Metering Services	SP Dataserve Ltd	Stark Software International Ltd	TMA Data Management	SMS Energy Services Limited			
						Latest Issue Issue 2 26/02/2015	Latest Issue Issue 4 26/02/2015	Latest Issue Issue 5 26/02/2015	Latest Issue Issue 6 26/02/2015	Latest Issue Issue 4 26/11/2009	Latest Issue Issue 2 26/11/2009	Latest Issue Issue 2 26/02/2015	HHDC & CDCA	HHDC	HHDC	HHDC	HHDC	HHDC	HHDC	HHDC	HHDC			
49	Landis + Gyr	E650	ZMD410CT44.xxx7 S3, ZMD410CT44.xxx9 S3, ZFD410CT44.xxx7, ZFD410CT44.xxx9 S3 Firmware Version: B31 & B32		ZMD			Issue 5 08/01/2013	Issue 6 08/01/2013			Issue 2 08/01/2013	EIServer 8.7 on Windows XP, SP3 21/01/2010											
	Landis + Gyr	E650	ZMD310CT44.xxx7 S3a, ZMD310CT44.xxx9 S3a Firmware Version: B31 & B32						Issue 6 08/01/2013			Issue 2 08/01/2013												
	Landis + Gyr	E650	ZMD405CT44.xxx7 S3, ZMD405CT44.xxx9 S3 Firmware Version: B31 & B32					Issue 4 08/01/2013	Issue 5 08/01/2013	Issue 6 08/01/2013				Issue 2 08/01/2013										MDR v3.4 05/11/2012
	Landis + Gyr	E650	ZMD402CT44.0457 S3, ZMD402CT44.0459 S3, ZFD402CT44.0457 S3, ZFD402CT44.0459 S3, ZMD402CT44.0467 S3, ZFD402CT44.0467 S3, ZFD402CT44.0469 S3, ZFD402CT44.0469 S3 Firmware Version: B31 & B32					Issue 2 08/01/2013	Issue 4 08/01/2013	Issue 5 08/01/2013	Issue 6 08/01/2013				Issue 2 08/01/2013									
50	Kaifa Technology Co Ltd	MA110	050502150211, 050206150211		KRJ							Issue 2 4/05/2016												
	Kaifa Technology Co Ltd	MA309	260306160301, 060300160301											Issue 2 4/05/2016										

The following Meter types are included for the purposes only of providing an Outstation type for use in the DTC data item J0471 Outstation Type.

Blue text in this document denotes the most recent changes

Elster	A1440	A14
--------	-------	-----

Compliance and Protocol approvals List V51.0

Notes

- 1) Not used
- 2) Premier has dispensation (D334) so that it can be installed in COP2 installations up to 31 July 2006
- 3) ISG has approved dispensation (D339) which allows this Metering Equipment type to be installed until 23 February 2008 (and will continue to be applicable for the life time of the Metering System). For new Metering System registrations after this date, Metering Equipment will be subject to compliance with the current issue of the relevant Code of Practice.
- 4) Prometer R & W with the firmware package versions listed in this row of the table are subject to dispensation D340.
- 5) ISG has approved dispensation (D344) which allows this Metering Equipment type to be used for all issues of CoP1 and CoP2 up to and including CoP1 Issue 2 and CoP2 Issue 4.
- 6) These Outstation codes will become effective from 4 November 2010 (CP1315)
- 7) For SVA purposes, Only Outstations that have been identified as having a fixed pulse multiplier of 1 may be exempt from a SVA proving test in accordance with BSCPs 514 and 502

Note: CoP5 Issue 6 compliances refer to communications by means of interrogation unless otherwise stated.
 Protocols for use with CoP5 Issue 6 compliant metering applies to communications by means of interrogation unless otherwise stated.

CoP4 Sample Calibrations

Meter Type	Sample Calibration Year									
	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019
Prometer R/W (Registered against CoP1 or 2)	✓	✓	✓	✓	✓					
Prometer R/W (Registered against CoP3, 5, 6 or 7)						✓	✓	✓	✓	✓

This table shows which Meters Types require Sample Calibrations in the indicated year in accordance with CoP4 Section 5.2