

1 Background

As part of the Anglesey Distribution Network reinforcement scheme, SP Manweb have installed a 2nd 132/33kV Grid Transformer at Caergeiliog substation (GT2). This additional Grid Transformer helps to maintain supplies for the underlying Amlwch/Caergeiliog group on the isle of Anglesey.

The connection to supply GT2 from the National Grid network for this arrangement differs from typical supply arrangements elsewhere in the SP Manweb Network. The connection is ultimately derived from Wylfa GSP (with National Grid owning and operating the 132kV Busbars at Wylfa). The connection for Caergeiliog GT2 is via a teed connection to a National Grid 132kV owned circuit (EV Line) at tower location EV79 which runs from Wylfa to Penrhos and the south of the island. This Tee point location is some 18km from Wylfa.

A newly constructed SP Manweb 132kV circuit connects this “Interface” point to the SP Manweb Network via a 1.4km circuit into Caergeiliog and GT2 and then onto the 33kV busbars. This is illustrated below.




Figure 1 - Outline supply arrangement (Wylfa)




Figure 2 – Operational Diagram - (Caergeiliog GT2)

Due to the remote location and practicalities of locating a meter at the National Grid / SP Manweb interface point and tee off point on tower EV79, a dispensation is required as it is proposed the metered is located at Caergeiliog and at 33kV.

The losses therefore with the SPM network assets from the metering location at Caergeiliog GT2/33kV to the EV79 Tee off point at the 132kV interface needs to be taken into account as these would not be accounted for at the remote metering location as they would be upstream of the meters location and so not be visible.

2 SLD

The diagram below shows a single line diagram representation of the connection from the tower EV79 Tee off to Caergeiliog GT2/33kV.




Figure 3 – SLD

3 Impedance data used

3.1 Conductors 132kV

The conductors used are standard supplied equipment. As such, their impedance, reactance and resistance values already exist with the SPM Manweb IPSA Power system model and conductor database. Further information on the installed span lengths are provided in Appendix A.

In summary the base impedance information for the 132kV circuits is illustrated below. Note that a typical modelling system base of 100MVA has been applied as unless otherwise stated.

Base Impedance		R1, pu per km	X1, pu per km	R0, pu per km	X0, pu per km	B, uS pu per km
200mm AAAC Poplar	OHL - Trident	0.0007461	0.002169	0.0015509	0.007504	0.000535
1200mm XLPE AL Cable	Cable - Ducter	0.017219251	0.009090909	0.056684492	0.034224599	0.000143336
Circuit data used		R1, pu	X1, pu	R0, pu	X0, pu	B, uS pu
200mm AAAC Poplar	OHL - Trident	0.000574146	0.001669111	0.001193464	0.005774553	0.000411699
1200mm XLPE AL Cable	Cable - Ducter	0.01172631	0.006190909	0.038602139	0.023306952	9.76115E-05
	Total	0.0123005	0.0078600	0.0397956	0.0290815	0.0005093

3.2 Conductors 33kV

The base impedance information for the 33kV circuit (GT2 Tails) is illustrated below.

Base Impedance		R1, pu per km	X1, pu per km	R0, pu per km	X0, pu per km	B, uS pu per km
1 x 630mm CU XLPE		0.003857	0.009231	0.01157	0.009231	0.001163
2 x 630mm CU XLPE		0.0019285	0.0046155	0.005785	0.0046155	0.002326
Circuit data used		R1, pu	X1, pu	R0, pu	X0, pu	B, uS pu
2 x 630mm CU XLPE		0.0001350	0.0003231	0.0004050	0.0003231	0.0001628

The IPSA model data tables are also provided in Appendix B for completeness and shows agreement with the data tables here.

3.3 Caergeiliog 132/33kV GT2

The actual Grid transformer name plate Impedance information is provided in Appendix C for completeness. SP Manweb has a standard 60MVA Grid transformer specification and impedance envelope (typically 20% impedance on rating). This is necessary to ensure system fault level infeed compliance and voltage regulation. Transformer X/R ratios of 25 and zero sequence to positive sequence impedance ratios of 85% are typical.

It is important to note that, in this instance, these values are solely for load flow purposes as the Grid Transformer losses are specified and shown in Appendix C on the nameplate. These losses are therefore taken into account in the calculations as they are based on the transformers FAT measurement results (Factory Acceptance Test) and so it is prudent to use these.

4 Modelling

4.1 IPSA V2 Model

An IPSA model was established to calculate the circuit losses. The values used in the IPSA model are shown in Appendix B, and are based on the data previously discussed. This data matches that within the SPM complete network model, but this simple model was created for simplicity. The model is illustrated below.




Figure 4 – IPSA Model

4.2 Losses - Circuit

Circuit losses were calculated using IPSA for a range of transformer loadings, up to the rating of the transformer at 60 MVA. This was done for unity power factor and a power factor of 0.95. The diagram below shows the losses for a transformer load factor of 0.3, 0.6 and 1, or 20, 40 and 60MVA.




Figure 5 – IPSA Model example circuit losses for transformer load factor of 0.3, 0.6 & 1 at UPF

As mentioned before, we are only concerned with the losses from the NG – EV79 location to Caergeiliog. The losses therefore for the upstream National Grid line is illustrated but has been omitted from the summations. The values for the model for the National Grid EV line was provided to SPEN and is the same as that used within this and the SPEN whole system model.

Circuit ohmic losses are typically proportional to the square of the current, and this can be seen from above.

4.3 Losses - Transformer

As shown in Appendix C, the transformer name plate shows the losses within the 60MVA GT2 as $P_0=17.08\text{kW}$ and $P_k=185.68\text{kW}$. These have therefore been applied and again have been on a basis they are proportional to the square of the transformer load factor.

4.4 Losses - Adjustment

From the IPSA results, data outlined and shown in the Appendices, an adjustment curve can be derived and applied to the actual observed metered reading. This adjustment takes cognisance of the inferred upstream losses from the 33kV meter location to the EV79 POC as a result of SPM's:

1. 33kV Grid Transformer tails (2 x 630mm² CU Cable – 70m)
2. 132/33kV Caergeiliog GT 2 (60MVA – 20.27% on rating)
3. MM 132kV circuit from Caergeiliog to EV79 Tee location
 - a. Cable section (1200mm² AL Cable – 681m)
 - b. OHL Trident section (200mm² Poplar OHL – 735m)
 - c. Downleads (200mm² Poplar OHL –35m)

Note the Figure 6 and the proposed measured kW adjustment has an intercept of 17.08kW, as this takes into account the no load losses for Caergeiliog GT 2 as per nameplate.




Figure 6 – Caergeiliog (EV79 to Boundary) Losses - kW for connection of GT2





Figure 7 – Caergeiliog (EV79 to Boundary) Losses - kW for connection of GT2

[illegible]

Appendix B – IPSA Model



Grid Infeed Properties
?
×

Main
Harmonics

Busbar
NG - Wylfa

Name
Grid Infeed

Status

☒ In
☐ Out

Load flow

Voltage Magnitude (pu)
1

Real Power Output (MW)

Reactive Power Output (MVar)

☐ Has generation profile

Profile
▼

Fault level

Peak LLL (MVA)
9000
RMS LLL (MVA)
3500
X2R LLL
45

Peak LG (MVA)
9000
RMS LG (MVA)
3500

AC decay (s)
0.2
RMS Fault Time (s)
0.07
Less detail <<

OK
Cancel
Help

Line Properties
?
×

Main
Ratings
Transient, harmonics and reliability

From busbar
NG - Wylfa
To busbar
NG - EV79

Name
NGT - 18.3 km
Type
Mixed
▼

Resistance (pu)
0.004016
Reactance (pu)
0.035925

Minimum Resistance (pu)
Susceptance (pu)
0.002048

Status

FROM
TO

☒ In
☐ Out
☒ In
☐ Out

☐ Zero Impedance

Zero sequence

Resistance (pu)
0.014535
Reactance (pu)
0.088616
☐ Zero sequence Only

☐ hide label and results

Database

Type
▼
Length
Parallel
1

Apply
Discard

☐ Use case-sensitive search for items

Add Section

OK
Cancel
Help

Line Properties

Main

Ratings

Transient, harmonics and reliability

From busbar

NG - EV79

To busbar

SPEN - MM8

Name

Poplar Trident 200mm (769m)

Type

OHL

Resistance (pu)

0.000574146

Reactance (pu)

0.00166911

Minimum Resistance (pu)

Susceptance (pu)

0.000411699

☐ Zero Impedance

Zero sequence

Resistance (pu)

0.00119346

Reactance (pu)

0.00577455

☐ Zero sequence Only

☐ hide label and results

Database

Type

Trident AAAC (HC): 200mm2 (75 deg)

Length

0.76953

Parallel

1

☐ Use case-sensitive search for items

FROM

☒ In
 ☐ Out

TO

☒ In
 ☐ Out

Plug-in

Edit...

Apply

Discard

Add Section

OK

Cancel

Help

Line Properties

Main

Ratings

Transient, harmonics and reliability

From busbar

SPEN - MM8

To busbar

SPEN - Caergeiliog - 132kV

Name

1200mm AL Cable (681m)

Type

Unset

Resistance (pu)

0.0117263

Reactance (pu)

0.00619091

Minimum Resistance (pu)

Susceptance (pu)

9.76115e-05

☐ Zero Impedance

Zero sequence

Resistance (pu)

0.0386021

Reactance (pu)

0.023307

☐ Zero sequence Only

☐ hide label and results

Database

Type

132UAL 1200XLPE: LEAD TREFOIL

Length

0.681

Parallel

1

☐ Use case-sensitive search for items

FROM

☒ In
 ☐ Out

TO

☒ In
 ☐ Out

Plug-in

Edit...

Apply

Discard

Add Section

OK

Cancel

Help

Transformer Properties

?

×

Main

Taps and compensation

Ratings

Transient, harmonics, IEC 60909 and reliability

From Busbar

SPEN - Caergeiliog - 132kV

To Busbar

SPEN - Caergeiliog - 33kV

Name

GT2

Type

Ground mounter

Resistance (pu)

0.0135133

Reactance (pu)

0.337833

Winding, earthing and zero sequence

Winding

xd1

(earthed star - delta, -30 degree phase shift)

ZERO SEQUENCE

Resistance (pu)

0.0114863

Reactance (pu)

0.287158

W1 NEUTRAL EARTH

Resistance (pu)

Reactance (pu)

W2 NEUTRAL EARTH

Resistance (pu)

Reactance (pu)

Magnetising and Core Losses

Resistance (pu)

Reactance (pu)

☒ on from side
 ☐ on to side

Calculate...

Database

Transformer

Type

Parallel

1

Apply

Discard

Line or cable, "From" side of transformer

Line or cable, "To" side of transformer

☐ Use case-sensitive search for items

Hide database

OK

Cancel

Help

Line Properties

?

×

Main

Ratings

Transient, harmonics and reliability

From busbar

SPEN - Caergeiliog - 33kV

To busbar

SPEN - Caergeiliog - 132kV Busbars

Name

2 x 630mm CU (70m)

Type

Unset

Resistance (pu)

0.000134995

Reactance (pu)

0.000323085

Minimum Resistance (pu)

Susceptance (pu)

0.00016282

☐ Zero Impedance

Zero sequence

Resistance (pu)

0.00040495

Reactance (pu)

0.000323085

☐ Zero sequence Only

hide label and results

Database

Type

33 UC 630 1c Tref XLPE

Length

0.07

Parallel

2

Apply

Discard

☐ Use case-sensitive search for items

Status

FROM

TO

☒ In
 ☐ Out

☒ In
 ☐ Out

Plug-in

Edit...

Add Section

OK

Cancel

Help

Appendix C – Caergeiliog GT2 Namplate

