



Client : Siemens Transmission & Distribution Ltd. / Princess Road / Manchester - UK

Order : 4511167776 dated 03.05.2019

NGC EGI CODE : P4VT10

EQUIPMENT TESTED

N° 10 Capacitor Voltage transformers type : TCVT 420
 Highest system voltage : 420 kV
 Rated capacitance : 4000 pF
 Rated frequency : 50 Hz
 Serial numbers : 30149712 ÷ 30149721

Ratio (kV/V)	Terminal marking	Burden (VA)	Class
396:√3 / 110:√3	a - n	50	0,5 / 3P

ROUTINE TEST

Test performed

1) Capacitor divider

- | | | |
|----------------------------------------------------------------------------------|---------------------|---|
| 1.1) Tightness of capacitor voltage divider | (See page 06) | √ |
| 1.2) Power-frequency withstand test at 50 Hz and partial discharge measurements. | (See page 02) | √ |
| 1.3) Capacitance and tanδ measurement at power-frequency. | (See pages 03 - 04) | √ |

2) Electromagnetic unit

- | | | | | | | |
|-----------------------------------------|---|------|--------|----|---------------|---|
| 2.1) Power-frequency tests on | : | | | | | √ |
| - primary windings at 150 Hz | : | 18,6 | kV for | 40 | s | √ |
| - secondary windings at 50 Hz | : | 3 | kV for | 60 | s | √ |
| 2.2) Tightness of electromagnetic unit. | | | | | (See page 07) | √ |

3) Capacitor Voltage Transformer

- | | | | | | | |
|--------------------------------------------------------------|--|---|--------|----|---------------|---|
| 3.1) Verification of terminal markings and polarity tests. | | | | | | √ |
| 3.2) Power-frequency test on low voltage terminal at 50 Hz : | | 4 | kV for | 60 | s | √ |
| 3.3) Ferro-resonance check. | | | | | (See annex A) | √ |
| 3.4) Accuracy check (determination of errors). | | | | | (See page 05) | √ |

NOTE : Test results were satisfactory according to standard :

IEC 61869-1 edition 2007

IEC 61869-5 edition 2011

Trench Italia
Test Laboratory

Alvin Zelo



Trench Italia

STABILIMENTO DI CAIRO M.tte / CAIRO M.tte FACTORY

VERBALE DI COLLAUDO

TEST REPORT

Data / Date

10.10.2019

Ord. N°

17035/010

Pag.n° / Page n°

3/7

Capacitance and loss angle measurement


Rated capacitance : 4000 pF

Rated voltage ratio : 40,7

Capacitance of standard capacitor : 71,1 pF

Equipment used for measurement : Type 2809 Tettex

Ambient temperature : 25,8 °C



Serial number	Test procedure	Capacitance under test	TOTAL CAPACITANCE C		C ₂ Measuring voltage voltage (kV) 5,6 C ₂ (pF)	K C ₂ /C
			Measuring voltage (kV)			
			Cs : 86,0 Ci : 142,6			
			C (pF)	tgδ (%)		
30149712	A	Cs	10523,0	0,0679	162476	41,001
		Ci	6356,3	0,0739		
		C	3962,68			
	B	Cs	10540,0	0,0678		
		Ci	6359,0	0,0733		
		C	3966,14			
30149713	A	Cs	10550,3	0,0728	163058	41,037
		Ci	6373,9	0,0725		
		C	3973,40			
	B	Cs	10560,3	0,0705		
		Ci	6376,5	0,0725		
		C	3975,83			
30149714	A	Cs	10521,2	0,0788	162845	40,981
		Ci	6385,3	0,0754		
		C	3973,68			
	B	Cs	10535,6	0,0761		
		Ci	6387,4	0,0730		
		C	3976,55			
30149715	A	Cs	10538,6	0,0819	162702	40,865
		Ci	6398,9	0,0794		
		C	3981,43			
	B	Cs	10542,8	0,0790		
		Ci	6401,3	0,0758		
		C	3982,96			
30149716	A	Cs	10532,7	0,0812	163248	41,080
		Ci	6381,6	0,0605		
		C	3973,88			
	B	Cs	10538,3	0,0776		
		Ci	6384,8	0,0730		
		C	3975,92			
30149717	A	Cs	10471,0	0,0806	163235	41,311
		Ci	6346,2	0,0807		
		C	3951,37			
	B	Cs	10491,0	0,0786		
		Ci	6348,2	0,0752		
		C	3955,00			

Restricted

A : Before power frequency test and partial discharge test at 10% Upr.

B : After power frequency test and partial discharge test at 100% Upr.



Trench Italia

STABILIMENTO DI CAIRO M.tte / CAIRO M.tte FACTORY

VERBALE DI COLLAUDO

TEST REPORT

Data / Date

10.10.2019

Ord. N°

17035/010

Pag.n° / Page n°

4/7

Capacitance and loss angle measurement


Rated capacitance : 4000 pF

Rated voltage ratio : 40,7

Capacitance of standard capacitor : 71,1 pF

Equipment used for measurement : Type 2809 Tettex

Ambient temperature : 25,8 °C



Serial number	Test procedure	Capacitance under test	TOTAL CAPACITANCE C		C ₂ Measuring voltage voltage (kV) 5,6 C ₂ (pF)	K C ₂ /C
			Measuring voltage (kV)			
			Cs : 86,0 Ci : 142,6			
			C (pF)	tgδ (%)		
30149718	A	Cs	10478,8	0,0879	161822	40,867
		Ci	6364,8	0,0774		
		C	3959,69			
	B	Cs	10478,8	0,0688		
		Ci	6367,1	0,0756		
		C	3960,58			
30149719	A	Cs	10559,7	0,0727	163173	41,017
		Ci	6382,7	0,0981		
		C	3978,15			
	B	Cs	10570,8	0,0676		
		Ci	6384,6	0,0712		
		C	3980,46			
30149720	A	Cs	10654,0	0,0671	165660	41,108
		Ci	6481,5	0,0985		
		C	4029,87			
	B	Cs	10645,0	0,0668		
		Ci	6479,2	0,0981		
		C	4027,70			
30149721	A	Cs	10526,6	0,0722	165440	41,215
		Ci	6488,1	0,0980		
		C	4014,04			
	B	Cs	10539,8	0,0670		
		Ci	6496,2	0,0973		
		C	4019,06			

Restricted

A : Before power frequency test and partial discharge test at 10% Upr.

B : After power frequency test and partial discharge test at 100% Upr.

**VERBALI DI COLLAUDO**

TEST REPORT

Data / Date

10.10.2019

Ord. N°

17035/010

Pag.n° / Page n°

6/7

The test was made on the capacitor divider entirely assembled.

Before the test, they were carefully cleaned, especially on the joint parts, and maintained at 1,0 bar over operating pressure for at least eight hours.

At the end of this period, it was observed :

[illegible]

Test result :

Satisfactory, according to standard IEC 61869-5 ed. 2011

**VERBALI DI COLLAUDO**

TEST REPORT

Ord. N°

Pag.n° / Page n°

17035/010

717

The test was made on the electromagnetic unit assembled as normal service carefully cleaned, especially on the joint parts, and maintained at 1,0 bar over operating pressure for at least eight hours, the e.m.u. shall be considered to have successfully passed the test if there is no evidence of leakage.

At the end of this period, it was observed :

[illegible]

Test result :

Satisfactory, according to standard IEC 61869-1 ed. 2007



TRENCH Trench Italia

STABILIMENTO DI CAIRO M.TTE / CAIRO M.tte FACTORY

VERBALE DI COLLAUDO

TEST REPORT

Data / Date

10.10.2019

Annex A at the test report n°
17035/10 dated 10.10.2019


Pag.n° / Page n°

1/1


FERRO-RESONANCE TEST

Before the accuracy test, 3 short-circuit applications at 0.8 Upr and 3 short-circuit applications at 1.5 Upr have been performed on each TCVT with positive results. The following oscillograms related to serial number 30149712 are included for reference.


1° application at 0.8 Upr




2° application at 0.8 Upr




3° application at 0.8 Upr



1° application at 1.5 Upr



2° application at 1.5 Upr



3° application at 1.5 Upr

