

# HEADLINE REPORT

---

<b>MEETING NAME</b>	Imbalance Settlement Group
<b>Meeting number</b>	211
<b>Date of meeting</b>	20/November/2018
<b>Purpose of paper</b>	Information
<b>Classification</b>	Public
<b>Synopsis</b>	This report sets out the headlines and key decisions of the most recent ISG meeting.

---

## OPEN SESSION – DECISION PAPERS

---

### 1. Continuous Acceptance Duration Limit (CADL) and De Minimis Acceptance Threshold (DMAT) Consultation Result– ISG211/01

1.1 Following the previous ISG meeting (ISG210), ELEXON issued the DMAT and CADL review paper for industry consultation. In this consultation ELEXON invited industry to comment on the proposal to reduce DMAT from 1MWh to 0.1MWh and reduce CADL from 15 minutes to 10 minutes. The paper presented the responses received from the consultation. The ISG were invited to make its final recommendations to the BSC Panel.

1.2 The ISG:

- a) **NOTED** the consultation responses presented in this paper; and
- b) **RECOMMENDED** to the BSC Panel that DMAT be set to 0.1MWh and CADL to 10 minutes.

### 2. Market Index Definition Statement (MIDS) Review 2018 Consultation Result– ISG211/02

2.1 Following the September 2018 ISG meeting, ELEXON issued the 2018 MIDS Review paper for industry consultation. The paper invited the ISG to make its final recommendations to the BSC Panel.

2.2 The ISG:

- a) **NOTED** that no consultation response were received; and
- b) **RECOMMENDED** to the BSC Panel that the suggested MIDS changes be made.

### 3. Application for a Non-Standard BM Unit Configuration at Down Barn Farm Power Station – ISG211/03

3.1 Green Frog Power (GFP) Trading Limited applied for a non-standard BM Unit for Down Barn Farm Power Station. The ISG were invited to approve the application.

3.2 The ISG:

- a) **APPROVED** a single non-standard BM Unit status for Down Barn Farm.

### 4. Application for Non-Standard BM Unit Configurations at East Anglia One Offshore Wind Farm – ISG211/04

4.1 East Anglia ONE Limited applied for two non-standard BM Units for its East Anglia ONE Offshore Wind Farm. The ISG were invited to approve the application.

# HEADLINE REPORT

---

4.2 The ISG:

a) **APPROVED** a single non-standard BM Unit status for the wind farm operator's Plant and Apparatus associated with T\_EAAO-1.

b) **APPROVED** a single non-standard BM Unit status for the wind farm operator's Plant and Apparatus associated with T\_EAAO-2.

## 5. Application for a Non-Standard BM Unit Configuration at Sellindge Converter Station – ISG211/05

5.1 ENGIE Power Limited applied for a non-standard BM Unit for the Sellindge Converter Station. The ISG were invited to approve the application.

5.2 The ISG:

a) **APPROVED** a single non-standard BM Unit status for the Sellindge Converter Station.

## 6. CP1510 'Allow the online management of registrations, Market Entry and Market Exit' – ISG211/06

6.1 This document is the Change Proposal (CP) Assessment Report for CP1510 which ELEXON presented to the Imbalance Settlement Group (ISG) at its meeting on 20 November 2018 and will present to the Supplier Volume Allocation Group (SVG) at its meeting on 4 December 2018. The ISG considered the proposed solution and responses received to the CP Consultation. The SVG will consider the proposed solution and the responses received to the CP Consultation before making a decision on whether to approve CP1510.

6.2 The ISG:

a) **APPROVED** the proposed changes to BSCP15, BSCP25, BSCP31, BSCP38, BSCP41, BSCP65, BSCP70, BSCP71, BSCP301, CRA Service Description, and CRA User Requirements Specification;

b) **APPROVED** CP1510 for implementation on 28 February 2019 as part of the February 2019 Release; and

c) **NOTED** that CP1510 will also be presented to the SVG on 4 December 2018 for decision.

## OPEN SESSION – INFORMATION ITEMS

---

### 7. Meeting Dates 2019 – ISG211/07

7.1 This paper presented the Imbalance Settlement Group (ISG) meeting dates for 2019.

7.2 The ISG:

a) **NOTED** the ISG meeting dates for 2019.

b) **NOTED** the CP Impact Assessment timetable for 2019.

### 8. CP1513 'Updates to BSCP601, CoP3 and CoP5' – ISG211/08

8.1 This document provided information on new Change Proposal (CP) 1513 and outlined the proposed progression timetable for this change, including when it will be issued for CP Consultation in the next suitable Change Proposal Circular (CPC) batch.

8.2 The ISG:

a) **NOTED** that CP1513 has been raised;

# HEADLINE REPORT

---

- b) **NOTED** the proposed progression timetable for CP1513; and
- c) **PROVIDED** any comments or additional questions for inclusion in the CP Consultation.

## OPEN SESSION – TABLED ITEMS

---

### 9. BSC Operations Headline Report – 284/02

The BSC Operations Headline Report provided an overview of the operations of the BSC for October 2018.

The ISG:

- a) **NOTED** the report.

### 10. Change Report – 284/03

This report presents a comprehensive monthly overview of the changes in the BSC Change Process.

The ISG:

- a) **NOTED** the report.

### 11. SPAR Report – ISG211/09

11.1 The System Prices Analysis Report (SPAR) provides a monthly update on price calculations. It is published by the ELEXON Market Analysis Team to the Imbalance Settlement Group (ISG), and on the ELEXON Website ahead of the monthly ISG meeting. This SPAR report provided an overview on price calculations and analysis of System Prices and the Balancing Mechanism for October 2018.

11.2 The ISG:

- a) **NOTED** the report.