

ISG212-SPAR

REPORTING ON NOVEMBER 2018

ISSUE 37 – PUBLISHED 18 DECEMBER 2018

SYSTEM PRICE ANALYSIS REPORT

The System Prices Analysis Report (SPAR) provides a monthly update on price calculations. It is published by the ELEXON [Market Analysis Team](#) to the Imbalance Settlement Group (ISG), and on the ELEXON Website ahead of the monthly ISG meeting.

This report provides data and analysis specific to System Prices and the Balancing Mechanism¹. It demonstrates the data used to derive the prices. The data is a combination of II and SF Settlement Runs.

On 1 November 2018, the second part of Modification P305 went live. This reduced the Price Average Reference (PAR) volume to 1MWh, introduced a 'dynamic' LoLP function and increased the Value of Lost Load (VoLL) to £6,000/MWh.

1 SYSTEM PRICES AND LENGTH

This report covers the month of November. Where available, data uses the latest Settlement Run (in most cases 'II' or 'SF').

In this report, we distinguish between a 'long' and a 'short' market when analysing System Prices, because the price calculation differs between two scenarios. When the market is long, System Prices are based predominantly on the System Operator's 'sell' actions such as accepted Bids. When the market is short, System Prices are based predominantly on the System Operator's 'buy' actions. **Table 1.1** gives a summary of System Prices for November 2018, with values shown in £/MWh.


Graph 1.2 shows the distribution of System Prices across Settlement Periods in November 2018 when the market was long and short.

52% of System Prices were between £30/MWh and £60/MWh, regardless of system length. When the system was long, 87% of prices were between £40/MWh and £60/MWh. When the system was short, 82% of prices were between £70/MWh and £100/MWh, and 9% of prices were over £100/MWh.

System Price (Long)					
Month	Min	Max	Median	Mean	Std Dev
November 2018	-50.00	70.00	48.20	45.63	10.11

System Price (Short)					
Month	Min	Max	Median	Mean	Std Dev
November 2018	29.80	191.37	77.99	81.59	15.99

1.1 System Price summary by month (£/MWh)



1.2 Frequency of System Prices over the last month

¹ For further detail of the Imbalance Price calculation, see our imbalance pricing guidance: <https://www.elexon.co.uk/operations-settlement/balancing-and-settlement/imbalance-pricing/>


SYSTEM PRICE ANALYSIS REPORT

System Prices exceeded £100/MWh a total of 48 times in November 2018, compared to 69 times in October. The highest System Price of the month, £191.37/MWh, occurred in Settlement Periods 35 and 36 on 26 November 2018. The price in these Settlement Periods were set by Buy Balancing Services Adjustment Actions (BSAAs) priced at £191.37/MWh.

There were three Settlement Periods where the System Price was £0/MWh, and four negative System Prices, in November. The lowest System Price, -£50/MWh, occurred during Settlement Periods 8 and 26 on 19 November, and in Settlement Period 48 on 29 November. These prices were set by Bids from CCGT or Pumped Storage BMUs all priced at -£50/MWh.

Graph 1.3 displays the spread of System Prices in November 2018 as a box plot diagram, split between a short and long system. The middle line in each box represents the median System Price of the month, which is £77.99/MWh for short Settlement Periods and £48.20/MWh for long Settlement Periods. Each box edge represents the lower and upper quartiles (25th and 75th percentile respectively), with the Interquartile Range (difference between the Upper and Lower quartiles) being £14.50/MWh for short System Prices and £3.20/MWh for long System Prices.

Outliers are shown on the graph as crosses, and have been defined as being greater than 1.5 times the Interquartile Range (IQR) away from the Upper and Lower quartiles. Under this definition, 122 long and 32 short System Prices for November were outliers. Of the 122 long outliers, 108 were less than the lower outlier boundary. These prices ranged from -£50/MWh (the lowest System Price of the month) to £41.24/MWh.




1.3 System Price spread over the last month

SYSTEM PRICE ANALYSIS REPORT

Graph 1.3 shows daily average System Prices over the last month. In November, the average System Price was £45.63/MWh when the system was long and £81.59/MWh when the system was short.

The highest daily average price when the system was short was £96.99/MWh, and occurred on 26 November. The system was short for 27 Settlement Periods on this day.


The lowest daily average price when the system was long was £33.46/MWh on 29 November 2018. The system was long in 33 Settlement Periods on this day.



1.4 Daily average System Price over the last month

Graph 1.4 shows the variation of average System Prices across the day. Short prices were highest in Settlement Period 35, with long prices lowest in Settlement Period 8. The lowest average System Prices, regardless of market length, occurred during Settlement Period 8, when the System Price was £46.86/MWh.

Average long Settlement Period System Prices ranged between £37.16/MWh and £49.94/MWh. Average short Settlement Period prices varied from £69.10/MWh to £103.98/MWh.




1.5 Average System Price by Settlement Period over the last month

SYSTEM PRICE ANALYSIS REPORT


Graph 1.5 shows system length by day, and **Graph 1.6** shows system length by Settlement Period for November. The system was long for 54% of Settlement Periods in November.

On 20 November, the system was short for 77% of Settlement Periods. On this day, the average NIV when the system was short was 320MWh. The average System Price in a short Settlement Period was £85.43/MWh on 20 November.

Settlement Period 37 was short for 77% of the month.



1.6 Daily system length by day over the last month



1.7 System Length by Settlement Period

SYSTEM PRICE ANALYSIS REPORT

2 PARAMETERS

In this section, we consider a number of different parameters on the price. We consider:


- The impact of Flagging balancing actions;
- The impact of the Replacement Price
- The impact of NIV Tagging;
- The impact of PAR Tagging;
- The impact of DMAT and Arbitrage Tagging; and
- How these mechanisms affect which balancing actions feed into the price.

Flagging

The Imbalance Price calculation aims to distinguish between 'energy' and 'system' balancing actions. Energy balancing actions are those related to the overall energy imbalance on the system (the 'Net Imbalance Volume'). It is these 'energy' balancing actions which the Imbalance Price should reflect. System balancing actions relate to non-energy, system management actions (e.g. locational constraints).

Some actions are 'Flagged'. This means that they have been identified as potentially being 'system related', but rather than removing them completely from the price calculation (i.e. Tagging them) they may be re-priced, depending on their position in relation to the rest of the stack (a process called Classification). The System Operator (SO) flags actions when they are taken to resolve a locational constraint on the transmission network (SO-Flagging), or to correct short-term increases or decreases in generation/demand (CADL Flagging).

Graph 2.1 shows the volumes of buy and sell actions in November 2018 that have been Flagged by the SO as being constraint related. On 4 November, 90% of sell volume was SO-Flagged.



2.1 Daily volume of SO-Flagged/non-Flagged actions over the last month

SYSTEM PRICE ANALYSIS REPORT

49% of sell balancing actions taken in November had an SO-Flag, compared with 67% in October. 40% of SO-Flagged sell actions came from Balancing Services Adjustment Actions (BSAAs), 26% from CCGT BMUs Wind BMUs, and 25% from Wind BMUs. The average initial price (i.e. before any re-pricing) of a SO-Flagged sell action was -£24.76/MWh.


37% of buy balancing actions taken in November had an SO-Flag, compared to 27% in October. 63% of SO-Flagged buy actions came from BSAAs and 36% from CCGT BMUs. The average initial price of a SO-Flagged buy action was £94.80/MWh.

Any actions with a total duration of less than the CADL are flagged. CADL is currently set to 15 minutes; this may be changed to 10 minutes on 1 April 2018. If this change is approved from January SPAR onwards we will include analysis of the impact of a 10 minute CADL.

2% of buy actions and less than 1% of sell actions were CADL Flagged in November. The majority of CADL Flagged buy actions (94%) came from Pumped Storage BMUs. 50% of CADL Flagged sell actions came from CCGT BMUs, with Pumped Storage BMUs accounting for a further 43%.

SO-Flagged and CADL Flagged actions are known as 'First-Stage Flagged'. First-Stage Flagged actions may become 'Second-Stage Flagged' depending on their price in relation to other Unflagged actions. If a First-Stage Flagged balancing action has a more expensive price than the most expensive First-Stage Unflagged balancing action, it becomes Second-Stage Flagged. This means it is considered a system balancing action and becomes unpriced.

Graph 2.2 shows First and Second-Stage Flagged action volumes as a proportion of all actions taken on the system. Note these are all the accepted balancing actions – only a proportion of these will feed through to the final price calculation.



2.2 Flagged Balancing Volumes


SYSTEM PRICE ANALYSIS REPORT

The Replacement Price

Any Second-Stage Flagged action volumes left in the NIV will be repriced using the Replacement Price. In total, 50% of sell actions in November were Flagged. Of these, 5% were assigned a Replacement Price.

The Replacement Price is either based on the Replacement Price Average Reference (RPAR currently based on the most expensive 1MWh of Unflagged actions); or if no Unflagged actions remain after NIV Tagging, the Market Index Price (MIP). In November, 152 Settlement Periods had a Replacement Price based on the RPAR and 48 Settlement Periods had a Replacement Price based on the MIP. However, the majority of Settlement Periods (86%) did not have a Replacement Price.

Graph 2.3 displays the count of Settlement Periods which had a Replacement Price applied, split by the system length and if the Replacement Price was based on RPAR or the MIP. The graph also displays the average original and Replacement Price of Second-Stage Flagged actions.



2.3 Average Replacement Price, original price of repriced actions and number of Settlement Periods with Replacement Price

Sell actions will typically have their prices revised upwards by the Replacement Price for the purposes of calculating the System Price. In November, the average original price of a Second-Stage Flagged repriced sell action was £14.69/MWh and the average Replacement Price for sell actions (when the System was long) was £45.15/MWh.

38% of buy actions were Flagged; of these 7% had the Replacement Price applied. Buy actions will typically have their prices revised downwards by the Replacement Price. The average original price of a buy action with the Replacement Price applied was £111.34/MWh, and the average Replacement Price was £84.17/MWh.

If there are no Unflagged actions remaining in the NIV, the Replacement Price will default to the Market Index Price. This occurred in 29 long and 19 short Settlement Periods in November, compared to 49 long and two short Settlement Periods last month.

SYSTEM PRICE ANALYSIS REPORT

NIV and NIV Tagging

The Net Imbalance Volume (NIV) represents the direction of imbalance of the system – i.e. whether the system is long or short overall.


Graph 2.4 shows the greatest and average NIV when the system was short, and **Graph 2.5** shows the greatest and average NIVs when the system was long. Note short NIVs are depicted as positive volumes and long NIVs are depicted as negative volumes.

In almost all Settlement Periods, the System Operator will need to take balancing actions in both directions (buys and sells) to balance the system. However, for the purposes of calculating an Imbalance Price there can only be imbalance in one direction (the Net Imbalance). 'NIV Tagging' is the process which subtracts the smaller stack of balancing actions from the larger one to determine the Net Imbalance. The price is then derived from these remaining actions.


NIV Tagging has a significant impact in determining which actions feed through to prices. In November, 79% of volume was removed due to NIV tagging. The most expensive actions are NIV Tagged first; hence NIV Tagging has a dampening effect on prices when there are balancing actions in both directions.

The maximum short system NIV of the month (1,113MWh) was seen on 22 November in Settlement Period 21, where the System Price was £81.51/MWh.

The minimum long system NIV of the month was -1,124MWh, on 27 November 2018 during Settlement Period 18, when the System Price was £49.01/MWh.



2.4 Short system NIV over the last month




2.5 Long system NIV over the last month

SYSTEM PRICE ANALYSIS REPORT

Graph 2.6 displays a scatter graph of Net Imbalance Volume and System Prices. The dashed lines display a 0MWh NIV and a £0/MWh System Price.

In Settlement Periods 35 and 36 on 26 November, when the highest System Price of the month (£191.37/MWh) occurred, the NIV was 372MWh and 235MWh respectively.



2.6 Net Imbalance Volume and System Price in the last month

PAR Tagging

PAR Tagging is the final step of the Imbalance Price calculation. It takes a volume weighted average of the most expensive 1MWh of actions left in the stack. The value of PAR has decrease from 50MWh to 1MWh from 1 November 2018 as part of BSC Modification P305.

Following the change of PAR from 1 November, PAR Tagging is active in almost all settlement periods. The only periods that are not affected by the new parameter would have a NIV of less than 1MWh.

During November, there was 1 Settlement Period where PAR Tagging was inactive 25 November 2018, Settlement Period 13. The NIV in this Settlement Period was -0.903MWh. In this Settlement Period, a total of 37.17MWh of balancing actions were taken by the System Operator, 19.037MWh of Bids and 18.133MWh of Offers.

SYSTEM PRICE ANALYSIS REPORT

DMAT and Arbitrage Tagged Volumes

Some actions are always removed from the price calculation (before NIV Tagging). These are actions which are less than the De Minimis Acceptance Threshold (DMAT) Tagging or buy actions which are either the same price or lower than the price of sell actions (Arbitrage Tagging).


DMAT is currently set to 1MWh this may be lowered to 0.1MWh on 1 April 2019. If this change is approved we will include analysis of a 0.1MWh DMAT in January SPAR onwards.

Graph 2.7 shows the volumes of actions removed due to DMAT Tagging. 0.07% of total buy and sell volume was removed by DMAT Tagging in November. 35% of DMAT Tagged volume came from Balancing Services Adjustment Actions (BSAAs), whilst 34% came from CCGT BMUs.


Graph 2.8 shows the volumes of actions that were removed due to Arbitrage Tagging. 1.20% of total buy and sell volume was removed by Arbitrage Tagging in November. 51% of Arbitrage Tagged volume was from BSAAs, with 36% from CCGT BMUs.

In November, the average initial price of an Arbitrage Tagged buy action was £26.53/MWh, and for a sell action was £50.44/MWh. The maximum price of an Arbitrage Tagged sell action was £273.11/MWh, and the lowest priced Arbitrage Tagged buy action was -£25/MWh.

On 16 November 2018, 2,395MWh of actions were Arbitrage Tagged, representing 6.5% of daily volume. The average price of an Arbitrage Tagged buy action was £36.31/MWh, and for a sell action was £59.69/MWh.



2.7 Daily percentage of DMAT Tagged volume over the last month



2.8 Daily percentage of Arbitrage Tagged volume over the last month

SYSTEM PRICE ANALYSIS REPORT

3 BALANCING SERVICES

Short Term Operating Reserve (STOR) costs and volumes

This section covers the balancing services that the System Operator (SO) takes outside the Balancing Mechanism that can affect the price.


In addition to Bids and Offers available in the Balancing Mechanism, the SO can enter into contracts with providers of balancing capacity to deliver when called upon. These additional sources of power are referred to as reserve, and most of the reserve that the SO procures is called Short Term Operating Reserve (STOR).

Under STOR contracts, availability payments are made to the balancing service provider in return for capacity being made available to the SO during specific times (STOR Availability Windows). When STOR is called upon, the SO pays for it at a pre-agreed price (its Utilisation Price). Some STOR is dispatched in the Balancing Mechanism (BM STOR) while some is dispatched separately (Non-BM STOR).


Graph 3.1 gives STOR volumes that were called upon during the month – split into BM STOR and non-BM STOR. **Graph 3.2** shows the utilisation costs of this capacity. 89% of the total STOR utilised in November came from outside of the Balancing Mechanism.

The average Utilisation Price for STOR capacity in November was £48.36/MWh (£167.01/MWh for BM STOR and £33.88/MWh for non-BM STOR).

On 15 November, 783MWh of BM STOR volume was called at an utilisation cost of £125,000. This represented 41% of the total BM STOR volume in November.



3.1 Daily STOR vs Non-BM STOR volume across the last month



3.2 Daily STOR vs Non-BM STOR utilisation costs across the last month

SYSTEM PRICE ANALYSIS REPORT

De-Rated Margin, Loss of Load Probability and the Reserve Scarcity Price

There are times when the Utilisation Prices of STOR plants are uplifted using the **Reserve Scarcity Price (RSVP)** in order to calculate System Prices. The RSVP is designed to respond to capacity margins, so rises as the system gets tighter (the gap between available and required generation narrows). It is a function of **De-Rated Margin (DRM)** at Gate Closure, the likelihood that this will be insufficient to meet demand (the **Loss of Load Probability, LoLP**) and the **Value of Lost Load (VoLL)**, set at £6,000/MWh from 1 November 2018).

Graph 3.3 shows the daily minimum and average Gate Closure DRMs for November 2018.

The System Operator has determined a dynamic relationship between each DRM and the LoLP², which will determine the RSVP.


The minimum DRM in November was 1,880MW on 5 November in Settlement Period 34 (compared to 2,155MW in October). This DRM corresponded to a LoLP of 0.0066 and RSVP of £39.79/MWh (see **Table 3.4**).

The RSVP re-prices STOR actions in the Imbalance Price calculation if it is higher than the original Utilisation Price.

Six non-BM STOR actions were re-priced using the RSVP on 5 November Settlement Period 34.

These actions were priced between £24.80/MWh and £38.99/MWh. These actions were subsequently Arbitrage Tagged and hence did not set the System Price in this Settlement Period.

With a pre-November 2018 VoLL of £3,000/MWh no actions would have been re-priced by the RSVP.



3.3 Minimum and average DRMs

3.4 Top 5 LoLPs and RSVPs

Date	SP	DRM	LoLP	RSVP	RSVP Used	System Length	System Price
05/11/2018	34	1,880.23	0.0066	39.79	Yes	Short	124.43
05/11/2018	36	2,075.76	0.0037	22.22	No	Short	114.68
05/11/2018	35	2,169.91	0.0027	16.01	No	Short	146.68
05/11/2018	37	2,223.24	0.0024	14.44	No	Long	48.60
26/11/2018	34	2,239.03	0.0015	9.25	No	Long	54.00

² The System Operators methodology for LoLP is set out in the LoLP Methodology statement: https://www.elexon.co.uk/wp-content/uploads/2015/10/Loss_of_Load_Probability_Calculation_Statement_v1.0.pdf

SYSTEM PRICE ANALYSIS REPORT


4 P305 - PAR ANALYSIS

This section compares live prices with a **PAR 50 pricing scenario**. From 1 November 2018, the System Price calculation parameters changed as part of BSC Modification P305. The changes were:

- A reduction in the PAR value from 50MWh to 1MWh;
- The introduction of a 'dynamic' LoLP function; and
- An increase in the VoLL from £3,000/MWh to £6,000/MWh. The PAR 50 scenario uses a VoLL of £3,000/MWh in the RSVP function.

This section looks at the difference in System Prices between a PAR 50 and a PAR 1 scenario.

Live System Prices when the system is long are the same or lower compared to PAR 50, and when the system is short prices are the same or higher. **Graph 4.1** compares live System Prices with prices recalculated using the PAR 50 scenario when the system was long.



4.1 Live prices vs PAR 50 prices: Prices when the System was long


System Prices were different in 42% of Settlement Periods, with 11% of these changes greater than £1/MWh. System Prices are an average of £0.52/MWh lower when the system was long, and £0.94/MWh higher when the system was short compared to a PAR 50 scenario.

When the system was long and System Prices changed, price changes were less than £1/MWh in 82% of Settlement Periods, and greater than £5/MWh in 15% of Settlement Periods. The biggest shift in price was £67.81/MWh (Settlement Period 26 on 19 November 2018), when the price would have been £17.81/MWh under a PAR 50 scenario compared to the current live System Price of -£50/MWh.

SYSTEM PRICE ANALYSIS REPORT

Graph 4.2 compares live System Prices with PAR 50 prices when the system was short. Prices were higher in 30% of short Settlement Periods compared to the PAR 50 scenario; 21% changed by more than £5/MWh and 7% by more than £10/MWh. The biggest difference in price was -£30.94/MWh (Settlement Period 28 on 5 November); the price would have been £74.06/MWh under the PAR 50 scenario, compared to the current live System Price of £105/MWh.

Under the PAR 50 scenario, there would be 40 Settlement Periods in November 2018 with prices greater than £100/MWh, compared to 48 periods under the current live scenario.



4.2 Live prices vs PAR 50 prices: Prices when the System was short

SYSTEM PRICE ANALYSIS REPORT

5 GLOSSARY

Term	Abbrev.	Definition
Bid		A proposed volume band and price within which the registrant of a BM Unit is willing to reduce generation or increase consumption (i.e. a rate below their FPN).
Bid/Offer Acceptance	BOA	A Bid or Offer within a given Settlement Period that was Accepted by the SO. BOAs are used in the Imbalance Price calculation process e.g. to calculate NIV or the System Price.
Offer		A proposed volume band and price within which the registrant of a BM Unit is willing to increase generation or reduce consumption (i.e. a rate above their FPN).
System Price		A price (in £/MWh) calculated by BSC Central Systems that is applied to imbalance volumes of BSC Parties. It is a core component of the balancing and settlement of electricity in GB and is calculated for every Settlement Period. It is subject to change via Standard Settlement Runs.
Replacement Price		A price (in £/MWh) calculated by BSC Central Systems that is applied to volumes that are not priced during the imbalance pricing process (detailed in BSC Section T) It is calculated for every Settlement Period, and is subject to change via Standard Settlement Runs.
Utilisation Price		The price (in £/MWh) sent by the SO in respect of the utilisation of a STOR Action which: (i) in relation to a BM STOR Action shall be the Offer Price; and (ii) in relation to a Non-BM STOR Action shall be the Balancing Services Adjustment Cost.
Market Index Price	MIP	The Market Index Price reflects the price of wholesale electricity in the short-term market (in £/MWh). You can find an explanation of how it is calculated and used in the Market Index Definition Statement (MIDS).
Reserve Scarcity Price	RSVP	Both accepted BM and non-BM STOR Actions are included in the calculation of System Prices as individual actions, with a price which is the greater of the Utilisation Price for that action or the RSVP. The RSVP function is based on the prevailing system scarcity, and is calculated as the product of two following values: <ul style="list-style-type: none"> the Loss of Load Probability (LoLP), which will be calculated by the SO at Gate Closure for each Settlement Period; and the Value of Lost Load (VoLL), a defined parameter currently set to £6,000/MWh.
Replacement Price Average Reference	RPAR	The RPAR volume is a set volume of the most expensive priced actions remaining after NIV tagging, and is currently 1MWh. The volume-weighted average of these actions, known as the Replacement Price, is used to provide a price for any remaining unpriced actions prior to PAR Tagging.
Long		In reference to market length, this means that the volume of Accepted Bids exceeds that of Accepted Offers.
Short		In reference to market length, this means that the volume of Accepted Offers exceeds that of Accepted Bid.
Net Imbalance Volume	NIV	The imbalance volume (in MWh) of the total system for a given Settlement Period. It is derived by netting buy and sell Actions in the Balancing Mechanism. Where NIV is positive, this means that the system is short and would normally result in the SO accepting Offers to increase generation/decrease consumption. Where NIV is negative, the system is long and the SO would normally accept Bids to reduce generation/ increase consumption. It is subject to change between Standard Settlement Runs.
Price Average Reference	PAR	The PAR volume is a set volume of the most expensive priced actions remaining at the end of the System Price calculation, and is currently 1MWh.