

# HEADLINE REPORT

---

**MEETING NAME** Trading Disputes Committee

---

**Meeting number** 247

**Date of meeting** 07 February 2019

**Venue** ELEXON Ltd

**Classification** Public

---

## DECISION PAPERS

---

### 1. TRADING DISPUTE DA942 – TDC247/01

1.1 The Technical Assurance Agent (TAA) identified a Current Transformer (CT) mismatch at a Half Hourly (HH) site. The HH Meter Operator Agent (MOA) re-schemed the Meter and the HH Data Collector (DC) corrected the data back to the Final Reconciliation Settlement Run (RF). ELEXON considers Trading Dispute DA942 valid against all three criteria for a Trading Dispute.

1.2 The TDC:

- a) **AGREED** the end date of 18 September 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- d) **AGREED** that the materiality exceeds £3,000;
- e) **AGREED** that a Settlement Error has occurred;
- f) **UPHELD** the Trading Dispute; and
- g) **AGREED** means of rectification through the Post-Final Settlement Run.

### 2. TRADING DISPUTE DA947 - TDC 247/02

2.1 The Technical Assurance Agent (TAA) identified a Current Transformer (CT) ratio mismatch at a Half Hourly (HH) site. The HH Meter Operator Agent (MOA) reprogrammed the Meter and the HH Data Collector (DC) corrected the data back to the Final Reconciliation Settlement Run (RF). ELEXON considers Trading Dispute DA947 valid against all three criteria for a Trading Dispute.

2.2 The TDC:

- a) **AGREED** the end date of 4 October 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- d) **AGREED** that the materiality exceeds £3,000;
- e) **AGREED** that a Settlement Error has occurred;
- f) **UPHELD** the Trading Dispute; and
- g) **AGREED** means of rectification through the Post-Final Settlement Run.

# HEADLINE REPORT

---

## 3. TRADING DISPUTE DA949 - TDC 247/03

3.1 A wiring issue and an energy saving device which was left switched on in a disused joinery resulted in erroneously high consumption volumes for a factory. ELEXON considers Trading Dispute DA949 valid against all three criteria for a Trading Dispute.

3.2 The TDC:

- a) **AGREED** the end date of 15 November 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- d) **AGREED** that the materiality exceeds £3,000;
- e) **AGREED** that a Settlement Error has occurred;
- f) **UPHELD** the Trading Dispute; and
- g) **AGREED** means of rectification through the Post-Final Settlement Run.

## 4. TRADING DISPUTE DA903 - TDC 247/04

4.1 ELEXON raised Trading Dispute DA903 in relation to an issue with the aggregation rule for a Half Hourly (HH) site. ELEXON considers Trading Dispute DA903 valid against all three criteria for a Trading Dispute.

4.2 The TDC:

- a) **AGREED** the end date of 26 November 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **AGREED** that the materiality exceeds £3,000;
- d) **AGREED** that a Settlement Error has occurred;
- e) **UPHELD** the Trading Dispute; and
- f) **AGREED** means of rectification through the Post-Final Settlement Run.

## 5. TRADING DISPUTE DA933 - TDC 247/05

5.1 An error in registration resulted in the consumption data for a wind farm being double counted in Settlement. ELEXON considers Trading Dispute DA933 valid against all three criteria for a Trading Dispute, subject to the Trading Disputes Committee (TDC) granting exceptional circumstances.

5.2 The TDC:

- a) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- b) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- c) **AGREED** that the materiality exceeds £3,000;
- d) **AGREED** that a Settlement Error has occurred;
- e) **UPHELD** the Trading Dispute; and
- f) **AGREED** means of rectification through the normal and Post-Final Settlement Runs.

# HEADLINE REPORT

---

## 6. TRADING DISPUTE DA957 - TDC 247/06

6.1 Incorrect data was used in the energy imbalance price calculation. ELEXON considers Trading Dispute DA957 valid against all three criteria for a Trading Dispute.

6.2 The TDC:

- a) **AGREED** the end date of 8 December 2018;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **AGREED** that the materiality exceeds £3,000;
- d) **AGREED** that a Settlement Error has occurred;
- e) **UPHELD** the Trading Dispute; and
- f) **AGREED** means of rectification through the normal Settlement Run.

## 7. TRADING DISPUTE DA918 - TDC 247/07

7.1 A Meter at a Half Hourly (HH) site recorded 50% of its actual consumption due to the Licensed Distribution System Operator (LDSO) updating the Current Transformers (CTs) from 100/5A to 200/5A. This error went unnoticed as the LDSO failed to inform the appropriate agents of the change.

7.2 The TDC:

- a) **AGREED** the end date of 3 April 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- d) **AGREED** that the materiality exceeds £3,000;
- e) **AGREED** that a Settlement Error has occurred;
- f) **UPHELD** the Trading Dispute; and
- g) **AGREED** means of rectification through the Post-Final Settlement Run.

## 8. TRADING DISPUTE DA939 - TDC 247/08

8.1 A Meter at a Half Hourly (HH) site was under recording energy consumption after a Licensed Distribution System Operator (LDSO) changed the ratio on the Current Transformer (CT) from 100/5A to 400/5A. The HH Meter Operator Agent (HHMOA) rectified the error and commissioned the Meter and programmed the Meter to match the ratio on the Current Transformer (CT).

8.2 The TDC:

- a) **AGREED** the end date of 19 May 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- d) **AGREED** that the materiality exceeds £3,000;
- e) **AGREED** that a Settlement Error has occurred;
- f) **UPHELD** the Trading Dispute; and
- g) **AGREED** means of rectification through the Post-Final Settlement Run.

# HEADLINE REPORT

---

## 9. TRADING DISPUTE DA943 - TDC 247/09

9.1 A Half Hourly Data Collector (HHDC) was collecting Half Hourly (HH) data from a different Meter serial as a result of incorrect Meter Technical Details (MTDs) inherited from the previous Half Hourly Meter Operator Agent (HHMOA). This caused energy readings to be larger than originally anticipated.

9.2 The TDC:

- a) **AGREED** the end date of 13 September 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- d) **AGREED** that the materiality exceeds £3,000;
- e) **AGREED** that a Settlement Error has occurred;
- f) **UPHELD** the Trading Dispute; and
- g) **AGREED** means of rectification through the Post-Final Settlement Run.

## 10. TRADING DISPUTE DA946 - TDC 247/10

10.1 A vacant site was billed for electricity consumption by error. ELEXON considers Trading Dispute DA946 valid against all three criteria for a Trading Dispute.

10.2 The TDC:

- a) **AGREED** the end date of 16 September 2018;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- d) **AGREED** that the materiality exceeds £3,000;
- e) **AGREED** that a Settlement Error has occurred;
- f) **UPHELD** the Trading Dispute; and
- g) **AGREED** means of rectification through the Post-Final Settlement Run.

## 11. TRADING DISPUTE DA923 - TDC 247/11

11.1 A Meter at a Half Hourly (HH) site was over recording consumption due to incorrect Meter Technical Details (MTDs) inherited from the previous Supplier which indicated the Current Transformer (CT) was selected at 300/5A but was actually selected at 50/5A. The Meter was programmed to 300/5 which caused the Meter to over record energy consumption.

11.2 The TDC:

- a) **AGREED** the end date of 2 November 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **DETERMINED** to exercise discretion under Section W of the Code and grant exceptional circumstances;
- d) **AGREED** that the materiality exceeds £3,000;
- e) **AGREED** that a Settlement Error has occurred;
- f) **UPHELD** the Trading Dispute; and

# HEADLINE REPORT

---

g) **AGREED** means of rectification through the Post-Final Settlement Run.

## 12. TRADING DISPUTE DA950 - TDC 247/12

12.1 Incorrect consumption data was entered into Settlement for a Non Half Hourly (NHH) Metering System. ELEXON considers Trading Dispute DA950 valid against all three criteria for a Trading Dispute.

12.2 The TDC:

- a) **AGREED** the end date of 26 July 2017;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **AGREED** that the materiality exceeds £3,000;
- d) **AGREED** that a Settlement Error has occurred;
- e) **UPHELD** the Trading Dispute; and
- f) **AGREED** means of rectification through the Post-Final Settlement Run.

## 13. TRADING DISPUTE DA953 - TDC 247/13

13.1 Incorrect consumption data was entered into Settlement for a Non Half Hourly (NHH) Metering System. ELEXON considers Trading Dispute DA953 valid against all three criteria for a Trading Dispute.

13.2 The TDC:

- a) **AGREED** the end date of 7 February 2018;
- b) **AGREED** that the Trading Dispute was raised in accordance with the Dispute Deadline;
- c) **AGREED** that the materiality exceeds £3,000;
- d) **AGREED** that a Settlement Error has occurred;
- e) **UPHELD** the Trading Dispute; and
- f) **AGREED** means of rectification through the Post-Final Settlement Run.

## INFORMATION PAPERS

---

### 14. Overview of Open Disputes – TDC 247/14

14.1 ELEXON presented an overview of the open disputes.

14.2 The TDC:

- a) **NOTED** the Trading Disputes currently awaiting rectification and open Trading Disputes; and
- b) **NOTED** the long outstanding Trading Disputes

### 15. EAC AA Market and GSP Group Level SEAE

15.1 The TDC was provided with information to address the issue of Erroneous Large Estimated Annual Consumptions (EACs)/Annualised Advances (AA) in Settlement.

15.2 The TDC:

## HEADLINE REPORT

---

- a) **NOTED** that the current levels of error within the SEAE graphs and further analysis do not meet the entry criteria for a Trading Dispute; and
- b) **NOTED** the content of the paper and attachment.