
Headline Report

Meeting name Imbalance Settlement Group

Purpose of paper Information

Meeting number 238

Classification Public

Date and time 2 February 2021, 11.00

Synopsis **This report sets out the headlines and key decisions taken at the February 2021 meeting of the Imbalance Settlement Group.**

OPEN SESSION - Decision Papers

1. CP1538 'Correct Specification of TERRE Tibco (ISG238/01)

1.1 This document is the Change Proposal (CP) Assessment Report for CP1538 which Elexon will present to the Imbalance Settlement Group (ISG) at its meeting on 2 February. The Committee will consider the proposed solution and the responses received to the CP Consultation before making a decision on whether to approve CP1538.

1.2 This change aims to implement definition changes in the IDD Part 1 document to ensure that it is aligned with the Tibco software. This would provide a secure foundation for any future TERRE changes which may be necessary.

The ISG:

a) **APPROVED** CP1538 for implementation on 1 April 2021 as part of the April 2021 Release.

2. Metering Dispensation D/505 – Generic Metering Dispensation (ISG238/02)

2.1 Elexon has proposed a lifetime Generic Metering Dispensation (D/505) from Code of Practice (CoP) 1, 2, 3, 4, 5 and 10 for the use of measurement transformers of a different IEC standard from the one specified in the relevant CoP so long as the accuracy class and specified limits of error specified within the relevant IEC standard are unchanged. We invite the ISG to approve the Generic Metering Dispensation D/505 on a lifetime basis.

The ISG:

a) **APPROVED** Generic Metering Dispensation D/505 for the use of measurement transformers of a different IEC standard specified in the relevant CoP so long as the accuracy class and specified limits of error and limits of phase displacement specified with in the IEC standard are unchanged on a lifetime basis.

b) **NOTED** that Generic Metering Dispensation D/505 will also be presented for decision to the SVG on 2 February 2021.

3. GC/DC KPIs Analysis (ISG238/04)

3.1 This paper provides Elexon's annual review of the Generation Capacity and Demand Capacity (GC/DC) Limits, based on analysis of the five Key Performance Indicators (KPIs) outlined in the Generation Capacity and Demand Capacity Limit Review and Determination document.

The ISG:

- a) **NOTED** the analysis presented in the paper; and
- b) **RECOMMENDED** that no changes are made to the current GC/DC Limits.

4. Updates to ISG Terms of Reference (ISG238/05)

- 4.1 Elexon has reviewed the Terms of Reference (ToR) for the four BSC Panel sub-committees. This paper presents the proposed changes to the ISG ToR.

The ISG:

- a) **NOTED** the proposed changes to the ISG's Terms of Reference;
- b) **COMMENTED** on the proposed changes to the ISG's Terms of Reference;
- c) **ENDORSED** the updated Terms of Reference; and
- d) **NOTED** that the updated Terms of Reference will be presented to the BSC Panel in March 2021 for approval.