

Attachment A — Approval of default LLF Values

CSAD 2.1 Site Specific and EHV 22/23											
				LLF STOD 1	LLF STOD 2	LLF STOD 3	LLF STOD 4				
MSID / LLFC	Site Name (copy from input sheet)	Connection Voltage (kV)	Voltage of circuit to which the Meter is connected (primary voltage) (kV)	Winter Weekday Peak	Winter Weekday	Other	Night	Import / Export	CVA / SVA	When the LLFs were last calculated for the Site?	Are the LLFs Site Specific?
642	Monan Wind, Harris	33	33	0.981	0.982	0.981	0.980	Import	SVA	14-Jul-16	Yes
842	Monan Wind, Harris	33	33	0.953	0.954	0.953	0.952	Export	SVA	14-Jul-16	Yes