



T e s t R e p o r t

Report No : L14389
Client: : Candela Traditional Lighting Ltd
319 Long Acre
Waterlinks, Birmingham, West Midlands, B7 5JT
Description : LED Luminaires with power supply
Manufacturer : Not Disclosed
Type/Model : MWH-V06L-BP – 48 LED
MWH-V08M-BP – 60 LED
Test Specification : Measurement of power consumption in accordance with the
“Unmetered Supplies Operational Information” document –
Version 13.0 (7/11/13)
Date Tested : 03/07/14
Conclusion : Refer to body of Report
Date of Issue : 17/07/14
Date of Expiry : 16/07/19

Tested by: C.LOVEITT
Position: Laboratory Technician

Approved by: J.ADAMS
Position: Laboratory Supervisor



1286

Page 1 of 8

These test results relate only to the unit(s) tested. This Report and any subsequent report(s) may not be reproduced except in full without the written approval of the Testing Laboratory.

Registered Office: Stafford Park 7, Telford, Shropshire, TF3 3BQ, United Kingdom
Tel: +44 (0) 1952 290907 Fax: +44 (0) 1952 290908 Email: lab@thelia.org.uk

Web: www.lialab.org.uk
Web: www.lialabcert.org.uk



Table 5. Wattage and VA results for MWH-V06L-BP 48 LED luminaire with power supply

Voltage	Sample Number				
	1	2	3	4	5
210	13.28	13.08	13.43	13.34	15.76
220	13.31	13.10	13.45	13.37	15.78
230	13.34	13.14	13.49	13.42	15.83
240	13.37	13.18	13.52	13.45	15.87
250	13.40	13.22	13.55	13.48	15.86

VA

Voltage	Sample Number				
	1	2	3	4	5
210	24.65	24.36	24.86	25.50	29.62
220	24.62	24.27	24.83	25.31	29.44
230	25.05	24.75	25.27	26.03	30.10
240	25.56	25.27	25.78	26.09	29.96
250	26.04	25.78	26.25	26.21	30.69

Table 6. Test Sample Details

Product Description	LED Luminaire with power supply
Model No.	MWH-V08M-BP
Number of Samples	Five
Condition on Receipt	Good
Nominal Dimensions	Not Applicable
Product Supply Requirement	240V, 50Hz
Lamp Type and Power	LED
Sampling Method: Test samples selected and supplied by client, no sampling method specified by client.	

Continued on following page



Table 7. Wattage and VA results for MWH-V08M-BP 60 LED luminaire with power supply

Watts 100%

Voltage	Sample Number				
	1	2	3	4	5
210	65.63	65.06	64.98	65.50	65.76
220	65.58	65.00	64.92	65.42	65.68
230	65.52	64.94	64.87	65.36	65.62
240	65.47	64.89	64.83	65.33	65.58
250	65.43	64.84	64.80	65.30	65.55

VA

Voltage	Sample Number				
	1	2	3	4	5
210	66.89	66.94	66.30	66.75	67.07
220	66.94	67.08	66.32	66.73	67.05
230	66.98	67.24	66.36	66.73	67.05
240	66.83	67.33	66.35	66.77	67.09
250	66.87	67.50	66.41	66.82	67.15

Table 8. Wattage and VA results for MWH-V08M-BP 60 LED luminaire with power supply

Watts 75%

Voltage	Sample Number				
	1	2	3	4	5
210	49.43	48.80	48.89	49.14	49.41
220	49.42	48.79	48.88	49.13	49.39
230	49.43	48.79	48.89	49.14	49.40
240	49.43	48.79	48.90	49.14	49.41
250	49.43	48.79	48.90	49.14	49.40

VA

Voltage	Sample Number				
	1	2	3	4	5
210	50.49	50.66	50.09	50.28	50.60
220	50.53	50.82	50.15	50.32	50.65
230	50.56	50.97	50.20	50.37	50.71
240	50.66	51.24	50.31	50.47	50.79
250	50.79	51.51	50.43	50.57	50.90

This page is to be read in conjunction with the first page of this report



DEVIATION(S) FROM TEST STANDARD

No reported deviations from test standard.

MEASUREMENT UNCERTAINTY

Equipment number 279 uncertainty of measurement for AC voltage +/-0.01%

Equipment number 279 uncertainty of measurement for AC current +/-0.03%

Equipment number 279 uncertainty of measurement for AC power +/-0.08%

Continued on following page

ILLUSTRATIONS



Figure 1. *Image of tested samples*

End