

Report Number	TRN-15764
Customer	Keylighting Ltd
Contact	Conor Buckingham
Product Type	Street Light
Test Purpose	UMS Energy Performance Test
Sales Order Ref	Q-LUX15-20266
Works Order Number	WO-6411
Test Item Reference	TI-10729
LAB Test Method Reference	TES-20012
Test Standards	LM-79-08 and Elexon UMS Charge Code process V4.0
Lab Location Reference	Performance
Tested By	Huw Rees
Date of Test	27 October 2015
Analysed by	Steve Hunt
Number of products tested	5

Address: LUX-TSI Ltd.,
Pencoed Technology Park,
Pencoed, Bridgend,
CF35 5AQ, UK
Telephone: +44 (0) 1656 864618
Authorised by: Gareth Jones
Email: gjones@lux-tsi.com
Signed:




JURA-3X12-72W-IP65-4K - Keylighting

Date: 2 November 2015

Disclaimers

This report is for the exclusive use of LUX-TSI's Customer and is provided pursuant to the agreement between LUX-TSI and its Customer. LUX-TSI's responsibility and reliability are limited to the Terms and Conditions of the agreement. LUX-TSI assumes no liability to any other party, other than the Customer in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Customer is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the LUX-TSI name or one of its marks for the sale or advertisement of the tested material, product or service must be approved in writing by LUX-TSI.



LUX-TSI is UKAS
accredited to
ISO/IEC 17025

The observations and test results in this report are relevant only to the sample tested. Opinions expressed and data supplied in this report, are given in good faith, and are based on the information provided by the Customer. This report does not remove the requirement for the Customer to obtain further independent advice and in particular to instruct a notified or competent body or person to carry out further evaluation work and/or testing. Accordingly, no warranty is given, nor is any term or condition to be implied, that the product, which is the subject of this report, complies with the requirements of any EU directives.

Nomenclature

Lamp Orientation described below relates to the position in which a lamp is designed to operate for maximum performance and safety, these include:

BD - Base Down (bulb is vertically positioned with the metal base at the bottom, glass up)

BU - Base Up (bulb is vertically positioned with the metal base at the top, glass hanging down)

HBD - Horizontal $+15^\circ$ to Base Down

H45 - Horizontal to -45° only

VBU - Vertical Base Up $\pm 15^\circ$

VBD - Vertical Base Down $\pm 15^\circ$

HBU - Base Up $\pm 90^\circ$ (bulb can be operated in a base up or horizontal position)

HOR - Horizontal Burn (bulb is positioned with the metal base parallel to the ground)

H75 - Horizontal $\pm 75^\circ$ (bulb should not be operated within 15° of vertical)

U - Universal Burn (burn can be operated in any position)

Test Equipment and Description

Yokogawa WT210 Power Analyser. Kikusui PCR2000M Stable AC Power Supply with PC control and data recording



The products under test are connected to the UMS Test system which has full data control and recording using Labview software. This allows full integration of the test equipment used - Kikusui AC Stable Power Supply, Yokogawa Power Analyser, Pico Temperature Logger and a LUX-TSI distribution control panel

Product Name	JURA-3X12-72W-IP65-4K - Keylighting
Part/Serial Number	See (Identifier) below
Type of Product	Street Light
Manufacturer	Tridonic
Date of Manufacturer	Unknown
Base Type	Tile
Driver Type	Mains
Driver Model	LCI 35W 700mA
Light Engine Model	VL M025WO/ 46/840
Operating Orientation	Base Up
Test Orientation	Base Up
Ambient Temperature	26.9°C
Humidity	<65% RH
Thermal Management	Passive
Dimmable	Yes
Product Summary	The product is of a street lantern design with a Metal enclosure. The driver is situated within the enclosure and the Light engine fitted on underside of the product

Dimension	Sample	Luminous Opening
Diameter/Width	325 mm	218 mm
Length	550 mm	72 mm
Height/Depth	40 mm	0 mm

Test Item	Identifier
10729A	1
10729B	2
10729C	3
10729D	4
10729E	5

Test Conditions



	Before Test	After Test
AC Supply Voltage (V)	249.8V	249.78V
AC Supply Frequency (Hz)	50Hz	50Hz
Voltage RMS Summation of the Harmonic Components (THD)	0.08%	0.07%


The test items were stabilised according to the electrical power stability of LM79-08. Stabilization is achieved when the difference in electrical power measurement is less than 0.5%. Each test item was stabilised at 250V.

Measurements were made with an ambient temperature of 25°C +/- 2°C. Measurements were taken only after sufficient time for thermal stabilisation has been allowed.

Test Results Summary

These are the summary graphs of the test results for all products tested. The raw results are on page 6 of this test report.





Power factors measured have a Lagging phase angle and therefore the driver has inductive properties.

Measurement Uncertainty

Parameter	Uncertainty
Voltage (300 V, 50/60 Hz)	$\pm 0.061 V_{rms}$
Current (200 mA, 50/60Hz)	$\pm 0.07 mA_{rms}$
Current (0.5 A, 50/60Hz)	$\pm 0.16 mA_{rms}$
Current (5 A, 50/60Hz)	$\pm 0.0016 A_{rms}$
Power (300 V, 200 mA, 50/60 Hz)	$\pm 0.032 W_{rms}$
Power (300 V, 0.5 A, 50/60 Hz)	$\pm 0.09 W_{rms}$
Power (300 V, 5 A, 50/60 Hz)	$\pm 0.0009 kW_{rms}$
Frequency (50/60 Hz)	$\pm 0.001 Hz$
Power Factor	$\pm 0.0006 PF$

Measurements of power of 0.50W or greater are made with an uncertainty of less than or equal to 2% at the 95% confidence level. Measurements of power less than 0.50W are made with an uncertainty of less than or equal to 0.01W at the 95% confidence level.


Full Test Results

Test Item	Voltage (V)	Current (mA)	Electrical Power (W)	Ambient Temp (°C)	Peak Power (VA)	Power Factor	Leading / Lagging
A	249.78	321.40	76.93	26.86	80.27	0.958	Lagging
B	249.80	322.00	77.09	28.19	80.42	0.959	Leading
C	249.88	327.30	78.07	27.78	81.80	0.954	Leading
D	249.70	326.80	77.87	30.63	81.60	0.954	Leading
E	249.79	327.70	78.06	28.69	81.85	0.954	Leading
A	239.45	331.10	76.57	27.86	79.27	0.966	Lagging
B	239.81	332.00	76.92	29.91	79.62	0.966	Leading
C	239.74	336.60	77.77	28.96	80.70	0.964	Leading
D	239.85	336.60	77.80	27.64	80.74	0.964	Leading
E	239.83	337.40	77.91	27.63	80.91	0.963	Leading
A	229.41	342.60	76.40	28.19	78.60	0.972	Lagging
B	229.65	343.30	76.67	27.27	78.84	0.973	Leading
C	229.56	347.60	77.52	27.47	79.80	0.971	Leading
D	229.62	347.40	77.50	27.79	79.76	0.972	Leading
E	229.60	348.30	77.62	27.63	79.97	0.971	Leading
A	219.40	355.30	76.27	27.57	77.96	0.978	Lagging
B	219.65	356.60	76.56	28.93	78.32	0.978	Leading
C	219.63	360.80	77.47	27.65	79.25	0.978	Leading
D	219.61	360.30	77.38	27.07	79.13	0.978	Leading
E	219.63	361.20	77.53	26.72	79.34	0.977	Leading
A	209.49	370.20	76.24	27.72	77.56	0.983	Lagging
B	209.70	371.70	76.50	27.27	77.94	0.982	Leading
C	209.63	375.70	77.39	28.29	78.76	0.983	Leading
D	209.63	375.30	77.31	27.21	78.68	0.983	Leading
E	209.71	376.40	77.50	27.72	78.93	0.982	Leading

Test Item Photographs

TI-10729


Images of Product(s) under test includes (where possible) labelling, Driver and Light engine details



Top of Test Item



Front Face of Test Item




Inside Driver Compartment including driver



Close up of Driver


Driver in Situ



Light Engine Serial Numbers

Light Engine

Appendix 1: Test item set-up



----- END OF REPORT -----