

T e s t R e p o r t

Report No : L15669

Client: : Aura Light UK
Waterloo House
Waterloo Road
Ketley Business Park
Ketley
Telford
TF1 5JD

Description : 35W INDICO Street Lantern

Manufacturer : Not Disclosed

Type/Model : 467158

Test Specification : Measurement of power consumption in accordance with the
'Unmetered Supplies Operational Information Document' –
Version 14.0 (17/12/2014)

Date Testing Started : 04/04/2016

Conclusion : Refer to body of report

Date of Issue : 12/04/2016

Date of Expiry : 11/04/2021

Tested by: M.ALI
Position: Photometrics Engineer



Approved: J.ADAMS
Position: Laboratory Supervisor



1286

INTRODUCTION

Aura Light UK has supplied the product identified in table 1 for measurement of power consumption in accordance with the 'Unmetered Supplies Operational Information Document' – Version 14.0 (17/12/2014).

PRODUCT DETAILS

Table 1. Test Sample Details

Product Description	35W INDICO Street Lantern
Model No.	467158
Number of Samples	Five
Condition on Receipt	Good
Nominal Dimensions	700mm x 300mm x 130mm
Product Supply Requirement	240V AC 50Hz
Lamp Type and Power	35W LED
Sampling Method: Test samples selected and supplied by client, no sampling method specified by client.	

The customer has declared that the equipment load does not vary with ambient temperature.

Continued on following page

RESULTS

Table 2. Wattage and VA results for 35W INDICO Street Lantern

Operating Mode	100%				
Watts					
Voltage	Sample Number				
	1	2	3	4	5
210	34.20	33.64	33.98	34.19	34.15
220	34.12	33.54	33.90	34.12	34.08
230	34.07	33.48	33.84	34.06	34.03
240	34.04	33.42	33.79	34.03	34.00
250	34.01	33.39	33.76	34.00	33.97
VA					
Voltage	Sample Number				
	1	2	3	4	5
210	34.69	34.18	34.60	34.70	34.71
220	34.66	34.15	34.59	34.69	34.70
230	34.68	34.17	34.61	34.71	34.73
240	34.72	34.20	34.65	34.76	34.78
250	34.77	34.25	34.71	34.81	34.85
Power Factor					
Voltage	Sample Number				
	1	2	3	4	5
210	0.99	0.98	0.98	0.99	0.98
220	0.98	0.98	0.98	0.98	0.98
230	0.98	0.98	0.98	0.98	0.98
240	0.98	0.98	0.98	0.98	0.98
250	0.98	0.97	0.97	0.98	0.97
Ambient Temperature During Test (°C)			24.0		
PF Leading/Lagging			Leading		

Continued on following page

DEVIATION(S) FROM TEST STANDARD

No reported deviations from test standard.

MEASUREMENT UNCERTAINTY

The following expanded uncertainties apply to the measurements shown in the results;

True Power (W): $\pm 0.69\%$, Apparent Power (VA): $\pm 0.61\%$

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a coverage probability of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

Continued on following page

ILLUSTRATION



Figure 1. Product image

End