

# Operational Information Document

## A guide to Unmetered Supplies under the BSC

Version 176.0

Effective Date: 156 ~~March~~ ~~November~~ 20176

### Intellectual Property Rights, Copyright and Disclaimer

The copyright and other intellectual property rights in this document are vested in ELEXON or appear with the consent of the copyright owner. These materials are made available for you for the purposes of your participation in the electricity industry. If you have an interest in the electricity industry, you may view, download, copy, distribute, modify, transmit, publish, sell or create derivative works (in whatever format) from this document or in other cases use for personal academic or other non-commercial purposes. All copyright and other proprietary notices contained in the document must be retained on any copy you make.

All other rights of the copyright owner not expressly dealt with above are reserved.

No representation, warranty or guarantee is made that the information in this document is accurate or complete. While care is taken in the collection and provision of this information, ELEXON Limited shall not be liable for any errors, omissions, misstatements or mistakes in any information or damages resulting from the use of this information or action taken in reliance on it.

**Contents Table**

<b>1</b>	<b>An introduction to Unmetered Supplies.....</b>	<b>5</b>
<b>1.1</b>	<b>What are Unmetered Supplies under the BSC? .....</b>	<b>5</b>
<b>1.2</b>	<b>What is the purpose of this document? .....</b>	<b>5</b>
<b>1.3</b>	<b>Before reading on, some key roles and terms explained.....</b>	<b>5</b>
<b>2</b>	<b>What are Charge Codes?.....</b>	<b>6</b>
<b>2.1</b>	<b>Why do I need one? .....</b>	<b>6</b>
<b>2.2</b>	<b>What are discontinued Charge Code structures? .....</b>	<b>6</b>
<b>2.3</b>	<b>The structure explained .....</b>	<b>7</b>
2.3.1	Lamps.....	7
2.3.2	Traffic equipment .....	11
2.3.3	Miscellaneous equipment .....	14
2.3.4	Control equipment .....	17
2.3.5	Motorway signals - Devices with variable hours .....	18
<b>3</b>	<b>How do I apply for a Charge Code? .....</b>	<b>19</b>
<b>3.1</b>	<b>Considerations in respect of Charge Code applications.....</b>	<b>19</b>
<b>3.2</b>	<b>Test data requirements.....</b>	<b>21</b>
<b>3.3</b>	<b>Applying to use a range of Generic LED Lighting Charge Codes.....</b>	<b>23</b>
3.3.1	The structure of Generic LED Lighting Charge Codes .....	23
3.3.2	Manufacturer Equipment LED Range Spreadsheet.....	25
<b>3.4</b>	<b>Test procedure for LED Variable Message, Bus Information Signs and signs with variable light levels .....</b>	<b>25</b>
<b>3.5</b>	<b>Test procedure for Belisha Beacons.....</b>	<b>26</b>
<b>3.6</b>	<b>Test procedure for CCTV Equipment.....</b>	<b>27</b>
<b>3.7</b>	<b>Test procedure for Constant Light Output (CLO).....</b>	<b>28</b>
<b>3.8</b>	<b>Test procedure for Multi-Level Static Dimming (MLSD) Devices.....</b>	<b>28</b>
<b>3.9</b>	<b>Testing requirements for WiFi Equipment.....</b>	<b>29</b>
<b>3.10</b>	<b>Testing requirements for 50 Series Electronic Ballasts .....</b>	<b>29</b>
<b>3.11</b>	<b>Charge Codes for Central Management System (CMS) Equipment.....</b>	<b>29</b>
<b>3.12</b>	<b>Charge Codes for Speed/ red light cameras or equipment that includes cameras .....</b>	<b>30</b>
<b>4</b>	<b>How are Charge Codes Calculated? .....</b>	<b>31</b>
<b>4.1</b>	<b>Equipment that is less than 10 Watts.....</b>	<b>31</b>
<b>4.2</b>	<b>Traffic signal heads.....</b>	<b>31</b>
4.2.1	Continuous green aspects .....	32
4.2.2	How do I record traffic signal equipment in my inventory? .....	32
4.2.3	Dimming Traffic Signals .....	32
4.2.4	Dummy Loads for LED Traffic Lights .....	33
4.2.5	What are filter signals? .....	33
<b>4.3</b>	<b>Cable network cabinets (Miscellaneous Codes Starting 813) .....</b>	<b>34</b>
<b>5</b>	<b>What is Half Hourly (HH) and Non Half Hourly (NHH) Trading? .....</b>	<b>35</b>
<b>5.1</b>	<b>Half-Hourly (HH).....</b>	<b>35</b>
<b>5.2</b>	<b>Non-Half Hourly (NHH) .....</b>	<b>35</b>
<b>6</b>	<b>Photoelectric Control Unit (PECU) array location and siting guidance .....</b>	<b>36</b>
<b>6.1</b>	<b>Location of a single array.....</b>	<b>36</b>
6.1.1	Weighted latitude and longitude of inventory .....	36
6.1.2	Weighted latitude and longitude of population .....	36
<b>6.2</b>	<b>Deciding on multiple or single arrays .....</b>	<b>36</b>
<b>6.3</b>	<b>Hosting and maintenance of the arrays.....</b>	<b>36</b>
<b>7</b>	<b>What are Switch Regimes? .....</b>	<b>37</b>
<b>7.1</b>	<b>Hybrid/thermal Photoelectric Control Units (PECUs).....</b>	<b>40</b>
<b>7.2</b>	<b>Part night dimming .....</b>	<b>40</b>
<b>7.3</b>	<b>Multi-Level Static Dimming (MLSD) Switch Regimes .....</b>	<b>41</b>
<b>7.4</b>	<b>Variable Power Switch Regime Spreadsheet.....</b>	<b>42</b>

7.4.1	The energy calculation for single or MLSD dimming using Generic LED Lighting Charge Codes or other Charge Codes ending '100'	42
<b>7.5</b>	<b>Motorway operating hours</b>	<b>42</b>
<b>7.6</b>	<b>Valid Combinations of Charge Codes and Switch Regimes</b>	<b>43</b>
<b>8</b>	<b>Standard file format for detailed inventories</b>	<b>46</b>
<b>8.1</b>	<b>General comments</b>	<b>46</b>
<b>8.2</b>	<b>Standard file format</b>	<b>47</b>
<b>8.3</b>	<b>Notes on standard inventory format</b>	<b>48</b>
<b>8.4</b>	<b>Notes for Customers on declaring Charge Codes and Switch Regimes for Multi-Level Static Dimming (MLSD) Devices</b>	<b>49</b>
<b>1</b>	<b>An introduction to Unmetered Supplies</b>	<b>4</b>
<b>1.1</b>	<b>What are Unmetered Supplies under the BSC?</b>	<b>4</b>
<b>1.2</b>	<b>What is the purpose of this document?</b>	<b>4</b>
<b>1.3</b>	<b>Before reading on, some key roles and terms explained</b>	<b>4</b>
<b>2</b>	<b>What are Charge Codes?</b>	<b>5</b>
<b>2.1</b>	<b>Why do I need one?</b>	<b>5</b>
<b>2.2</b>	<b>What are discontinued Charge Code structures?</b>	<b>5</b>
<b>2.3</b>	<b>The structure explained</b>	<b>6</b>
2.3.1	Lamps	6
2.3.2	Traffic equipment	10
2.3.3	Miscellaneous equipment	13
2.3.4	Control equipment	16
2.3.5	Motorway signals – Devices with variable hours	17
<b>3</b>	<b>How do I apply for a Charge Code?</b>	<b>18</b>
<b>3.1</b>	<b>Considerations in respect of Charge Code applications</b>	<b>18</b>
<b>3.2</b>	<b>Applying to use a range of Generic LED Lighting Charge Codes</b>	<b>20</b>
3.2.1	The structure of Generic LED Lighting Charge Codes	20
3.2.2	Manufacturer Equipment LED Range Spreadsheet	21
<b>3.3</b>	<b>Test procedure for LED Variable Message, Bus Information Signs and signs with variable light levels</b>	<b>21</b>
<b>3.4</b>	<b>Test procedure for Belisha Beacons</b>	<b>22</b>
<b>3.5</b>	<b>Test procedure for CCTV Equipment</b>	<b>23</b>
<b>3.6</b>	<b>Test procedure for Constant Light Output (CLO)</b>	<b>24</b>
<b>3.7</b>	<b>Test procedure for Multi-Level Static Dimming (MLSD) Devices</b>	<b>24</b>
<b>3.8</b>	<b>Testing requirements for WiFi Equipment</b>	<b>25</b>
<b>3.9</b>	<b>Testing requirements for 50 Series Electronic Ballasts</b>	<b>25</b>
<b>3.10</b>	<b>Charge Codes for Central Management System (CMS) Equipment</b>	<b>25</b>
<b>3.11</b>	<b>Charge Codes for Speed/ red light cameras or equipment that includes cameras</b>	<b>26</b>
<b>4</b>	<b>How are Charge Codes Calculated?</b>	<b>27</b>
<b>4.1</b>	<b>Equipment that is less than 10 Watts</b>	<b>27</b>
<b>4.2</b>	<b>Traffic signal heads</b>	<b>27</b>
4.2.1	Continuous green aspects	28
4.2.2	How do I record traffic signal equipment in my inventory?	28
4.2.3	Dimming Traffic Signals	28
4.2.4	Dummy Loads for LED Traffic Lights	29
4.2.5	What are filter signals?	29
<b>4.3</b>	<b>Cable network cabinets (Miscellaneous Codes Starting 813)</b>	<b>30</b>
<b>5</b>	<b>What is Half Hourly (HH) and Non Half Hourly (NHH) Trading?</b>	<b>31</b>
<b>5.1</b>	<b>Half Hourly (HH)</b>	<b>31</b>
<b>5.2</b>	<b>Non Half Hourly (NHH)</b>	<b>31</b>
<b>6</b>	<b>Photoelectric Control Unit (PECU) array location and siting guidance</b>	<b>32</b>
<b>6.1</b>	<b>Location of a single array</b>	<b>32</b>
6.1.1	Weighted latitude and longitude of inventory	32

~~6.1.2~~ Weighted latitude and longitude of population .....32

~~6.2~~ **Deciding on multiple or single arrays** ..... 32

~~6.3~~ **Hosting and maintenance of the arrays**..... 32

~~7~~ **What are Switch Regimes?** ..... 33

~~7.1~~ **Hybrid/thermal Photoelectric Control Units (PECUs)**..... 36

~~7.2~~ **Part night dimming** ..... 36

~~7.3~~ **Multi-Level Static Dimming (MLSD) Switch Regimes** ..... 37

~~7.4~~ **Variable Power Switch Regime Spreadsheet**..... 38

~~7.4.1~~ The energy calculation for single or MLSD dimming using Generic LED Lighting Charge Codes or other Charge Codes ending '100' .....38

~~7.5~~ **Motorway operating hours** ..... 38

~~7.6~~ **Valid Combinations of Charge Codes and Switch Regimes** ..... 39

~~8~~ **Standard file format for detailed inventories** ..... 42

~~8.1~~ **General comments** ..... 42

~~8.2~~ **Standard file format**..... 43

~~8.3~~ **Notes on standard inventory format**..... 44

~~8.4~~ **Notes for Customers on declaring Charge Codes and Switch Regimes for Multi-Level Static Dimming (MLSD) Devices** ..... 45

## 1 An introduction to Unmetered Supplies

### 1.1 *What are Unmetered Supplies under the BSC?*

An Unmetered Supply (UMS) means a supply of electricity to a particular inventory of equipment in respect of which a Licensed Distribution System Operator (LDSO) has issued an Unmetered Supply Certificate. For example, this equipment could be any electrical equipment that draws a current and is connected to the Distribution Network without a meter, i.e. there is no meter recording its energy consumption, e.g. street lights, traffic signs, zebra crossings, etc.

### 1.2 *What is the purpose of this document?*

This document aims to provide guidance on:

- What Charge Codes are (unique code representing unmetered equipment);
- The meaning of a Charge Code's structure;
- The testing required to obtain a Charge Code;
- How to account for equipment such as traffic signals in Customer inventories;
- Switch Regime codes (and Part Night dimming);
- The difference between Non Half Hourly (NHH) and Half Hourly (HH) trading; and
- Other useful operational information relating to Unmetered Supplies under the BSC.

### 1.3 *Before reading on, some key roles and terms explained...*

**The Customer** – Typically a lighting authority, being a County, Metropolitan, Unitary, Borough or Parish Council that has an Unmetered Supply inventory in Great Britain. They are responsible for maintaining a detailed inventory of all their UMS equipment and providing regular updates to their Unmetered Supplies Operator (UMSO). The Customer is also responsible for contracting with the Meter Administrator (MA), if the UMS is traded HH under the BSC. The Supplier will appoint the MA for Settlement purposes. Customers should contact their UMSO if they have any questions on how to submit equipment in their detailed inventory.

**The Unmetered Supplies Operator (UMSO)** – The UMSO is part of the LDSO, also known as the Distribution Business or Network Operator. The UMSO is responsible for looking after all of the Unmetered Supplies on its network. The UMSO makes new connections and decides what equipment is suitable for treatment as an Unmetered Supply. The UMSO provides a summarised inventory to the MA for HH traded UMS or calculates an Estimated Annual Consumption (EAC) for NHH traded UMS.

**The Meter Administrator (MA)** – is responsible for providing HH consumption data into Settlement. This is the consumption of a particular Customer in kWh, for each half hour of every day. The Supplier will appoint the MA for Settlement purposes.

**BSCCo (the Balancing and Settlement Code Company, the role fulfilled by ELEXON)** - is responsible for ensuring that the processes within BSCP520 'Unmetered Supplies Registered in SMRS' are carried out effectively. BSCCo is also responsible for issuing Charge Codes and Switch Regimes to Customers such as product manufacturers and county councils that have an Unmetered Supply inventory. BSCCo also coordinates the Central Management Systems (CMS) approval process.

**Unmetered Supplies User Group (UMSUG)** - An expert group reporting to the Supplier Volume Allocation Group (SVG) advising them on the UMS arrangements under the Balancing and Settlement Code (BSC). Their work includes reviewing Charge Code applications, advising on changes to the relevant BSC subsidiary documents (e.g. BSCP520), the resolution of issues and new developments relating to UMS. The UMSUG is chaired by BSCCo and meets on an ad-hoc basis driven by the SVG and business need.

## **2 What are Charge Codes?**

A Charge Code is simply a 13 digit number which represents a specific type of UMS equipment. It is used by UMSOs and MAs to look up the power value (known as circuit watts) associated with the equipment and calculate consumption.

The Charge Code itself also contains information in its structure. The first two digits (first three digits for miscellaneous equipment) provide an indication of the type of equipment, for instance whether it is a new light-emitting diode (LED) street light or a high pressure sodium lamp. The Charge Code can also include the nominal Watts for the equipment. Typically this could be the 'printed value' on the equipment, e.g. the power value on a lamp, 100W SON or the circuit watts for the equipment at full power. For equipment without any 'printed' values, the nominal Watts could be the rating at which the product is marketed by the manufacturer.

### **2.1 Why do I need one?**

Charge Codes are required so that the energy consumption of the equipment can be recorded as accurately as possible. By having a Charge Code it shows that the manufacturer has provided load research for the equipment ([as explained below](#)) and the Charge Code has been issued by BSCCo.

Equipment shall not be connected to the Distribution Network without first being issued with a Charge Code. The issue of a Charge Code does not guarantee an unmetered connection to a Distribution Network. Connection to a network is at the discretion of the Distribution Business following its licence conditions and UMS connections policy.

### **2.2 What are discontinued Charge Code structures?**

Sometimes certain Charge Code structures are marked as discontinued. This means that no further Charge Codes will be provided with the defined structure in future applications, but existing (historic) Charge Codes with the discontinued structure remain valid and will still appear on the Charge Code Spreadsheet.

## 2.3 The structure explained

The structure of the Charge Code depends on the type of equipment. There are currently three categories: Lamps, Traffic Equipment and Miscellaneous.

### 2.3.1 Lamps

Standard lighting equipment has the following structure:

Digits	Description
<b>1 and 2</b>	Identifies the lamp type
<b>3, 4, 5 and 6</b>	The nominal lamp Watts (typically the power value printed on the lamp, e.g. a 100W SON) or the circuit watts N.B. this is not the same (usually less than) as the circuit watts
<b>7</b>	The control gear type
<b>8, 9 and 10</b>	Allows equipment with the same full circuit watts to have a different Charge Code
<b>11, 12 and 13</b>	The dimming level, i.e. the percentage of full load (N.B. '100' = full load circuit watts)

#### Definition of digits 1 and 2:

Code	Description	Definition Letters	Comments
01	General lighting service filament	GLS, GLD	
03	Tungsten Halogen	TH	
11	Low Pressure Sodium	SOX, SOXPLUS	SOX - Low pressure sodium
12	Low Pressure Sodium (Economy)	SOX/E, SOX-PLUS, SOX-HF	SOX E – Low pressure sodium – energy efficient – i.e. lower Watts for same light output and HF would be High Frequency electronic ballast; and
14	High Pressure Sodium	SON, SON/T, SON/+	SON – High pressure sodium that has many suffixes such as T – tubular or PLUS being high output
21	High Pressure Mercury	MBF/U, MBFR/U	MBF - Mercury Blended Fluorescent
23	High Pressure Mercury (Blended)	MBTL/U	
24	High Pressure Mercury (Halide)	MBI	
25	High Pressure Mercury (Induction)	QL	
26	High Pressure Mercury (Ceramic Discharge Metal Halide)	CDM-T, CDM-TT, CDO	CDO - Ceramic Discharge Outdoor CDM - Ceramic Discharge Metal
27	High Pressure Mercury (Metal Arc)	MP	
28	Cosmopolis	CPO	CPO - Cosmopolis
29	Cold Cathode		

Code	Description	Definition Letters	Comments
31	Low Pressure Mercury (Fluorescent Tube) - Single Lamp	MCF/U	MCF - Mercury Coated Fluorescent  Codes 31 and 32 are for the same lamps. These lamps are often mounted in a tray as twin lamps and used in traffic sign illumination. The difference is that code 31 is for a single lamp with its own control gear. Two lamps in a tray would therefore require a quantity of 2 in the number of lamps. However it is possible to mount 2 lamps in a tray in series with a single set of control gear. See Comment in 32 below.
32	Low Pressure Mercury (Fluorescent Tube) - Twin Lamp (two lamps operated in series on a single ballast)	MCF/U	See Comment in 31 above, Code 32 is rated to cover two lamps and the single ballast. In this case the quantity to be entered in the number of lamps is only one.
33	Low Pressure Mercury (Compact) - Single Lamp	SL, PL-S, PL-L	See Comment in 31 above, Codes 33 and 34 follow the same principle but for a compact type.
34	Low Pressure Mercury (Compact) - Twin Lamp (two lamps operated in series on a single ballast)	PL-S, PL-L	See Comment in 31 above, Codes 33 and 34 follow the same principle but for a compact type.
35	Low Pressure Mercury (Compact) - Single Lamp	PL-C, PL*E/C	
36	Low Pressure Mercury (Compact) - Single Lamp	PL-T	
37	Low Pressure Mercury (2D) - Single Lamp	2D	
38	Low Pressure Mercury – Compact Integral Standard Gear		
39	Low Pressure Mercury (Induction)		
40	light Emitting Diodes (LEDs)  (Legacy Charge Codes only)		Discontinued for new products after 15 June 2016 see <a href="#">Generic LED Lighting Charge Codes</a> . The 40 series legacy Charge Codes previously issued are for LED traffic sign lights or aesthetic and other purposes, not for street lights, e.g. not set in a lighting column, see Code 41.
41	LED street lights  (Legacy Charge Codes only)		Discontinued for new products after 15 June 2016 see <a href="#">Generic LED Lighting Charge Codes</a> . The 41 series legacy Charge Codes previously issued are for LED street lights, not traffic signs This code is for LEDs that are set in a lighting column (or similarly mounted) and are used to illuminate roads and highways. LEDs that are for aesthetics or other purposes used Code 40.
42	Generic LED lighting		<a href="#">See Section 3.2</a> <a href="#">See Section 3.3</a>
45	Luminescent		



Code	Description	Definition Letters	Comments
50	Electronic Ballasts		This code is reserved for electronic ballasts that will drive lamps at a given circuit watts regardless of the specification of the lamp attached to the ballast.
Codes with higher numbers are covered later in the document (see paragraphs 2.3.3 and 2.3.4)			

### Definition of digits 3, 4, 5 and 6

These represent the nominal rating of the equipment in Watts, i.e. '0250' represents a lamp with a nominal rating of 250 Watts.

### Definition of digit 7: Control Gear type

Code	Control Gear Description	Applicable Lamp Types	Explanation
0	No Control Gear or 50 Series Ballast	GLS/GLD, TH, MBT, SL, PL*E/C, LED	Lamps which do not require control gear or where the control gear is incorporated into the lamp envelope. LED drivers are incorporated into equipment <b>OR</b> any Charge Codes that start with '50'.
1	Standard Control Gear (auto leak)	HPL & HPI, MBF, SOX & SOX/E, SLI, MCF, PL-S, PL-L, PL-C, PL-T & 2D	Consists of a ballast/transformer and capacitor. A starter switch may also be incorporated.
2	Low Loss Control Gear	SOX & SOX/E, SON & SON/T, CDM-T, MP	Consists of a ballast/transformer and capacitor together with an electronic ignitor.
3	Electronic Ballast	CPO, HPL & HPI, MBF, SOX & SOX/E, SON & SON/T, SLI, MCF, PL-S, PL-L & PL-C, QL	Provides the initial ignition pulse and the subsequent voltage / current control of the lamp.  Note: the Electronic Ballasts Control Codes were previously divided into High and Low Frequency. This differentiation was removed in version 12.0 of this document.
4	SOX/E Optimum Gear	SOX/E	Consists of a ballast / transformer and capacitor together with an electronic ignitor to provide the ignition pulse to the lamp.
5	Low Frequency (L/F) Electronic Ballast (Frequencies lower than 1 kHz)	Discontinued	These should now use Code 3.
6	Multi-Level Static Dimming (MLSD): Dimming Control with stand-by power integral to the ballast	Discontinued	This code was used to identify ballasts that have programmable dimming capability and stand-by power. It is used by the UMSO to ensure the ballast is declared with an appropriate Control Charge Code that accounts for the stand-by power.

### Definition of digits 8, 9 and 10

These digits allow equipment with the same first seven digits but different circuit watts to be uniquely identified. Where equipment has another code with dimmed values, these three digits shall be same for the same equipment running undimmed (100% or full brightness), and for each of its dimmed codes.

Where the equipment is set up for reduced operation by the manufacturer, i.e. the equipment is configured to run in normal operation (undimmed) at a power level below the normally maximum (100% or full brightness), then the three digits shall be set to a unique value, normally the three digits are incremented by one (or the next available three digits), e.g. '001', '002', '003', etc. If for example a piece of equipment has the three digits of '001' and is also indicating 100% operation, if the manufacturer then applies for the same piece of equipment to be set up with reduced operation '002' shall be used.

### Definition of digits 11, 12 and 13

The last three digits of the code represent the % of full power that dimming of the equipment will produce.

For example '070' at the end of a code for an LED street lamp would indicate that the equipment dims down to operate at 70% of the full power of the lamp. For equipment without any dimmed circuit watts, or running permanently at reduced operation, or operated by CMS equipment the last three digits of the Charge Code will always be '100' where the actual dimmed levels are determined from the event file.

If the equipment can be run at full power with no dimming by the Customer, BSCCo will issue an undimmed version of the code, i.e. 100%. This applies to where a manufacturer is applying for a series of dimmed Charge Codes but no 100% code exists. To calculate the dimming percentage, take the rounded dimmed circuit watts, divide them by the full power circuit watts and then multiply by 100 and finally round to the nearest whole number.

For example; if the equipment had full power circuit watts of 7 and dimmed circuit watts of 3.12 (which would be rounded to 3.1).

The code would end:  $(3.1/7.0) \times 100 = 44.2857 = 44\%$  (nearest whole number) = 044.

Please note, that for part night dimming to be used, a part night dimming Switch Regime or a MLSD Switch Regime must be used. [Switch Regimes](#) are explained later on in this document.

### Example of lamp Charge Code

For example, if the lamp is a High Pressure Sodium (SON/T or SON/PLUS) with a nominal rating of 100W then the first two digits of the Charge Code will be '14'. The next four digits will be '0100'. If the lamp is controlled by a high frequency electronic ballast the next digit will be '3' and if the ballast is a new type the next three digits will be a unique identifier, e.g. '003'. Finally if the lamp is dimmed to 60% energy over part-night then the last three digits are '060'.

Thus two codes would be issued, where it is operating at 100% with no dimming, the code will be 14 0100 3003 100, where the equipment is dimming the code will be: 14 0100 3003 060. The spacing is used to better communicate the codes in documents such as this, but the Charge Code must not contain spaces in the detailed inventory.

### Ballasts with 'stand-by' power

Where a ballast draws 'stand-by' power when the lamp is off, due to an integral control device, an uplift of 1 Watt shall be applied to the circuit watts to account for the power drawn. It is recognised that this will not allow for the correct allocation of the energy but is a pragmatic approach to account for energy drawn by the ballast during daylight hours.

Where the control is not integral to the ballast it will be allocated a separate Control Charge Code and will be required to be declared separately.

#### 2.3.2 Traffic equipment

All traffic codes start with 79 and can be on continually, switched manually and can have more than one brightness level.

Where a traffic signal dims its brightness from Dusk to Dawn the Customer shall declare the appropriate Switch Regime, i.e. 821 if switching controlled by an electronic 70/35 Lux photocell. The UMSO and MA will make the appropriate adjustment using the full and dimmed circuit watts (in this context known as day/night Watts) declared for the equipment. Please see guidance on dimming traffic signals in Section 4.2.32.

Digits	Description
<b>1 and 2</b>	Always 79. Traffic signal codes begin with "79" as the first two digits.
<b>3 and 4</b>	Numeric code that represents the type of traffic signal equipment
<b>5, 6 and 7</b>	The nominal Watts (not the same as circuit watts)
<b>8, 9 and 10</b>	A numeric code that allows equipment with the same first seven digits of the Charge Code but with different circuit watts to be uniquely identified.
<b>11, 12 and 13</b>	Always '100'. It should be noted that traffic lights and other non-lighting traffic equipment may have 'day' and 'night' Watts. This means that there is no need for a fixed dimming percentage at the end of the code because dimming percentages apply to part night dimming in conjunction with part night switching regimes. For a fuller explanation see paragraph 4.2.32.

**Definition of digits 3 and 4:**

Code	Equipment Description	Comments
01	3 lamp vehicle aspect (undimmed)	<b>Non LED lights, see below for Traffic LED codes</b>
02	3 lamp vehicle aspect (dimmed)	<b>Non LED lights, see below for Traffic LED codes</b>
03	2 lamp pedestrian aspect (undimmed)	<b>Non LED lights, see below for Traffic LED codes</b> These codes are for red and green aspects (men), where one or other is permanently lit.
04	2 lamp pedestrian aspect (dimmed)	<b>Non LED lights, see below for Traffic LED codes</b>
05	Wait Signal/Push Button (undimmed)	<b>Non LED lights, see below for Traffic LED codes</b>
06	Controller	
07	Vehicle Detector	
08	Cable less Link Unit (CLU)	
09	Lamp Monitoring Unit (LMU)	
10	Outstation Monitoring Unit (OMU)	
11	Outstation Transmission Unit (OTU)	
12	Detector Power Pack Unit (DPU)	
13	Speed Discrimination Unit (SDU)	
14	Variable Maximum Unit (VMU)	
15	Microprocessor Optimised Vehicle Actuation (MOVA)	
16	Belisha Beacons	Non LED lights, see below for <b>Traffic</b> LED codes
17	Regulatory or Box Sign	Non LED lights, see below for <b>Traffic</b> LED codes
18	School Crossings	
19	Pole Mounted Responder	
20	Traffic Counter	
21	Speeding / Red Light Camera	
22	Motorway Overhead Gantry	
23	Ticket Machine	
24	Wait Signal/Push Button (dimmed)	
25	Speed Warning Signs	
26	Variable Message Signs	See paragraph <a href="#">Variable Message Signs</a> below
27	Vehicle Aspect - Filter lamp (undimmed)	Non LED lights, see below for <b>Traffic</b> LED codes
28	Vehicle Aspect - Filter lamp (dimmed)	Non LED lights, see below for <b>Traffic</b> LED codes
29	Vehicle Activated Sign (Dimmed Activated)	
30	<del>Weather detection/measurement equipment [Discontinued]</del>	Discontinued for future applications - See Miscellaneous Code <a href="#">830</a>
31	Supply cabinet	
32	<del>CCTV equipment [Discontinued]</del>	See also Miscellaneous codes for CCTV, Code 870
33	Audio equipment	
34	Radio equipment	
35	Telephone equipment	
36	Communications equipment	
37	<i>[Not currently used]</i>	

Code	Equipment Description	Comments
38	LED Wait Signal/Push Button (undimmed)	These codes are for push button equipment where the 'Wait' signal (or button) is only lit upon pressing the button.
39	LED Wait Signal/Push Button (dimmed)	See comment for Code 38 above.
40	LED 3 lamp vehicle aspect (undimmed)	
41	LED 3 lamp vehicle aspect (dimmed)	
42	LED 2 lamp far side pedestrian aspect (undimmed)	These codes are for red and green aspects (men) on far side of the road, where one or other is permanently lit. Please see Codes 54 and 55 for near side aspects.
43	LED 2 lamp far side pedestrian aspect (dimmed)	See above
44	LED filter (undimmed)	
45	LED filter (dimmed)	
46	LED Belisha Beacons (undimmed)	
47	LED School Crossings	
48	<del>LED Regulatory Sign Light</del> [Discontinued]	Discontinued for future applications - LED 'street' signs should be coded under lamps in the 40 Lamp range.
49	<i>[Not currently used]</i>	
50	LED Belisha Beacons (dimmed)	
51	<i>[Not currently used]</i>	
52	Pedestrian Detector	
53	Pedestrian Detector with night light	Codes in this range actually increase their load at night due to the night light. These codes are treated like dimming Charge Codes.
54	LED 2 lamp nearside pedestrian aspect with/without push-button (undimmed)	These codes are for red and green aspects (men, horse or bike) on the near side of the road and may incorporate a pedestrian push button. For red/green far side aspects please see Codes 42 and 43.
55	LED 2 lamp nearside pedestrian aspect with/without push-button (dimmed)	See above.
56	Continuous Green Aspect (undimmed)	These Codes are for Non-LED Aspects (see below) and see paragraph 4.2
57	Continuous Green Aspect (LED) (undimmed)	See paragraph 4.2
58	Continuous Green Aspect (dimmed)	These Codes are for Non-LED Aspects (see below) and see paragraph 4.2
59	Continuous Green Aspect (LED) (dimmed)	See paragraph 4.2

### Definition of digits 5, 6 and 7

These represent the nominal rating of the equipment in Watts, i.e. '025' may represent a pedestrian detector with a nominal rating of 25 Watts.

### Definition of digits 8, 9 and 10

These two digits allow equipment with the same first seven digits of the Charge Code, but with different full circuit watts, to be uniquely identified.

### Definition of digits 11, 12 and 13

Always '100'. It should be noted that the UMSO and MA systems were designed to take account of any day and night Watts associated with traffic lights and other non-lighting traffic equipment. This means that there is no need for a dimming percentage at the end of the code. For more information, see [How do I record traffic signals in my inventory?](#) below.

#### 2.3.3 Miscellaneous equipment

Miscellaneous equipment covers all other equipment not defined in either the lamps or traffic signals sections above. For this equipment the nominal Watt values are set to match the circuit watts. This allows for any local Code derived for equipment that may match a national Charge Code will provide the same energy calculation. Further guidance on local versus national Charge Codes is provided below.

### Issuing of local or national Miscellaneous Charge Codes

UMSOs may issue Miscellaneous Charge Codes without having them published in the BSCCo Charge Code Spreadsheet where the equipment is to be used solely within the UMSO's area. For clarity, 'nationally' means in GSP Groups controlled by more than one UMSO. Where the Apparatus is intended for use solely within a single UMSO's GSP Group(s) an application to BSCCo is not required.

CMS equipment and equipment that will be used nationwide will be submitted to BSCCo for Charge Codes to be issued in the usual way. In these cases the Charge Code will continue to be issued by BSCCo and published on the [BSC Website](#).

The structure of the code is:

Digits	Description
<b>1, 2 and 3</b>	Digit 1 is always 8. Digits 2 and 3 represent the type of Equipment, see below table.
<b>4, 5, 6 and 7</b>	Circuit watts
<b>8, 9 and 10</b>	Same as for traffic signals
<b>11, 12 and 13</b>	Always 100

**Definition of digits 1, 2 and 3**

Code	Description	Comments
802	AA/RAC Boxes	
804	Advertising Hoardings	Lighting on Advertising Hoardings should use relevant lamp Codes. This code should be used where there is other equipment such as motors (used for scrolling to change the advert)
806	Alarm System	
807	Automated Number Plate Recognition System	
808	Automatic Railway Crossing	
810	Battery Charger	
811	Bus Information Systems	See <a href="#">Bus Signs</a> below
812	Bus Shelter (Discontinued)	Lighting in Bus Shelters should use relevant lamp Codes. For Bus Information Systems see Code 811
813	Cable Network Cabinets	
814	Cathodic Protection	
815	Control Host	Charge Code 815 0000 000 000 is a fixed Charge Code with circuit watts set to zero. This Charge Code can be used to populate the Apparatus Charge Code ( <a href="#">Field 8</a> ) on a Customer inventory in instances where control equipment (e.g. group switch photocell) is located within equipment that does not itself have any controlled unmetered supply, such as a feeder pillar.
816	Clock	
817	CMS Equipment	
818	Damp Proof Course	
820	Door Answering Service	
821	Electrical Isolation Device	
822	Fire Warning System	
824	Flood Warning System	
826	Gas Governors	
828	Gauging Flume	
830	Weather detection/measurement equipment	This Code has been amended from 'Ice Detector' to cover wider types of Apparatus and replaces Codes formerly in the 79 30 range
832	Illuminated Map Cabinets	
834	Lifting Barrier	
835	Information Systems	
836	Navigation Signal	
838	Pay & Display Machine	
839	People Counter/ Traffic Counter	
840	Phone card Phones	
842	Police Boxes	
844	Pump	

Code	Description	Comments
846	Radio Transmitter	
848	Radio Relay Station	
850	Railway Signal	
852	Rain Gauge	
854	Security Camera [Discontinued]	See Code 870 below and <a href="#">CCTV</a>
856	Septic Tanks	
858	Sewage Flow Recorder	
860	Storm Overflow	
862	Tannoy Alarm System	
863	Telephone Kiosks	
864	Ticket Machine	
866	<del>TV Aerial</del> [Discontinued]	See Code 868
868	TV Amplifier	
870	TV Camera / Equipment	See <a href="#">CCTV</a> below
871	CCTV illuminator	
872	<del>TV Relay</del> [Discontinued]	See Code 868
873	Trafficmaster Units	
874	Ventilation Unit	
876	Warden Call Equipment	
878	Warning Bell	
880	Water Level Indicator	
882	WiFi Equipment	For testing requirements of this equipment see <a href="#">WiFi Equipment</a>
899	Other	

#### Definition of digits 4, 5, 6, and 7:

For miscellaneous equipment, the nominal Watts will always equal the circuit watts.

#### Definition of digits 8, 9 and 10

A numeric code that allows equipment with the same first seven digits of the Charge Code, but with different full circuit watts to be uniquely identified.

#### Definition of digits 11, 12 and 13

The last three digits for these codes will always be '100'. Where the miscellaneous equipment has dimming functionality the energy saved from dimming will be accounted for in the calculation of the circuit watts.



### 2.3.4 Control equipment

These have the exact same structure as lamp codes ([please see above](#))

#### Definition of digits 1 and 2

Equipment Codes	Description	Comment
<b>91</b>	Time Switch Controllers	Load is continuous
<b>92</b>	Thermal Photocells	Are based on 3 Watts when the lamp is switched 'OFF' and 0 Watts when lamp is switched 'ON'.
<b>93</b>	Hybrid Photocells	Are based on 3 Watts when the lamp is switched 'OFF' and 0 Watts when lamp is switched 'ON'.
<b>94</b>	Electronic Photocells	Load is continuous, covers solid state, latching relay and part night photocells
<b>95</b>	Electronic Photocells (Latching relay)[Discontinued]	See Code 94.
<b>96</b>	Infra Red Photocells	
<b>97</b>	Electronic Photo Cell Timeswitch [Discontinued]	See Code 94.
<b>98</b>	Electronic Controls (e.g. CMS devices)	Relates to a controller for CMS equipment. e.g. a node or telecell connected to the lamp/ ballast to facilitate dimming and switching.
<b>99</b>	MLSD Controls and Controls integral to Ballasts	Relates to: <ul style="list-style-type: none"> <li>• A standalone dimming control device (not inbuilt as part of a photocell) which also incorporates the load consumed by a separate standard photocell; or</li> <li>• A photocell with inbuilt dimming control; or</li> <li>• A standard photocell or timeswitch together with an 'uplift' to account for the load consumed by dimming control gear integral to the lamp ballast.</li> </ul> For more information see <a href="#">MLSD</a> below

### 2.3.5 Motorway signals - Devices with variable hours

These are Charge Codes which begin '60' and are currently processed by the UMISO separately. As such they are not contained in the Charge Code Spreadsheet available on the BSC Website but are in a separate spreadsheet on the BSC Website: [Charge Codes and Switch Regimes](#).

Currently, Highways England which is responsible for English motorways makes the calculations for motorway signals. Additionally, annual motorway operating hours will be calculated by Highways England based on actual operational information.

Three load states for the circuit watts should be submitted with an application for a Charge Codes as follows:

- Quiescent: equipment is on but signal is not illuminated;
- Dim: equipment is on and signal is on at reduced brightness; and
- Bright: equipment is on and at full load.

The Dim and Bright circuit watts will include the quiescent load.

### 3 How do I apply for a Charge Code?

#### 3.1 Considerations in respect of Charge Code applications

In order to apply for a Charge Code or apply to use a range of Generic LED Lighting Charge Codes (see below), please contact ELEXON's Unmetered Supplies Operations: [ums.operations@elexon.co.uk](mailto:ums.operations@elexon.co.uk) or contact the ELEXON switchboard on 020 7380 4100.

Further guidance and an application checklist can be found on the BSC Website ([Overview of the UMS Charge Code Process](#) and [Unmetered Supplies](#)).

The objective of the testing procedure is to provide an accurate indication of the load at the Distribution Network terminals of the particular equipment under normal conditions; i.e. to establish what consumption would be recorded by a standard meter fitted at the supply terminals.

~~The load tests for equipment designed for operation at other voltages MUST include an appropriate transformer (unless directed otherwise by BSCCo).~~

The Applicant shall ensure the provision of the following information or necessary conditions are met:

- Test data shall be provided, along with a clear description of the equipment (including the product name and product code, and version number if applicable, used by the manufacturer), its typical operation and installation. Additional information (e.g. brochures, etc.) shall be provided where necessary to enable the list of agreed ratings to be maintained;
- Photographs of the equipment should be included, including a photograph of the assembled unit;
- Testing shall be carried out by an ISO 17025 accredited test house or other test house agreed by BSCCo and that the scope of the accreditation covers the testing of the electrical properties of equipment (or other supporting evidence that the testing party is suitably qualified). Test houses that have ISO 17065 can apply to BSCCo to provide a service to third parties that are not ISO 17025 accredited. The test house shall ensure the third party can meet the appropriate testing standards and shall review and issue test reports on behalf of the third party;
- BSCCo reserves the right to witness the tests if so required;
- ~~• Both power/voltage and volt-ampere/voltage curves will be required with measurements taken at 210, 220, 230, 240 and 250 volts, 50 hertz. Typically the power measurements provided shall be greater or equal to the nominal Watts stated in the Charge Code application;~~
- ~~• The accuracy of the measurements shall be stated and the minimum accuracy shall be  $\pm 2\%$  of the recorded value as per the Electricity (Unmetered Supply) Regulations 2001;~~
- ~~• The testing set-up to undertake the power measurements shall include any voltage transformers, drivers or any other equipment necessary to operate the equipment from the mains. In the case of traffic signals where there are multiple pieces of equipment being supplied by one transformer, the power measurements shall exclude the transformer. Please note that an uplift of 10% will be added to the power measurements in deriving the circuit (and/or dimming) watts;~~
- ~~• The sample size shall be a minimum sample size of five. Additional samples shall be requested where the test data provided is deemed to be unsatisfactory or insufficient by BSCCo. If the equipment under test is made up of two or more components, the additional (not core) components are to be tested at one sample each and at one voltage (240V without a transformer or the input voltage in the case that the equipment requires a transformer but is~~

~~to be tested without one). The equipment as a whole is still required to be tested at five voltages and with a minimum of five samples (see section 3.5 for an example involving a CCTV equipment);~~

- ~~• Samples shall be tested after operating for sufficient time to reach their steady load state. If it is likely that the load will vary over the life of the equipment then the tests shall be carried out after at least one hundred hours of operation (See also paragraph [Test Procedure for Constant Light Output](#));~~
- ~~• If the equipment consists of both lamps and control gear, then the control gear shall be divided into at least three batches of five samples, e.g. 15 samples in total. Each batch is to be tested with lamps supplied by a different major manufacturer. Electronic ballasts that drive more than one lamp type to the same Watts should also be tested with five samples of each lamp type that can be operated with the ballast;~~
- ~~• If the equipment includes facilities to dim to a fixed load level, then data for full load as well as each dimmed load is required;~~
- ~~• If the equipment includes a dimmable ballast or driver, then the Applicant shall submit load curve data, giving the relationship between the control parameter (e.g. 0-10V or DALI/DSI/MALDI or other control methods) and the power input to the equipment. Additionally the maximum and minimum level to which these ballasts or drivers can operate shall be provided with the Charge Code application;~~
- ~~• If the equipment is housed within a cabinet, then clear evidence shall be provided that additional equipment cannot be added (e.g. not scalable) and that a meter cannot be installed or that it fits the criteria for an unmetered supply as defined in the Unmetered Supply Statutory Instrument (2001 No. 3263);~~
- ~~• If the equipment incorporates heating (e.g. frost heaters) or cooling equipment (e.g. fans) then the estimated operating hours under the different regimes should be reported;~~
- ~~• If the equipment load varies with ambient temperature then test data shall be provided at a room temperature (approx. 20°C). The testing temperature shall be declared and a statement or data shall be provided on the maximum variation in load at both likely extremes (high and low) with the application;~~
- ~~• Test houses are required to identify if power factors provided in the test data for Apparatus are leading or lagging;~~
- ~~• It is historically a standard requirement of UMS Connection Agreements or the National Terms of Connection that the power factor of connected equipment shall be as near to unity as practicable but in any case not less than 0.85 lagging or 0.95 leading. If the equipment does not meet this standard then a Distribution Business may refuse to connect the equipment. For guidance where an application is made for a piece of equipment with a circuit watts of less than 25 Watts then lower power factors will be considered. Where power factors are leading, this should be identified by the test house and be provided by the Applicant with the test data. Leading power factors will be declared as neutral/ unity in the Charge Code Spreadsheet.~~

BSCCo (with input from the UMSUG where appropriate) will consider the test results in recommending an appropriate Charge Code for inclusion in the [Charge Code Spreadsheet](#).

Any questions raised by BSCCo to the Applicant shall be answered in full before the application can proceed.

### **3.2 Test data requirements**

The Applicant shall adhere to the following requirements when preparing the test data:

- Both power/voltage and volt-ampere/voltage curves will be required with measurements taken at 210, 220, 230, 240 and 250 volts, 50 hertz. Typically the power measurements provided shall be greater or equal to the nominal Watts stated in the Charge Code application;
- The accuracy of the measurements shall be stated and the minimum accuracy shall be  $\pm 2\%$  of the recorded value as per the Electricity (Unmetered Supply) Regulations 2001;
- The testing set-up to undertake the power measurements shall include any voltage transformers, drivers or any other equipment necessary to operate the equipment from the mains. If there are multiple pieces of equipment (each requiring a separate Charge Code) being supplied by one transformer or power supply unit, the power measurements shall exclude that transformer or power supply unit. Please note that an uplift of 10% will be added to the power measurements in deriving the circuit (and/or dimming) watts;
- If the equipment operates on voltage levels below 210 volts, the power measurements to be taken shall be based on the test range specified in the table below.

<b><u>Nominal Watts</u></b>	<b><u>Nominal Voltage</u></b>	<b><u>Test Range</u></b>
<u>10W or more</u>	<u>100V or more, but less than 210V</u>	<u>Power measurements to be taken at nominal voltage and at -10V, -5V, +5V, and +10V of nominal voltage</u>
	<u>Less than 100V</u>	<u>Power measurements to be taken at nominal voltage and at -4V, -2V, +2V, and +4V of nominal voltage</u>
<u>Less than 10W</u>	<u>Less than 210V</u>	<u>Power measurements to be taken at nominal voltage only</u>

The test range to be used is dependent on the nominal voltage and nominal Watts of the equipment. For example, if the equipment has a nominal voltage of 48 volts and nominal Watts of 12 Watts, the power measurements shall be taken at 44, 46, 48, 50 and 52 volts.

- If the equipment includes facilities to dim to a fixed load level, then data for full load as well as each dimmed load is required. If the equipment is dimmed by application of a lower voltage supply, the equipment shall have its power measurements taken at the nominal full

voltage and the nominal dimmed voltage(s). The nominal full voltage and nominal dimmed voltage(s) are typically specified in the equipment's technical specification or data sheet;

- The sample size for each voltage level and/or dimming level to be tested shall be a minimum sample size of five. Additional samples shall be requested where the test data provided is deemed to be unsatisfactory or insufficient by BSCCo;
- Samples shall be tested after operating for sufficient time to reach their steady load state. If it is likely that the load will vary over the life of the equipment then the tests shall be carried out after at least one hundred hours of operation (See also paragraph Test Procedure for Constant Light Output);
- If the equipment consists of both lamps and control gear, then the control gear shall be divided into at least three batches of five samples, e.g. 15 samples in total. Each batch is to be tested with lamps supplied by a different major manufacturer. Electronic ballasts that drive more than one lamp type to the same Watts should also be tested with five samples of each lamp type that can be operated with the ballast;
- If the equipment includes a dimmable ballast or driver, then the Applicant shall submit load curve data, giving the relationship between the control parameter (e.g. 0-10V or DALI/DSI/MALDI or other control methods) and the power input to the equipment. Additionally the maximum and minimum level to which these ballasts or drivers can operate shall be provided with the Charge Code application;
- If the equipment is housed within a cabinet, then clear evidence shall be provided that additional equipment cannot be added (e.g. not scalable) and that a meter cannot be installed or that it fits the criteria for an unmetered supply as defined in the Unmetered Supply Statutory Instrument (2001 No. 3263);
- If the equipment incorporates heating (e.g. frost heaters) or cooling equipment (e.g. fans) then the estimated operating hours under the different regimes should be reported;
- If the equipment load varies with ambient temperature then test data shall be provided at a room temperature (approx. 20°C). The testing temperature shall be declared and a statement or data shall be provided on the maximum variation in load at both likely extremes (high and low) with the application;
- It is historically a standard requirement of UMS Connection Agreements or the National Terms of Connection that the power factor of connected equipment shall be as near to unity as practicable but in any case not less than 0.85 lagging or 0.95 leading. If the equipment does not meet this standard then a Distribution Business may refuse to connect the equipment. Where an application is made for a piece of equipment with a circuit watts of less than 25 Watts then lower power factors will normally be considered;
- The test house should identify whether the power factor is leading or lagging and this information should be provided by the Applicant. Leading power factors will be declared as neutral/ unity in the Charge Code Spreadsheet.

### **3-23.3 Applying to use a range of Generic LED Lighting Charge Codes**

From 15 June 2016 LED manufacturers or Customers can apply to use these Charge Codes by either providing:

- data showing the power range of the driver settings that can be used; and
- a load curve based on test data from sufficient different dimming levels (to include full power and the minimum dimming level); or
- details of legacy LED products to be mapped to generic Charge Codes (test results not required).

This allows us to extrapolate intermediate power levels. We still expect the test data to include both Watts (W) and Volt Amps (VA). We are assuming a unity power factor of 1 for the purposes of the generic Charge Codes. We shall provide the manufacturer with confirmation that it can use all generic Charge Codes published on the Charge Code Spreadsheet within the capability of the equipment (LED driver limits).

#### **3-2-13.3.1 The structure of Generic LED Lighting Charge Codes**

These are generic Charge Codes for **LED lights or LED street lights** that are not traffic signals. The full range of Generic LED Lighting Charge Codes are published on the [Charge Code Spreadsheet](#).

<b>Digits</b>	<b>Description</b>
<b>1 and 2</b>	Always 42
<b>3, 4, 5 and 6</b>	The circuit watts (0001 to 0500) this is either for the LED light or LED street light at full power or a mid-life value for LED street lights with driver enabled Constant Life Output (as opposed to CMS CLO)
<b>7, 8, 9 and 10</b>	Always 0000
<b>11, 12 and 13</b>	Always 100

#### **Definition of digits 1 and 2:**

The value of 42 defines the product as an LED light or an LED street light.

#### **Definition of digits 3, 4, 5 and 6**

These represent the circuit watts of the equipment in Watts at full power, i.e. '0250' represents a lamp with a full power rating of 250 Watts. For lamps with driver enabled CLO this will be the mid-life value.

#### **Definition of digits 7, 8, 9 and 10**

The value of 0000 defines the product as a Generic LED light or a Generic LED street light.

**Definition of digits 11, 12 and 13**

The value of 100 defines that these Charge Codes are the full power rating for the lamp. Dimming of these Generic LED Lighting Charge Codes is achieved by linking them with a dimming [Switch Regime](#) which is explained later in this document.



### **3.2.23.3.2 Manufacturer Equipment LED Range Spreadsheet**

We will publish each manufacturer's allowed Charge Code range for each product/drivers range on the [Manufacturer Equipment LED Range Spreadsheet](#) on the [BSC Website](#)<sup>1</sup>. As a minimum the spreadsheet will include:

- the manufacturer;
- the manufacturer's product designation;
- the Generic LED Lighting Charge Codes – lower limit; and
- the Generic LED Lighting Charge Codes – upper limit.

For applications to use a range of Generic LED Lighting Charge Codes the successful Applicant will be informed that it can use the appropriate range. The Apparatus and valid range will be included in the [Manufacturer Equipment LED Range Spreadsheet](#).

### **3.33.4 Test procedure for LED Variable Message, Bus Information Signs and signs with variable light levels**

Charge Codes will only be provided on a case-by-case basis where the Applicant can satisfy the following criteria:

- Bus Information signs will be considered for Charge Codes on a case-by-case basis. For Visual Bus Information Displays with an optional audio player: Separate data provided for just visual and visual plus audio mode (50% of each mode will be included the calculation of the circuit watts);
- Vehicle Activated Signs and Car Park Signs will have the default position of being metered unless a case is made by an Applicant why they cannot be metered. This case will be reviewed by the UMSUG and considered by the SVG;
- County Council Traffic Information Signs should be metered only and not considered for UMS Charge Codes; and
- Highways England or Transport for Scotland VMS will be considered for UMS Charge Code Applications for legacy connections only. No Charge Codes should be allowed for applications where the heating load exceeds the Heavy Bright Load (including quiescent load + Controller).
- Sign Lights and Regulatory signs: Where the information on a sign is illuminated, for instance by a fluorescent tube or LEDs (e.g. backlit or top lit), then the Charge Code will be constructed using lamp codes (e.g. see 31 or 42 series above). Where the message on the sign is made up of LEDs or other types of lighting then the Charge Code will be constructed as a traffic sign (see coding structure for various traffic signs in section the [Traffic Equipment Section](#) e.g. speed warning or variable message signs).

Where applications are agreed the test data shall be provided along with a description of typical operation and installation of the equipment. Application for Charge Codes shall be made on a per unit basis, e.g. one Charge Code to include all items such as the controller, heating elements, and the message block sign. The message blocks shall be tested with either 'BBBB' or '8888' illuminated for the full width of the block. Where a message sign can be dimmed test data shall be provided on the same basis as for full load with the sign dimmed.

---

<sup>1</sup> <https://www.elexon.co.uk/>.

The Applicant shall provide clear detail on why the load is deemed to be predictable and why the equipment cannot, or is impractical for it to, be metered.

This equipment is deemed to be on continuously. There should be one Charge Code which includes an agreed percentage for all of the elements making up the full installation, such as heater, controller, etc. It will be necessary to determine an average load for the display, taking into consideration any night time dimming (see paragraph 3.21).

The equipment shall then be tested in line with the testing requirements described in the section above. Where Charge Codes can be provided for Vehicle Activated Speed Warning Signs the circuit watts will be derived using the quiescent load of the unlit sign with an uplift equal to 10% of the load of the sign when illuminated. Test data for both modes of operation must therefore be provided by the Applicant.

Where Apparatus (other than street lights) has variable light levels the BSCCo will apply a weight to the load at each light level according to the percentage of time that the Apparatus is deemed to be at each light level. The Applicant must provide sufficient detail on the operation of the Apparatus to allow BSCCo to determine the appropriate weightings.

BSCCo will consider the test information provided and consult with the Customer as to an appropriate figure for the circuit watts.

#### **3.43.5 Test procedure for Belisha Beacons**

Belisha Beacons shall be tested at a constant load with the lamp constantly on (i.e. no flashing). BSCCo will then take 62% of the full circuit watts to account for the lamp flashing. Alternatively, the energy consumed over the period of say 10 minutes will give the average consumption while flashing. When submitting test evidence the method of test should be clearly stated.

### ***3.53.6 Test procedure for CCTV Equipment***

The following individual components will need the circuit watts / VA measured:

The camera itself; and then where applicable:

<b>Equipment</b>	<b>% of circuit watts used in calculation</b>
Fibre Optic Transmitter (or other communication method)	100%
Microwave link	100%
Tel. Receiver	100%
Cabinet heater 5°C thermostat	13%
Demister 5°C thermostat	13%
Heater 5°C thermostat	13%
Pan & tilt motor	5%
Washer	5%
Wiper	5%
Zoom	10%
<b><i>N.B. Since these Codes fall in the Miscellaneous 800 range, UMSOs can allocate their own Charge Codes using the table. Nominal Watts must equal circuit watts. For Highways England equipment this must be submitted to BSCCo as used nationwide.</i></b>	

The camera, which is the core component, shall be tested at five voltages and with a minimum of five samples. All other additional components, as detailed in the table above, shall be tested at one sample each and at one voltage.

Alternatively, where it is impracticable to disassemble the CCTV equipment and test each component separately, the whole equipment shall be tested at different operating modes. Please see below for an example:

#### **Example**

Suppose a CCTV equipment is made up of these components: Camera, Heater, Wiper, Pan & tilt motor, and Zoom. The whole equipment shall be tested at the following modes:

- Mode 1: Only the Camera itself in operation, with all other components switched off
- Mode 2: Camera and Heater in operation
- Mode 3: Camera and Wiper in operation
- Mode 4: Panning and tilting the Camera at full speed
- Mode 5: Zooming the Camera at full speed

BSCCo will compare the test data from Mode 1 against all other operating modes' to derive the energy consumption of each additional component. For example, to derive the energy consumption of the Heater itself, BSCCo will calculate the difference using the test results from Mode 1 and Mode 2.

Applicants shall test the camera, under Mode 1, at five voltages and with a minimum of five samples. For all other operating modes, only one sample of test data (with the Camera and the additional component being tested together) shall be supplied.

### **3-63.7 Test procedure for Constant Light Output (CLO)**

Evidence that includes beginning-, mid-, and end-of-life data shall be provided for equipment that has driver enabled CLO functionality. For this purpose mid-life is halfway through the design life of the product.

E.G. If the end-of-life current is 20% higher than the beginning-of-life current, then the driver output current should be adjusted to simulate 'end of life' conditions and the appropriate measurements taken.

This may be achieved by using a resistor or other methodology. A clear statement of methodology shall be supplied with the application.

The mid-point of the beginning of 'life' and 'end of life' data will then be used by BSCCo.

The mid-life circuit watts value will be used by BSCCo to define the Charge Code.

For Generic LED Lighting Charge Codes for driver enabled CLO, Applicants will notify their Customers of the 42 Series Generic LED Charge Code that has the circuit watt value (digits 3 to 6) matching the approved mid-life value. E.g. If the mid-life value for an LED street light is 52 Watts then the Applicant will notify their Customers that the Generic LED Lighting Charge Code is 42 0052 0000 100.

Where a CMS is being used to control lighting there are two methods to achieve CLO. If the built-in functionality of the driver or ballast adjusts the power level over the life of the equipment (irrespective of any additional dimming) the Charge Code that equates to the mid-life circuit watts is to be used in the Customer's inventory. However, if the CMS Program controls the power level over the life of the equipment in order to achieve CLO (in addition to any dimming), a CLO Charge Code must not be used.

i.e. CLO should either be controlled by the CMS Program or alternatively the CLO functionality is activated within the driver/ballast, but not both. Using both could have adverse effects.

### **3-73.8 Test procedure for Multi-Level Static Dimming (MLSD) Devices**

MLSD equipment will have different types of Charge Codes depending on whether the dimming control is integral to the ballast or not. Stand-alone dimming devices will be coded as a control Charge Code (i.e. 99 xxxx xxxx 100), as will photocells with inbuilt dimming control capability.

Where the dimming control is integral to the ballast, the equipment will be coded as 'Electronic Ballast with integral MLSD Dimming Equipment'. A dedicated Control Charge Code will be used in conjunction with these ballasts with an uplift of 1 Watt to account for the stand-by power. These codes can be coded either with specific lamp types or with any lamp type if the ballast will drive the lamps to specific values.

In addition to the requirement for test data set out in 3.21, evidence of the accuracy of the equipment in setting the switching times for on/off and dimming shall be provided. The manufacturer shall also provide evidence of the relationship between the control signal (e.g. 0-10v, DALI/DSI) and the percentage dimming with the application. Where the application is in association with a specific lamp then evidence shall be supplied showing the lamp being dimmed at 10% levels from 50% **energy** to full power. Where the equipment can be used with a range of lamps the manufacturer shall provide appropriate evidence that the product will dim correctly.

The Charge Codes provided will be associated with specific Switch Regimes and 'Variable Power Switch Regimes' will be published on the BSC Website: [Variable Power Switch Regime Spreadsheet](#)

Applications for Switch Regimes shall be made by the Customer or the manufacturer in accordance with the MLSD Switch Regime application process defined in 76.3.

### **3-83.9 Testing requirements for WiFi Equipment**

The equipment shall be tested as if operated in a realistic environment. This should be one of the testing requirements; to replicate, in a laboratory, the data flow that will go through the equipment during live operation 'in the field'. The test house shall consider the modes of operation that are appropriate for testing and set out clearly the test environment in the test report. Consideration should be given to:

- The signal strength;
- That any radio power indicators are active and connected to the network;
- There is an active internet connection at the Ethernet port;
- Where auxiliary access points are to be used to simulate a network, then ensure such access points are active and connection is confirmed;
- Confirmation of the frequency of the signal(s) and that it was active during measurement; and
- The materiality of network searching activity.

The measurements are to be taken after 15 minutes at each voltage level.

### **3-93.10 Testing requirements for 50 Series Electronic Ballasts**

To qualify for a 50 series Code the electronic ballasts will drive lamps at a given Watts regardless of the specification of the lamp attached to the ballast. The criteria to be considered in any application are defined as follows:

- That the ballast must be able to drive more than one lamp type (e.g. High Pressure Sodium and Metal Halide);
- The five test samples per lamp type should be supplied by the Applicant (i.e. 10 test samples, five for each lamp type for the two aforementioned lamp types);
- Data for full load and minimum power level must be supplied;
- That there can be a maximum divergence from the highest values lamp type at full power of 2%;
- That there can be a maximum divergence from the highest values lamp type at minimum power level of 5%; and
- Where the test data for the lamp / ballast combination diverge from the above criteria Charge Codes shall be provided separately for each lamp / ballast combination

If the equipment can only be used with High Pressure Sodium (SON) lamps then the 14 series will be used for construction of the Charge Code and not the 50 series.

### **3-103.11 Charge Codes for Central Management System (CMS) Equipment**

All CMS equipment (e.g. Controls, gateways and relays) are deemed to be operating continuously. The CMS will provide the actual detail on the operation of individual pieces of Apparatus controlled by the

system in a file called an 'event log'. The event log provides the on/off times and dimming percentages for each piece of Apparatus that is being controlled. The event log is obtained by the MA who calculates the energy volumes using the events (in the event log) and the 100% (full power) version of the Charge Code for each piece of Apparatus.

Therefore Customers should apply only for the full power Charge Code and not for dimmed Charge Codes for all the possible levels the equipment could dim to.

***~~3.11~~3.12 Charge Codes for Speed/ red light cameras or equipment that includes cameras***

If the equipment includes camera equipment then the Applicant shall confirm whether the operation of the flash is material to the consumption of the Apparatus and appropriate evidence shall be provided with the Charge Code application.

## 4 How are Charge Codes Calculated?

### 4.1 Equipment that is less than 10 Watts

For equipment that is rated as less than 10 Watts BSCCo will issue circuit watts to the nearest one decimal place, e.g. 2.125 = 2.1 Watts (1.d.p.). Please note that control equipment (Charge Codes beginning with '90' and above) will still always be given circuit watts to two decimal places.

Miscellaneous equipment is an exception and will always be coded to the nearest Watt to allow for the same value to be used as the nominal Watts in construction of a miscellaneous Charge Code.

### 4.2 Traffic signal heads

Cyclically operating lamps are treated as a continuous load and use the following assumed percentage operating times to give a load value per signal aspect. Please see below for an example calculation and [how to record traffic signals in your inventory](#):

Signal Lamp Type	% Operating Times Used in Charge Code Calculation
3 lamp vehicle aspects	One third of the total of 55% of red lamp + 5% of amber lamp + 45% of green lamp
2 lamp pedestrian aspects	50% of each lamp for tungsten 50% of the total of 80% of red lamp + 20% of green lamp for LED
Pedestrian "Wait" signals combined with Push Button Unit	Where the signal is only lit upon pushing the button; 20% of each lamp for tungsten 20% of the total of 80% of red lamp + 20% of green lamp for LED  Where the unit constantly displays a signal; 50% of each lamp for tungsten 50% of the total of 80% of red lamp + 20% of green lamp for LED
Filter lamps	20% of each lamp
Belisha Beacons	62% of each lamp
School Crossings	50% of each lamp
Dimmed lamps	Tungsten lamps shall be rated at the full circuit watts for the daytime period and at 66% of the circuit watts for the night-time period. LED lamps are case by case in accordance with Charge Code testing.
Continuous Green Aspect	100% of aspect

## Example

Let us consider the following example:

For some manufacturers of LED lamp aspects the Watts may vary by the lamp colour. The nominal Watts used in the Charge Code will be the average of the different colour lamp energy in Watts.

A manufacturer contacts BSCCo with a new traffic signal with a 3 aspect head, red of 11.8W, Amber 11.1W and green 14W.

So from the section above, the operating time for each aspect is as follows:

- The red aspect is on 55% of the time  $11.8W \times 0.55 = 6.49W$
- The amber aspect is on 5% of the time  $11.1W \times 0.05 = 0.56W$
- The green aspect is on 45% of the time  $14.0W \times 0.45 = 6.30W$

This accounts for the signal aspects being on for a different amount of time depending on the colour. The total power is 13.35W, but then this figure is then divided by 3, which gives the circuit watts of an individual lamp aspect. In this case it is 4.4W per aspect. Exactly the same process would apply for calculating the dimmed circuit watts if applicable.

The code would thus be: 79 xx yyy 000 100, circuit watts (day)

(xx is used to represent whether the traffic signal is LED, Tungsten, dimmed/undimmed, etc...)

(yyy is the nominal circuit watts calculated by averaging the LED ratings for each colour aspect)

### 4.2.1 Continuous green aspects

Where the traffic head also contains a continuous green aspect a separate Charge Code at 100% power will be defined thus: 79 56 yyy 000 100 or 79 57 yyy 000 100 (if the aspect is LED)

### 4.2.2 How do I record traffic signal equipment in my inventory?

For inventory purposes, the Charge Code is for each individual lamp within a head or aspect. From the section above you can see that the circuit watts are calculated for each aspect, taking into account how long each colour aspect is on for. This means that the Charge Code shall be entered as a quantity of 3 for a standard 3 aspect traffic signal. If continuous green aspects are present then the aspect Charge Code should also be declared with the appropriate quantity.

### 4.2.3 Dimming Traffic Signals

All Traffic Signals take an electricity supply on a continuous basis and normally in an inventory would be allocated against Switch Regime Code 001. However, large numbers of Traffic Signals can operate in a dimmed mode at night through voltage reduction. The switch to dimmed mode is triggered by the operation of a Dusk to Dawn Photoelectric Control Unit (PECU) (or time switch), which when switched on in the evening, causes the voltage to reduce. This means that the equipment is now operating at the dimmed Watts (or night Watts) figure shown in the Charge Code Spreadsheet. When the PECU switches off in the morning the voltage increases and the equipment operates at full brightness and circuit watts in the Charge Code Spreadsheet.

When submitting such equipment in an inventory, the Switch Regime code for the PECU (or time switch) in the Switch Regime Spreadsheet should be shown against that item.



If the item is traded on a NHH basis the operating hours to be used in the EAC calculation for the dimmed (Dusk to Dawn) operation will be those shown against the relevant Switch Regime in the Switch Regime Spreadsheet, i.e. 821 for a 70/35 Lux electronic photocell.

For the day time (Dawn to Dusk) operation the hours to be used will be the continuous hours for Switch Regime 001 (8,766 hours) minus the dimmed hours. A worked example is shown below:

Take an inventory in the Midlands, which includes 300 x 50 Watt Red Amber Green Vehicle Aspects with a Charge Code of 7902050000100. These are switched to dimmed operation by use of 70/35 Electronic PECUs which is Switch Regime 821.

The calculation will be:

$300 \text{ items} \times 12\text{W} \times 4,150 \text{ hours} / 1,000 = 14,940.0 \text{ kWh}$  allocated to the Dusk to Dawn profile.

$300 \text{ items} \times 18\text{W} \times 4,616 (8,766-4,150) \text{ hours} / 1,000 = 24,926.4 \text{ kWh}$  allocated to the Dawn to Dusk profile.

If the item is traded on a HH basis the Equivalent Meter will work out bright and dimmed loads based on the hours of operation of the relevant photocell.

#### 4.2.4 Dummy Loads for LED Traffic Lights

A Dummy Load is required for some LED lights to increase the load so that a lamp monitor system would pick up if a lamp fails. The dummy load is to be applied to the lamp circuit watts as part of the test process. Where evidence is provided that different dummy loads are set dependent on equipment types then more than one Charge Code can be constructed using the appropriate uplift.

#### 4.2.5 What are filter signals?

The coding for a traffic light containing four or more aspects depends upon the use of the other aspects.

#### 4 (or more) Signal Aspects

If the fourth aspect is on for the same time as another head, e.g. left arrow on at the same time as the straight ahead signal, then a quantity of 4 must be associated with the corresponding 3 head lamp Charge Code.

If the length of time is the same as (or greater) than the green signal light, it shall be counted as a normal green signal lamp. In this case a quantity of 4 (1 red + 1 amber + 2 green aspects) would be entered on the detailed inventory for the relevant Charge Code.

#### Part of Green Sequence

If the fourth aspect is only on for part of the time, e.g. a right filter arrow on for part of the time of the straight ahead signal, then a quantity of 3 shall be associated with the specific Charge Code and also a quantity of 1 shall be associated with the correct Charge Code for the filter lamp head.

Traffic filter signals are coded as 20% of the full circuit watts of the lamp to recognise that they are only illuminated for part of the green sequence. The definition of a green filter signal is a green signal indicating movement for a specific amount of time. This amount of time **must** be less than the time that the main green signal light is on for.

### **4.3 Cable network cabinets (Miscellaneous Codes Starting 813)**

The wide variety and different makes of equipment (power amplifiers, distribution amplifiers, etc.) used in communication distribution cabinets makes it extremely difficult to provide an accurate breakdown of equipment for each installation (with corresponding Charge Codes). In addition a cabinet may be directly connected to the Distribution Business's network and then supply energy to equipment in other cabinets downstream of that cabinet, via the Customer's own communication network and associated private wiring.

It is therefore necessary to measure the actual load (spot check) at each exit point from the Distribution Business's network, and to quote the load applicable to each exit point in bands of 20 Watts (i.e. 400, 420, 440, etc.). The Customer shall round to the nearest 20 Watts and declare that Watts on the inventory via a Charge Code.

As examples, if a particular load is measured at 458 Watts, then it is rounded to 460 Watts, whereas 448 would be rounded to 440 Watts. The Charge Codes entered on the inventory would be 813 0460 000 100 and 813 0440 000 100, respectively.

## 5 What is Half Hourly (HH) and Non Half Hourly (NHH) Trading?

Currently Customers can trade their electricity in three ways, either NHH, passive HH or dynamic HH. The main difference between them is the use of dynamic data.

Dynamic data is actual recorded data such as the switching times of a representative sample of photocells contained in a PECU array. Data recorded by a CMS is also dynamic data, with the switching times of each individual lamp controlled by the system and/or power levels being recorded.

### 5.1 Half-Hourly (HH)

HH data is the energy consumption of a Customer in kWh, apportioned into the correct half hour of each day.

Dynamic HH trading achieves this by use of the data obtained from PECU arrays and/or any CMS.

Passive HH achieves this by using the calculated Sunrise/Sunset times. Passive HH does not use any dynamic data.

In order to trade HH an MA must be appointed. The MA is appointed by the Supplier and contracted by the Customer (who may have chosen to operate HH).

### 5.2 Non-Half Hourly (NHH)

NHH trading does not use any dynamic data and instead uses an estimated number of annual hours for each type of photocell Switch Regime. These annual hours are published by BSCCo in the Switch Regime Spreadsheet. The appropriate Category for each Switch Regime is defined in the Switch Regime Spreadsheet. The Category shown in the spreadsheet is not appropriate for certain load types:

- Traffic signal equipment, particularly where dimming is in use, so traffic signal consumption should always be regarded as either Category A – continuous; or split in proportion across Category B – Dusk to Dawn & Category D – Dawn to Dusk.
- Thermal & hybrid photocells daytime load would be allocated to Category D – Dawn to Dusk
- All other equipment controllers (electronic photocells, time switches, etc.) would be allocated to Category A – continuous

## **6 Photoelectric Control Unit (PECU) array location and siting guidance**

If there is disagreement regarding the location and siting of a Customer's PECU array or the number of arrays required, BSCP520 'Unmetered Supplies registered in SMRS' makes reference to carrying out 'research'.

This section is intended to expand on the type of research that can be considered by the MA and UMSO when agreeing proposed locations.

### **6.1 Location of a single array**

#### **6.1.1 Weighted latitude and longitude of inventory**

If there is latitude and longitude information contained in the Customer's detailed inventory, it should be possible for the MA and/or UMSO to perform a weighted longitude/latitude calculation to see where the ideal location of a single PECU array should be.

#### **6.1.2 Weighted latitude and longitude of population**

If known, it is possible to perform the calculation described above but using the population figures of the various major towns in the Customer's area.

### **6.2 Deciding on multiple or single arrays**

The number of arrays may be subject to decisions on the number of PECU types that can be populated in the array. More than one array may be required if the population of PECUs for a Customer cannot be reasonably represented on a single array of 30 PECUs. Furthermore, the size of the Customer's area might require more than one array to facilitate accurate calculation of Burn Hours. It is possible for the MA to calculate the Annual Burn Hours for any latitude and longitude. If the differences between the proposed array sites are very small (i.e. less than +/- 2%) then this would suggest that one array should be sufficient. If actual Burn Hours are available for existing arrays this data could also be used.

### **6.3 Hosting and maintenance of the arrays**

It is now common practice for the Customers to host PECU arrays. The MA is responsible for ensuring the siting of the array complies with all the considerations of the PECU array siting procedures defined in **BSCP520 'Unmetered Supplies registered in SMRS'**.

Where PECUs are identified for replacement the MA can direct the Customer to replace the PECU with an appropriate PECU, taking into account the type and age and any changes to the Customer's population of PECUs (keeping it representative). The MA shall ensure on the next dial that the replaced cell is performing in line with expectations.

## 7 What are Switch Regimes?

Switch Regimes are three character alpha-numeric codes that allow the operating hours for equipment to be determined. This information together with the power information obtained from the Charge Code allows consumption (kWh) to be calculated.

The Switch Regime is a component of the detailed inventory submitted by the Customer to the UMSO. This is then used by the UMSO (for NHH Customers) or the MA (for HH Customers) to determine the consumption.

The Customer's own records include, in some format, the switching arrangement. The record for each item shall be completed at the initial installation and then updated when any changes take place. The failure to record changes in lamp or Switch Regime is one of the most common sources of inventory errors.

Switching devices are purchased either by the Customer or by the Customer's contractors to the Customer's specification. The Customer specifies the switching arrangement for a particular item on the work order issued to the installer or the repair/maintenance operative.

The Regime Code for a particular device is usually obtained from either the BSC Website, the manufacturer of the control device or the UMSO.

Customers normally have a definite policy on the use of particular switching regimes and only use a few codes. The current emphasis on energy saving, carbon reduction and cost control has resulted in some Customers starting programmes to change areas to part night operation and/or to specify photocells that operate at lower light levels. It is important to use the correct code so as to ensure that the expected cost benefits are actually achieved.

The following Switch Regime Codes provide a standardised listing of switch types. For NHH Trading these cross reference to annual burning hours used in the calculation of the EAC. If an inventory is HH traded either calculated switching times (passive data) or the switching times from either a PECU array or a CMS (dynamic data) will be used to calculate HH consumptions.

BSCCo will from time to time review the annual burning hours used for NHH EAC calculations and adjust the hours based upon representative data obtained from PECU arrays. A default value for burning hours will be assigned to a new Switch Regime until 12 months' data has been collected and the burn hours can be calculated.

Switch Regime	Switch Regime Description	Examples of Equipment Type
001	No switching – 24 Hour Burning	Traffic signals, traffic signs continuously burning, variable message signs, Pedestrian underpass/subway lighting (although some installations may be under time control), CCTV Systems and various detection equipment, Traffic Counters, and much of the miscellaneous equipment
010-036	Manual Switching Equipment - to be used for equipment which is manually switched on and off for pre-determined periods per day, month or year.	School Patrol Crossing Flashing Lights

Switch Regime	Switch Regime Description	Examples of Equipment Type
040-059	Motorway Control Centre Switching: Message Signs and Signals	For use by Highways England
078-079	Part Time Traffic Signals	
100	Infrared detectors	These are typically in the base of bollards. The hours associated with IR detectors have been derived to be in excess of the most common PEC type (70/35). The offset values to Sunrise and Sunset is set to negative number.
200-399	Time Switch Control - - to be used for equipment which is controlled by a time switch that has pre-determined on/off periods per day, month or year.	Normal time switch control, Part night lighting controlled by time switch
400-499	Thermal Photo Cells (Positive Differential Switch "ON/OFF")	Thermal photo cell controllers are units in which the output of the photo cell is directly fed to the bi-metallic strip which provides both the switching and the time delay. These units generally have a positive differential for switching. For example, 100 Lux 'ON' 200 Lux 'OFF' although other switch 'ON/OFF' levels are available.
500-599	Electronic Photo Cell Time Switch (Part Night Dimming Controller)	Equipment which is automatically switched on and then to a single preset dimming level for part of the night. These are given in GMT and clock times. Please refer to information given below on part-night dimming.  This series cannot be used with Charge Codes ending in '100'.
600-699	Hybrid Photo Cells (Negative Differential Switch "ON/OFF")	Hybrid photo cell controllers are units in which the output of the photo cell is fed to the bi-metallic strip via an electronic circuit which provides the time delay. The bi-metallic thermal strip only acts as switching mechanism. These units generally have a negative differential for switching. For example, 70 Lux "ON" 35 Lux "OFF" although other switch "ON/OFF" levels are available. See further detail on Hybrid/ Thermal PECUs given below.
700-799	Electronic Photo Cell Time Switch (Part Night Controller)	The actual switch 'ON' times are controlled by a photo electric cell with the midnight switch 'OFF' times being factory preset (alternative factory switching 'OFF' times are available). An early morning switch 'ON' factory preset for 05.00 (alternative factory switching 'ON' times are available) with the switch 'OFF' being controlled by the photo electric cell.

Switch Regime	Switch Regime Description	Examples of Equipment Type
800-899	Electronic Photo Cells (Negative Differential Switch "ON/OFF")	Electronic photo cell controllers are units in which the output of a photo cell is fed to a switching mechanism (generally solid state but can be an electro mechanical relay) via an electronic circuit which provides the time delay. These units generally have a negative differential for switching. For example, 70 Lux 'ON' 35 Lux 'OFF' although other switch 'ON/OFF' levels are available.
998-999	CMS Controlled Equipment	CMS controlled equipment only. The Switch Regime code shall be set to 999 to denote the use of switched equipment (i.e. normal operation is Dusk to Dawn), or 998 to denote equipment which is normally operating continuous.
A01 to AZZ	MLSD Switch Regimes: (70/35)	For use with of MLSD equipment with variable on/off switching that aligns to 70/35 PECU.
B01 to BZZ	MLSD Switch Regimes: (55/28)	For use with MLSD equipment with variable on/off switching that aligns to 55/28 PECU.
C01 to CZZ	MLSD Switch Regimes: (Timeswitch)	For use with MLSD equipment with on/off switching controlled via a timeswitch (fixed or programmable). No separate control code is required.
D01 to DZZ	MLSD Switch Regimes: (35/18)	For use with MLSD equipment with variable on/off switching that aligns to 35/18 PECU.
E01 to EZZ	Part Night Switch Regime defaults	These Switch Regimes provide the Offset values to be used by MAs when Electronic Photo Cell Time Switch Regimes (Part Night Controller) in the 700 Series default.

A complete list of all [Switch Regimes](#) may be found on the [BSC Website](#).

## 7.1 *Hybrid/thermal Photoelectric Control Units (PECUs)*

Unlike Electronic PECUs these items only use energy when the PECU is switched off, i.e. between Dawn and Dusk.

If an inventory is traded NHH, in order to calculate an EAC it is necessary to determine the Dawn to Dusk operating hours. The hours to be used will be the continuous hours of 8,766 less the Dusk to Dawn hours shown in the Switch Regime Spreadsheet for a particular type of PECU, the remainder being the Dawn to Dusk operating hours.

### **Example**

An inventory in the Midlands GSP Group has a total of 10,000 Thermal 70/140 PECUs, Switch Regime 421. The operating hours for this Switch Regime from Dusk to Dawn are 4,246, which means that each PECU uses 3 Watts of electricity for 4,520 hours (8,766-4,246) annually between Dawn and Dusk. The EAC calculation is 10,000 items x 3 Watts x 4,520 hours / 1,000 = 135,600 kWh allocated to the Dawn to Dusk profile.

If the PECUs are included in a HH inventory the Equivalent Meter will apply the circuit watts to the energy consumption calculations for those periods when the associated PECU in the array is in a 'switched off' state and zero Watts when the PECU is logged as 'switched on'.

## 7.2 *Part night dimming*

Part night dimming allows a Customer to reduce their energy consumption and carbon emissions for part of the night. The power of the lamp will be reduced typically around midnight, returning to full power at the desired time, typically when traffic volumes increase again in the morning.

Under the current arrangements only a single dimming step can be accommodated outside of the CMS or MLSD processes as described in this document.

For more information on CMS please refer to the [ELEXON CMS fact sheet](#).

The codes required for single step part night dimming are the '500' Series. These are given in GMT and clock time. These have a calculated number of hours per annum that the lamp will be on at full power and at dimmed power. In order to use these reduced hours, a Charge Code with dimmed circuit watts will also need to be quoted on the Customer's inventory (i.e. the last three digits of the Charge Code should be less than 100, such as 060).

Part night cells are a direct plug-in replacement for normal photocells. They can either simply switch the load 'ON', 'OFF', 'ON', 'OFF' during the night or 'ON', 'DIM', 'BRIGHT', 'OFF' according to the type of cell and the particular equipment they are controlling. In the middle of summer, the cells may not switch back 'ON' in the morning.

Typically, they calculate midnight by determining the mid-point of the last three on-off cycles then switch the load 'ON', 'DIM' and 'OFF' at the times already programmed into the cell at the time of manufacture.

A more sophisticated version is available that adjusts for the change from GMT to BST and back to GMT. The transition is triggered when the time that the cell is switched 'ON' during 24 hours equals the time the cell is switched 'OFF'.

E.G. Assuming a Customer has a SELC 4000 ECONO 100 Watt Part Night Ballast (Dimmed 72% circuit watts). The Customer wants to benefit from the dimming available. They contact their UMSO to inform them that they are now dimming their lamps from 23:00 to 05:00.



The Customer would update the Switch Regime in their inventory to 530. They would also need to quote the correct Charge Code: 14 0100 5004 072.

To calculate the energy consumption (using the NHH hours published for the Eastern GSP Group) the following would apply;

Bright Hours = 1676, Dimmed Hours = 2475, Full Power circuit watts = 110, Dimmed circuit watts = 79

$$\begin{aligned} & (1676 \times 110) / 1000 + (2475 \times 79) / 1000 \\ & = \text{Dimmed Consumption } 184.36 + \text{Full Power Consumption } 195.525 \\ & = 380\text{kWh per annum (to the nearest kWh)} \end{aligned}$$

For a full list of Charge Codes that support dimming please see the [Charge Code Spreadsheet](#).

### **7.3 Multi-Level Static Dimming (MLSD) Switch Regimes**

A Customer (or the driver / ballast manufacturer) can apply for a MLSD Switch Regime from BSCCo. The application can be made for a single change in power level or up to eight different power levels, including the 100% level, in a 24-hour period. These Switch Regimes can only be paired with Charge Codes that have '100' as their last three digits.

The manufacturer or lighting engineer can set the Apparatus to any dimming level between 10% and 85% of full power (noting the limit of eight events). However, when applying for the MLSD Switch Regimes the Applicant should round the dimming levels to the nearest 5% boundary (percentages ending in a 0 or a 5).

More specifically, if the dimming % ends in a 1, 2, 8 or 9 then round to nearest % ending 0. If dimming % ends 3, 4, 6 or 7 round to nearest dimming % ending in a 5.

E.g. Assuming dimming % are always whole numbers and the Apparatus is physically set to dim to 52% of full power at 02:00 hours and to 68% full power at 04:00 hours. The application for a Switch Regime would be for 50% of full power at 02:00 hours and 70% full power at 04:00 hours.

The Applicant will also declare if the switch times are in Co-ordinated Universal Time (UTC) (equivalent of Greenwich Mean Time (GMT)) or if the times are 'Clock Time' (GMT in winter and British Summer Time (BST) in summer).

Where a dimming device can be configured remotely or locally the manufacturer (or its representative) will provide an undertaking to BSCCo that the Customer will not be provided with the ability to change the operation of the device. Furthermore, any changes undertaken on behalf of the Customer will be reported to both BSCCo and the host UMSO. The Customer must provide a new inventory immediately declaring the new Switch Regimes for a Variable Power Switch Regime as defined in the Variable Power Switch Regime Spreadsheet on the BSC Website: [Variable Power Switch Regime Spreadsheet](#)

The Switch Regime will be calculated based on a 70/35, 55/28, 35/18 or 20/20 Lux PECU or Time Switches.

## 7.4 **Variable Power Switch Regime Spreadsheet**

The [Variable Power Switch Regime Spreadsheet](#) displays all events and percentages on a single line, to allow users to filter entries. A single-step dimming to 50% would give the following information:

- Switch Regime: 01A (UTC)
- On Event: PECU
- Power %: 100
- Switch Event 2 Time: 01:00
- Switch Event 2 Power % Energy: 50
- Switch Event 3 Time: 05:00
- Switch Event 3 Power % Energy: 100
- Off Event: PECU

The [Switch Regime Spreadsheet](#) shows the average Burn Hours (if at full circuit watts) used to calculate the NHH EAC.

### 7.4.1 **The energy calculation for single or MLSD dimming using Generic LED Lighting Charge Codes or other Charge Codes ending '100'**

Where a Customer purchases their unmetered energy on a HH basis, the MA uses the MLSD dimming approach for both multi and single step dimming. That is, they will enter the dimming level and timings indicated by the Switch Regimes into the Equivalent Meter<sup>2</sup>. Any percentage reduction in power will then be applied to the full circuit watts at the indicated times. The energy calculations that determine the HH consumption values for the LED lighting Apparatus will reflect the dimming (reduced power).

Where a Customer purchases their unmetered energy on a NHH basis, this requires the UMSO to estimate the annual consumption of the Apparatus (the EAC).

For a 100 Watt Generic LED street light dimmed from 01:00 to 05:00 hours (UTC) with Switch Regime Burn Hours of 3496 hours per year the calculation would be:

$$100 \text{ Watts} * 3496 \text{ Hours} = 349.6 \text{ kWh per year}$$

We calculated this using the Burn Hours (3496 hours) and converting to kWh, using a generic Charge Code ending '100' (e.g. 42 0100 000 100).

## 7.5 **Motorway operating hours**

Annual motorway operating hours will be calculated by Highways England based on actual operational information. These are updated periodically and issued to UMSOs.

---

<sup>2</sup> An Equivalent Meter is the software used by an MA to calculate the HH energy consumption.

**7.6 Valid Combinations of Charge Codes and Switch Regimes**

	Equipment Type	Lamp /Ballast Charge Codes ending in 100	Lamp /Ballast Charge Codes ending in less than 100	Lamp /Ballast Charge Codes for use with MLSD	School Crossing Patrol Warning Signals	Traffic Signal Equipment (Non Dimming)	Traffic Equipment (Dimming)	Miscellaneous (Non Dimming)	Any Legacy Charge Code beginning 800-899 that has been given a dimming circuit watts value	Control Host	
	Charge Code range	Prefixed 01 to 50	Prefixed 01 to 50	Prefixed 40, 41, 42 or 50. Also any prefixed 14 and 21-33 where dimming is possible	Prefixed 7918 or 7947	Prefixed 7901, 7903, 7905 to 7917, 7919 to 7923, 7925 to 7927, 7930 to 7938, 7940, 7942, 7944, 7946, 7948 <sup>3</sup> , 7952, 7954, 7956, 7957,	Prefixed 7902, 7904, 7924, 7929, 7939,7941, 7943, 7945, 7950, 7953 <sup>4</sup> , 7955, 7958, & 7959	Codes beginning 800 - 899 except those listed as dimming		815	
Switch Regime Type	Switch Regime Series			<b>Valid Combination</b>							
Continuous - No switching - 24 Hour Burning	001	Yes	No	No	No	Yes	No	Yes	No	No	
Manually Switched e.g. School Crossing Patrol Flashers	030 to 036	No	No	No	Yes	No	No	No	No	No	
Part Time Traffic Signals	078	No	No	No	No	Yes	No	No	No	Yes	

<sup>3</sup> The 7948 Series Charge Code can additionally be used with Dusk to Dawn or self-control Switch Regime types.

<sup>4</sup> The 7953 Series increases in load at night due to a night light but is treated as per Dimming Charge Codes

	Equipment Type	Lamp /Ballast Charge Codes ending in 100	Lamp /Ballast Charge Codes ending in less than 100	Lamp /Ballast Charge Codes for use with MLSD	School Crossing Patrol Warning Signals	Traffic Signal Equipment (Non Dimming)	Traffic Equipment (Dimming)	Miscellaneous (Non Dimming)	Any Legacy Charge Code beginning 800-899 that has been given a dimming circuit watts value	Control Host	
	Charge Code range	Prefixed 01 to 50	Prefixed 01 to 50	Prefixed 40, 41, 42 or 50. Also any prefixed 14 and 21-33 where dimming is possible	Prefixed 7918 or 7947	Prefixed 7901, 7903, 7905 to 7917, 7919 to 7923, 7925 to 7927, 7930 to 7938, 7940, 7942, 7944, 7946, 7948 <sup>3</sup> , 7952, 7954, 7956, 7957,	Prefixed 7902, 7904, 7924, 7929, 7939,7941, 7943, 7945, 7950, 7953 <sup>4</sup> , 7955, 7958, & 7959	Codes beginning 800 - 899 except those listed as dimming		815	
<b>Switch Regime Type</b>	<b>Switch Regime Series</b>			<b>Valid Combination</b>							
Part Time Traffic Signals	079	No	No	No	No	Yes	No	No	No	Yes	
Infra Red Photo Cells (see Note Below) <sup>5</sup>	100	Yes	No	No	No	No	No	Yes	Yes	Yes	
Full Night Time Switches	200 to 210, 370 & 380	Yes	No	No	No	No	Yes	Yes	Yes	Yes	
Part Night Time Switches	219 to 369, 371 to 377 & 381	Yes	No	No	No	No	No	Yes	No	Yes	
Thermal Photo Cells	400 - 499	Yes	No	No	No	No	Yes	Yes	Yes	Yes	
Single Stage Dimming Devices	500 -599	No	Yes	No	No	No	No	No	No	Yes	

<sup>5</sup> Infrared detectors are typically located in the base of bollards (at ground level and under an opaque cover) which results in significantly longer operating hours than if an infrared detector were located within a PECU array in an elevated location. Therefore infrared detectors should not be included within an PECU array but the burning hours should be derived using the extended offsets defined in the Switch Regime Spreadsheet on a passive basis."

	Equipment Type	Lamp /Ballast Charge Codes ending in 100	Lamp /Ballast Charge Codes ending in less than 100	Lamp /Ballast Charge Codes for use with MLSD	School Crossing Patrol Warning Signals	Traffic Signal Equipment (Non Dimming)	Traffic Equipment (Dimming)	Miscellaneous (Non Dimming)	Any Legacy Charge Code beginning 800-899 that has been given a dimming circuit watts value	Control Host	
	Charge Code range	Prefixed 01 to 50	Prefixed 01 to 50	Prefixed 40, 41, 42 or 50. Also any prefixed 14 and 21-33 where dimming is possible	Prefixed 7918 or 7947	Prefixed 7901, 7903, 7905 to 7917, 7919 to 7923, 7925 to 7927, 7930 to 7938, 7940, 7942, 7944, 7946, 7948 <sup>3</sup> , 7952, 7954, 7956, 7957,	Prefixed 7902, 7904, 7924, 7929, 7939,7941, 7943, 7945, 7950, 7953 <sup>4</sup> , 7955, 7958, & 7959	Codes beginning 800 - 899 except those listed as dimming		815	
Switch Regime Type	Switch Regime Series			<b>Valid Combination</b>							
Hybrid Photo Cells	600 - 699	Yes	No	No	No	No	Yes	Yes	Yes	Yes	
Part Night Electronic Photo Cells	700 - 799	Yes	No	No	No	No	No	Yes	No	Yes	
Electronic Photo Cells	800 - 899	Yes	No	No	No	No	Yes	Yes	Yes	Yes	
CMS (Continuous - No Switching)	998	Yes	No	No	No	No	No	Yes	No	No	
CMS (Switching)	999	Yes	No	No	No	No	No	Yes	No	No	
MLSD	A01-AZZ, B01-BZZ, C01 - CZZ and D01-DZZ	No	No	Yes	No	No	No	No	No	Yes	

## 8 Standard file format for detailed inventories

Customers should maintain an inventory of their unmetered equipment to enable them to populate a file with the data described in this section. Where typical unmetered equipment is supplied by a metered feeder pillar then this should be recorded in the inventory system and not included within the inventory submitted to the UMSO. Otherwise the consumption will be charged for twice.

Customers may have equipment connected to more than one Distribution Network, it is therefore important that the inventory identifies which Network Operator each unmetered equipment is connected so that the inventory can be submitted to the correct UMSO.

### 8.1 General comments

The inventory shall be submitted either as a fixed format text file or as a comma separated file with a line for each item of inventory.

The file format below is that which shall be supplied by the Customer or as otherwise agreed with the UMSO. The file format shall contain, as a minimum, the following information:

- a) a list of items of Unmetered Equipment providing a unique identification and geographical location of each item;
- b) the number of items of each category of Unmetered Equipment, classified by Charge Code and Switch Regime. Items not able to be so classified shall be identified and quantified separately;
- c) the nominal rating for each Charge Code shall be indicated; and
- d) the Switch Regime for each UMS equipment. Items not able to be so classified shall be identified separately.

For the purposes of this Unmetered Supplies Operational Information Document, reference to the Summary Inventory means only the summarised information identified in (b), (c) and (d) above.

## 8.2 Standard file format

Field No.	Name	Details Required	Type	Length	Start Position	Finish Position
1	Road Reference	e.g. Ordnance Survey Number	Text	8	1	8
2	Town, Parish, District		Text	30	9	38
3	Road Name		Text	30	39	68
4	Location		Text	20	69	88
5	Unit Type	Identifies the record as a lamp or a sign, etc. B = bollard; F = school crossing flashers; L = street light; M = miscellaneous; P = pillar; R = Refuge Beacon; S = sign light; T = traffic signal equip; Z = Belisha Beacon (Zebra)	Text	1	89	89
6	Unit Identity	Identity shown on unit (if any)	Text	12	90	101
7	CMS Unit Reference	Unique alphanumeric identifier of the CMS Unit (if applicable)	Text	12	102	113
8	Charge Code	Appropriate BSCP520 code	Numeric	13	114	126
9	No. of Items	Number of items of this Charge Code at this location	Numeric	3	127	129
10	Switch Regime	Appropriate BSCP520 code	Alpha-Numeric	3	130	132
11	No. of Controls	Number of PECs or time switches on the item	Numeric	1	133	133
12	Control Charge Code	Appropriate BSCP520 code for the control device	Numeric	13	134	146
13	Ordnance Survey Grid ref or 'Easting' or Longitude	This can be either in Longitude or Easting	Text	11	147	157
14	Ordnance Survey Grid ref or 'Northing' or Latitude	This can be either in Latitude or Northing	Text	11	158	168
15	Exit Point (Optional)	Y if Yes, N if No, U if Unknown	Text	1	169	169

The data, with the originator clearly identified, shall be either on a CD or attached to an email. It may be a compressed .ZIP file but NOT a 'self extracting .EXE' archive.

### 8.3 Notes on standard inventory format

This format has been developed to provide the information required for the operation of BSCP520 and the auditing requirements of Distribution Businesses in a standard way. It is expected to be of particular benefit to Customers with unmetered equipment in more than one Distribution Licence area and to suppliers of inventory software who wish to provide a standard extract package for their Customers.

It is NOT intended to supersede existing arrangements where both the Customer and the Distribution Business agree to continue with a different format. With respect to the longer, 13 digit Charge Code, the Distribution Business will continue to support the 'old' seven digit Charge Code format for a period of time to be agreed with the UMS Customer.

**Field 1** Road Reference

National Street Gazetteer Unique Street Reference Number is the preferred format because it provides a better location than the combination of road name and town. It is also a very useful sort field when checking for duplicate records.

NSGIR codes are not available for motorways so the motorway reference shall be used e.g. M42, A1(M)

**Field 3** Road Name

In the case of Motorways this will be the Motorway reference number e.g. M42, A1(M)

**Field 5** Unit Type

B = bollard	F = school crossing flasher	L = street light
M= miscellaneous	P = pillar	R = refuge beacon
S = sign light	T = traffic signal equip	Z = zebra crossing

**Field 7** CMS Unit Reference

Where this field is populated, the Switch Regime code in Field 10 shall be reported as either 998 or 999.

**Field 11** No. of Controls

In the case of isolation pillars which only contain a time control device and no other load consuming device then the number of time control devices shall be entered here and the appropriate Charge Code in field 11. Zeroes shall be entered in fields 8 & 9.

**Fields 13, 14** Grid References or Latitude and Longitude

Data is to be inserted in these fields when available. The increasing use of GPS equipment provides very accurate location data which may supplement or be in addition to the location in Field 4.

**Field 15** A 'Y' identifies if the equipment is connected directly to the Distribution network, a 'N' indicates fed via some private distribution network, i.e. a sign light looped from a lighting column, or column fed from private distribution cables.



## **8.4 Notes for Customers on declaring Charge Codes and Switch Regimes for Multi-Level Static Dimming (MLSD) Devices**

These notes are provided for the accurate declaration of Charge Codes and Switch Regimes for MLSD devices:

### **Dimming devices integral to the ballast or driver:**

- The Charge Code for the dimming-equipped lamp/ballast ending in '100' must be declared in Field 8;
- A valid alpha-numeric Switch Regime that corresponds to the operation of the device will be declared in Field 10; and
- A Control Charge Code in the 99 series that accounts for any standby power used by the ballast will be declared in Field 12. It also includes the power of a standard photocell so please note the 99... Charge Code will be used instead of a standard photocell Charge Code.

### **Dimming devices that are stand alone or integral PECU:**

- The standard Charge Code for the lamp/ballast(s) must be declared in Field 8;
- A valid alpha-numeric Switch Regime that corresponds to the operation of the device will be declared in Field 10; and
- The Charge Code for the dimming device in the 99 series will be declared as the Control Charge Code in Field 12. Please note a separate Charge Code for the photocell is not required as its consumption is included in the 99... control Charge Code.

*Note: Valid Combinations for declaration can be found in the Variable Power Switch Regime Spreadsheet on the BSC Website: [Variable Power Switch Regime Spreadsheet](#)*