



Redlined Code of Practice (CoP) 10 text for CP1479 'Updates to the Defined Metering Points in Codes of Practice 1, 2, 3, 5 and 10'

This CP proposes changes to Appendix A. We have redlined these changes against Version 9.0.

We also included housekeeping changes.

There is no impact on any other part of this document for this CP.

Amend Appendix A as follows:

APPENDIX A DEFINED METERING POINTS

For transfers of electricity between the following parties the Defined Metering Point (DMP) shall be at one of the following locations:-

1. For transfers between ~~the~~ Transmission System ~~operator~~ and a ~~single~~ Distribution System operated by a Licensed Distribution System Operator where no other Party(s) are connected to the busbar, the DMP shall be at the point(s) of connection to the Transmission System. A Party shall install Metering Equipment at a point on the circuit (e.g. the common incoming circuit for double busbar connections) within 50 metres of the DMP. Such point shall be the Actual Metering Point for the purposes of this Code of Practice~~lower voltage side of the supergrid connected transformer.~~
2. For transfers between ~~the~~ Transmission System ~~operator~~ and a ~~single~~ Distribution System operated by a Licensed Distribution System Operator where other Party(s) are connected to the busbar, the DMP shall be at the circuit connections to that Distribution System operated by a Licensed Distribution System Operator.
3. For transfers between ~~the~~ Transmission System ~~operator~~ and more than one Distribution System operated by a Licensed Distribution System Operator connected to the same busbar, the DMP shall be at the circuit connections of each Distribution System operated by a Licensed Distribution System Operator to such busbar.
4. For transfers between Distribution Systems operated by Licensed Distribution System Operators, not including a connection to the Transmission System, the DMP shall be at the point(s) of connection of the two Distribution Systems operated by Licensed Distribution System Operators.
5. For transfers between ~~the~~ Transmission System ~~operator~~ and:-
 - (i) Generating Plant, the DMP shall be at the point(s) of connection of the Generating Plant to the Transmission System~~high voltage side of the generator transformers and station transformer(s).~~
 - (ii) An Offshore Power Park Module(s) comprising a single BM Unit, the DMP shall be at the point(s) of connection of the Offshore Power Park Module to the Transmission System. A Party may install Metering Equipment at either:
 - the DMP; or
 - a point or points on the Offshore Platform, other than the DMP. Such point or points shall be the Actual Metering Point for the purposes of this Code of Practice.
6. For transfers between a Distribution System operated by a Licensed Distribution System Operator and Generating Plant, the DMP shall be at the point(s) of connection of the generating station to the Distribution System operated by ~~the~~ Licensed Distribution System Operator.

Formatted: Font: Do not check spelling or grammar

7. For transfers between the Distribution System ~~operated by~~ a Licensed Distribution System Operator and a Customer, the DMP shall be at the point(s) of connection to the Distribution System ~~operated by~~ the Licensed Distribution System Operator.
8. For transfers between ~~the~~ Transmission System ~~operator~~ and a Customer, the DMP shall be at the point(s) of connection to the Transmission System.
9. For transfers between ~~the~~ Transmission System ~~operator~~, or a Distribution System operated by a Licensed Distribution System Operator, and an External System the DMP shall be at the point(s) of connection of that External System to the Transmission System or to the Distribution System operated by a Licensed Distribution System Operator as follows:-
 - ~~(i) For the EdF link the busbar side of the busbar disconnectors at the Sellindge 400 kV Substation.~~
 - ~~(ii) For the Moyle Interconnector, the Converter Station side of the L15 circuit breaker on the Coylton feeder at Auchenerosh Substation.~~
10. For transfers between an Offshore Transmission System (or Offshore Transmission System User Assets) and a Distribution System operated by a Licensed Distribution System Operator, the DMP shall be at the point(s) of connection to ~~the~~ Distribution System operated by a Licensed Distribution System Operator.

Formatted: Indent: Left: 0 cm