29th September 2017

Mike Smith
Elexon

Our ref.: Firmware version 3.5.x **Your ref.: CewePrometer R & W**

Dear Mr Smith,

In the last year we have had a new firmware version of the CewePrometer released in Europe and this is now due to be released to the UK market, as the new release does not change any communication protocols we have not needed to submit samples for protocol testing. We would now like to seek formal approval so we can release this new firmware to the market.

There are two main changes to the product

1. The Data refresh rate for Harmonics has been changed to 6 seconds instead of 1 second.
2. Support for DST calculation has been added based on algorithm.

No other function or protocol has been altered in the meter.

In line with our normal process of updating firmware we now release a new top-level number. We are therefore requesting formal approval for the new firmware 3.5.x

We would like to continue approving versions in the 3.5.x format if possible to allow minor changes, we would inform you of all changes that change either the function of the meter or the physical attributes or communication protocols.

Best regards

Ian Anthony

Technical Support
Manager

Cewe Instrument AB
Box 1006
SE-611 29 NYKÖPING
SWEDEN

Telephone **Telefax** **e-mail**

VAT No.
SE5563805646