



**Redlined Code of Practice Three 'The Metering of Circuits with a Rated Capacity not Exceeding 10 MVA for Settlement Purposes' text for CP1513 'Updates to BSCP601, CoP3 and CoP5'**

This CP proposes changes to section 5.1.3 we have redlined these changes against Version 13.0, which will go live as part of the June 2019 Release if Approved.

**There is no impact on any other part of this document for this CP.**

*Amend section 5.1.3 as follows:*

### 5.1.3 Measurement Transformers Installed on Existing Circuits

Where circuits, other than those newly installed, are to be metered to this Code of Practice and where the installed measurement transformers do not comply with the class accuracies specified in clauses 5.1.1 & 5.1.2, then such measurement transformers may be used providing the following requirements and those in clause 4.3.1 are met:-

- (i) Where subsequently a significant alteration to the primary plant (e.g. a switchgear change) is carried out, new measurement transformers as detailed in clauses 5.1.1 and 5.1.2, shall be provided.
- (ii) In all other respects the requirements of clauses 5.1.1 and 5.1.2 are met, except that where test certificates are not available other documentary evidence as referred to in clause 4.[32](#).2 shall be available.