

Redlined BSCP514 'SVA Meter Operations for Metering Systems Registered in SMRS' text for CP1514 'The number of register digits for smart Meters'

This CP proposes changes to section 1.2. We have redlined these changes against Version 35.0.

There is no impact on any other part of this document for this CP.

Amend section 1.2 as follows:

1.2 Main Users of Procedure and their Responsibilities

This BSCP should be used by Suppliers and their Agent(s) (including MOAs) and Data Collectors (DCs), the SVA Agent(SVAA), by each Licensed Distribution System Operator (LDSO) and the BSCCo Transfer Co-ordinator where MS are being transferred from Central Meter Registration Service (CMRS) to SMRS and vice versa.

All Supplier Agents using this BSCP shall be appropriately Qualified (in SVA and if operating in Central Volume Allocation (CVA), additionally CVA Qualified).

The MOA shall perform the responsibilities and obligations set out in this BSCP for a MS for all Settlement Days for which the MOA is appointed by the Supplier in SMRS.

Where the same Metering Equipment (ME) in SVA is being utilised for the measurement of the Import and/or Export Energy for more than one MSID at a site, the Supplier(s) shall ensure that the same MOA is appointed for all the MSIDs involved to comply with the requirements of the BSC. Where there is an Import Supplier and an Export Supplier the obligation rests with the Export Supplier to appoint the same MOA as the Import Supplier. Otherwise, these obligations shall be fulfilled by mutual agreement between the Suppliers involved.

Where the same ME is being utilised for the measurement of Import by SMRS and Export by CMRS, the same MOA shall be appointed to all the Import and Export Meters. The Party which is the Registrant of the CVA MS shall secure that the same person is appointed as MOA in relation to the CVA MS as is appointed in relation to the SVA MS. This MOA shall be Qualified for both SVA and CVA operations.

For NHH MS, any Meter reading(s) required for processes described in this BSCP may be obtained remotely where communication equipment is installed for the SVA MS in question.

When retrieving any reading(s) from a Meter of type SMETS 2 Version 3.1 or above (or for other Meter Types where there is known to be a difference between the number of digits held in the internal register and those displayed on the Meter), the reading(s) should be consistent with the number of register digits displayed on the display of the Metering System. In the event where an internal reading is retrieved (e.g. via a handheld device), the leading digits from the reading should be truncated such that the number of digits are consistent with the display of the Metering System.

In the case where the MOA cannot complete the required processes in this BSCP, this shall be reported to the Supplier and the Supplier shall resolve as appropriate.

The SVAA will be managing the Market Domain Data in addition to performing the Supplier Volume Allocation role, and therefore SVAA is the Market Domain Data Manager (MDDM).